

Aug 17 04 02:06p IBM USER
From: RJ Lee Group, Inc. To: Mr Noel Drago

732 6018

P.3

Date: 8/17/2004 Time: 9:17:13 AM

Page 2 of 3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
PA

Report Date: 8/6/2004
Sample Receipt Date: 8/5/2004
RJ Lee Group Job No.: ATH306366-961
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
		Start	Stop								Analytical Sensitivity (S/mm ²)	(S/cc)
29079 HT	Field Blank	8/4/2004	8/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	325	0.000	0.08839	0 0	< 11.5 11.3	N/A N/A
29080 HT	Area	8/4/2004	8/4/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1848.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005
29082 HT	Area	8/4/2004	8/4/2004	99	N/A	(East) - Greenwich	335	1896.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005
29081 HT	Area	8/4/2004	8/4/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1868.00	0.04420	0 0	22.6 22.6	< 0.005 0.005
29083 HT	Area	8/4/2004	8/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1924.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005

Authorized Signature:

 /sfb
Kimberly A. Allison, Manager - TEM Analysis

Notes:

Volumes provided by Ambient were used to calculate analytical results and sensitivities.

" " indicates results less than analytical sensitivity. " " indicates that sample was not analyzed.

Samples for this project were analyzed at our Monroeville, PA (PA GVI AP #101308-0, NY ELAP #10644) facility.

If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.

Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.

Samples will be held for 90 days and then disposed of per Federal regulations.

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 17 04 02:07p

IBM USER

732 8018

p. 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
PA

Report Date: 8/6/2004
Sample Receipt Date: 8/6/2004
RJ Lee Group Job No.: ATH306366-968
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
		Start	Stop								(S/mm ²)	(S/cc)
29099.HT	Field Blank	8/4/2004	8/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08839	0 0	< 11.3 11.3	N/A N/A
29100.HT	Area	8/4/2004	8/4/2004	99	Not Acquired	(SouthWest) - Washington and Albany	345	1908.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005
29101.HT	Area	8/4/2004	8/4/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2001.75	0.04420	0 0	< 22.6 22.6	< 0.004 0.004
29102.HT	Area	8/4/2004	8/4/2004	99	N/A	(East) - Greenwich	335	1864.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005
29103.HT	Area	8/4/2004	8/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1832.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005
29104.HT	Field Blank	8/4/2004	8/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08839	0 0	< 11.3 11.3	N/A N/A
29105.HT	Area	8/4/2004	8/5/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1992.00	0.04420	0 0	< 22.6 22.6	< 0.004 0.004
29106.HT	Area	8/4/2004	8/5/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1992.00	0.04420	0 0	< 22.6 22.6	< 0.004 0.004
29107.HT	Area	8/4/2004	8/5/2004	99	N/A	(East) - Greenwich	385	1984.00	0.04420	0 0	< 22.6 22.6	< 0.004 0.004
29108.HT	Area	8/4/2004	8/5/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1996.00	0.04420	0 0	< 22.6 22.6	< 0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.

2. "—" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.

3. Samples for this project were analyzed at our Monroeville, PA (NYLAP #101208-0, NY ELAP #10644) facility.

4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.

5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.

6. Samples will be held for 90 days and then disposed of per Federal regulations.

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 17 04 02:07p

IBM USER

732 6018

p.5

Date: 8/16/2004 Time: 0:00:00 PM

Page 3 of 4

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-968

RJ Lee Group, Inc.

Building: 130 Liberty

Report Date: 8/6/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

- Volumes provided by Ambienta were used to calculate analytical results and sensitivities.
- "-" indicates results less than analytical sensitivity. "...." indicates that sample was not analyzed.
- Samples for this project were analyzed at our: Monroeville, PA (NYLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.