

Aug 17 04 02:02p

IBM USER

732 6018

p.3

Date: 08/20/04 Time: 2:20 PM

Page 2 of 3

RJ LeeGroup, Inc.

8/2

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 8/3/2004
Sample Receipt Date: 8/3/2004
RJ Lee Group Job No.: ATH306306-950
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
		Start	Stop								Analytical Sensitivity (S/mm ²)	(S/cc)
5227233.HT	Field Blank	8/2/2004	8/2/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08792	0 0	< 11.4 11.4	N/A N/A
5227234.HT	Area	8/2/2004	8/2/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1904.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227235.HT	Area	8/2/2004	8/2/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1924.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227236.HT	Area	8/2/2004	8/2/2004	99	N/A	(East) - Greenwich	385	1940.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227237.HT	Area	8/2/2004	8/2/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1952.00	0.04396	0 0	< 22.7 22.7	< 0.004 0.004

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- Indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Samples for this project were analyzed at our Monroeville, PA (NYLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 17 04 02:02p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 8/5/2004 Time: 1:43:36 PM

P. 4
Page 2 of 3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
PA

Report Date: 8/5/2004
Sample Receipt Date: 8/4/2004
RJ Lee Group Job No.: ATH306366-059
Samples Received: 0
Building: 130 Liberty

Enacted: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (nm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
16758 HT	Area	8/3/2004	8/3/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1884.00	0.04420	0	0	< 22.6 22.6	< 0.005 0.005
16758 HT	Area	8/3/2004	8/3/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1860.00	0.04420	0	0	< 22.6 22.6	< 0.005 0.005
122616 HT	Area	8/3/2004	8/3/2004	99	N/A	(East) - Greenwich	335	1908.00	0.04420	0	0	< 22.6 22.6	< 0.005 0.005
16757 HT	Field Blank	8/3/2004	8/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08839	0	0	< 11.3 11.3	N/A N/A
122616 HT	Area	8/3/2004	8/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1932.00	0.04420	0	0	< 22.6 22.6	< 0.005 0.005

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

Volumes provided by Ambient were used to calculate analytical results and sensitivities.

"-" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.

Samples for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility

If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values

Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures

Samples will be held for 90 days and then disposed of per Federal regulations.

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.