

Aug 17 04 10:08a

IBM USER

732 6018

p.2

7/30

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/31/2004
Sample Receipt Date: 7/31/2004
RJ Lee Group Job No.: ATH306366-945
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5226415.HT	Field Blank	7/30/2004	7/30/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0	0	< 11.4 11.4	N/A N/A
5226416.HT	Area	7/30/2004	7/30/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1912.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5226417.HT	Area	7/30/2004	7/30/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1928.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5226418.HT	Area	7/30/2004	7/30/2004	99	N/A	(East) - Greenwich	385	1952.00	0.04396	0	0	< 22.7 22.7	< 0.004 0.004
5226419.HT	Area	7/30/2004	7/30/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1964.00	0.04396	0	0	< 22.7 22.7	< 0.004 0.004

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "----" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 1 of 2

Aug 17 04 01:57p

IBM USER

732 6018

p.2

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/31/2004
Sample Receipt Date: 7/31/2004
RJ Lee Group Job No.: ATH306366-945
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5226415.HT	Field Blank	7/30/2004	7/30/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0	0	< 11.4 11.4	N/A N/A
5226416.HT	Area	7/30/2004	7/30/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1912.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5226417.HT	Area	7/30/2004	7/30/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1928.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5226418.HT	Area	7/30/2004	7/30/2004	99	N/A	(East) - Greenwich	385	1952.00	0.04396	0	0	< 22.7 22.7	< 0.004 0.004
5226419.HT	Area	7/30/2004	7/30/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1964.00	0.04396	0	0	< 22.7 22.7	< 0.004 0.004

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 1 of 2