

Aug 17 04 01:58p

IBM USER

732 6018

p. 4

Date: 8/4/2004 Time: 10:12:10 AM

Page 2 of 4

RJ LeeGroup, Inc.

7/31

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 8/4/2004
Sample Receipt Date: 8/3/2004
RJ Lee Group Job No.: ATH306366-952
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity (S/mm ²) (S/cc)
5227189.HT	Field Blank	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08792	0 0	< 11.4 11.4 N/A N/A
127190.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1888.00	0.04396	0 0	< 22.7 22.7 < 0.005 0.005
5227192.HT	Area	7/31/2004 7/31/2004	99	N/A	(East) - Greenwich	335	1876.00	0.04396	0 0	< 22.7 22.7 < 0.005 0.005
7191.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1876.00	0.04396	0 0	< 22.7 22.7 < 0.005 0.005
5227200.HT	Field Blank	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08792	0 0	< 11.4 11.4 N/A N/A
5227193.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1876.00	0.04396	0 0	< 22.7 22.7 < 0.005 0.005
127201.HT	Area	7/31/2004 8/1/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	2072.00	0.04396	0 0	< 22.7 22.7 < 0.004 0.004
127202.HT	Area	7/31/2004 8/1/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	2076.00	0.04396	0 0	< 22.7 22.7 < 0.004 0.004
127203.HT	Area	7/31/2004 8/1/2004	99	N/A	(East) - Greenwich	335	2076.00	0.04396	0 0	< 22.7 22.7 < 0.004 0.004
127204.HT	Area	7/31/2004 8/1/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	2080.00	0.04396	0 0	< 22.7 22.7 < 0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.

"<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.

2. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.

3. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.

4. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.

5. Samples will be held for 90 days and then disposed of per Federal regulations.

6. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 17 04 01:57p

IBM USER

732 6018

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 8/3/2004 Time: 9:35:44 AM

Page 2 of 3 P. 3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report**TEM Air Analysis**

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 8/3/2004
Sample Receipt Date: 8/2/2004
RJ Lee Group Job No.: ATH306366-946
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5227174.HT	Field Blank	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0 0	< 11.4 11.4	N/A N/A
5227176.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1772.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227175.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1764.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227177.HT	Area	7/31/2004 7/31/2004	99	N/A	(East) - Greenwich	385	1772.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227178.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1776.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

Aug 17 04 10:08a IBM USER
From: RJ Lee Group, Inc To: Mr. Noel Drago

732 6018
Date: 8/3/2004 Time: 9:35:44 AM

Page 2 of 3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 8/3/2004
Sample Receipt Date: 8/2/2004
RJ Lee Group Job No.: ATH306366-946
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5227174.HT	Field Blank	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0 0	< 11.4 11.4	N/A N/A
5227176.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1772.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227175.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1764.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227177.HT	Area	7/31/2004 7/31/2004	99	N/A	(East) - Greenwich	385	1772.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227178.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1776.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005

Authorized Signature: _____

/s/

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

Aug 17 04 10:08a

IBM USER

732 6018

P. 4

Date: 8/12/2004 Time: 10:12:10 AM

Page 2 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 8/4/2004
Sample Receipt Date: 8/3/2004
RJ Lee Group Job No.: ATH306366-952
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mm ²)	(S/cc)
5227189.HT	Field Blank	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08792	0 0	< 11.4 11.4	N/A N/A
5227190.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1888.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227192.HT	Area	7/31/2004 7/31/2004	99	N/A	(East) - Greenwich	335	1876.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227191.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1876.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227200.HT	Field Blank	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08792	0 0	< 11.4 11.4	N/A N/A
5227193.HT	Area	7/31/2004 7/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1876.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227201.HT	Area	7/31/2004 8/1/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	2072.00	0.04396	0 0	< 22.7 22.7	< 0.004 0.004
5227202.HT	Area	7/31/2004 8/1/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	2076.00	0.04396	0 0	< 22.7 22.7	< 0.004 0.004
5227203.HT	Area	7/31/2004 8/1/2004	99	N/A	(East) - Greenwich	335	2076.00	0.04396	0 0	< 22.7 22.7	< 0.004 0.004
5227204.HT	Area	7/31/2004 8/1/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	2080.00	0.04396	0 0	< 22.7 22.7	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Samples for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.