

Aug 16 04 10:16a IBM USER
From: RJ Lee Group, Inc To: Mr. Noel Drago

732 6018
Date: 8/5/2004 Time: 1:48:36 PM

p. 9
Page 2 of 3

8/3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
PA

Report Date: 8/5/2004
Sample Receipt Date: 8/4/2004
RJ Lee Group Job No.: ATH306366-959
Samples Received: 0
Building: 130 Liberty

Period: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
16749 HT	Area	8/3/2004 8/3/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1834.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005
16758 HT	Area	8/3/2004 8/3/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1860.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005
12670 HT	Area	8/3/2004 8/3/2004	99	N/A	(East) - Greenwich	335	1908.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005
757 HT	Field Blank	8/3/2004 8/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08839	0 0	< 11.3 11.3	N/A N/A
12670 HT	Area	8/3/2004 8/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1931.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005

Authorized Signature

/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

Volumes provided by Ambient were used to calculate analytical results and sensitivities.

"-" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.

Samples for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.

If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.

Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures

Samples will be held for 90 days and then disposed of per Federal regulations.

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 16 04 10:16a

IBM USER

732 6018

p. 10

RJ Lee Group, Inc. 1000 W. 10th Street, Suite 100

Date: 8/16/2004 File: 1000 W. 10th Street

Page 2 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
PA

Report Date: 8/6/2004
Sample Receipt Date: 8/5/2004
RJ Lee Group Job No.: JATH300300-064
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mm ²)	(S/cc)
17641.HT	Field Blank	8/3/2004 8/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	345	0.000	0.08839	0 0	< 11.3 11.3	N/A N/A
17645.HT	Area	8/3/2004 8/3/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1904.00	0.04420	0 0	22.6 22.6	< 0.005 0.005
17646.HT	Area	8/3/2004 8/3/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1880.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005
17648.HT	Area	8/3/2004 8/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	345	1828.00	0.04420	0 0	< 22.6 22.6	0.005 0.005
17645.HT	Field Blank	8/3/2004 8/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08839	0 0	< 11.3 11.3	N/A N/A
17647.HT	Area	8/3/2004 8/3/2004	99	N/A	(East) - Greenwich	335	1850.00	0.04420	0 0	< 22.6 22.6	< 0.005 0.005
17648.HT	Area	8/3/2004 8/4/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	2065.00	0.04420	0 0	< 22.6 22.6	0.004 0.004
17647.HT	Area	8/3/2004 8/4/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	2012.00	0.04420	0 0	< 22.6 22.6	< 0.004 0.004
17649.HT	Area	8/3/2004 8/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	345	2016.00	0.04420	0 0	< 22.6 22.6	< 0.004 0.004
17648.HT	Area	8/3/2004 8/4/2004	99	N/A	(East) - Greenwich	345	2012.00	0.04420	0 0	< 22.6 22.6	< 0.004 0.004

Notes:

* Volumes provided by Ambient were used to calculate analytical results and sensitivities.

"-" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.

* Samples for this project were analyzed at our Monroeville, PA (NY/LAP #101208-0, NY ELAP #10844) facility.

If R. Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.

Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.

Samples will be held for 90 days and then disposed of per Federal regulations.

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Aug 16 04 10:17a

IBM USER

732 6018

p.11

RJ Lee Group, Inc. 130 Liberty

Date: 8/6/2004 Time: 10:20:02 AM

Page 3 of 4

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH3063-05-064
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 8/6/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (nm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
		Start	Stop							Chry	Amph	(S/mm ²)	(S/cc)

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

- 1. Values provided by Ambion were used to calculate analytical results and sensitivities.
- 2. "..." indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
- 3. Samples for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- 4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- 5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- 6. Samples will be held for 90 days and then disposed of per Federal regulations.
- 7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.