

Aug 16 04 10:43a IBM USER
from RJ Lee Group Inc. to Mr. Noel Drago

732 6018

p. 6

Date: 8/4/2004 Time: 10:40:38 AM

Page 2 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
PA

Report Date: 8/4/2004
Sample Receipt Date: 8/3/2004
RJ Lee Group Job No.: ATH306366-954
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chrys	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
227212.HT	Area	8/1/2004		99	Not	(South West) - Washington	335	1908.00	0.04396	0	0	5.227	5.0005

Aug 16 04 10:43a IBM USER
From RJ Lee Group Inc. To: Mr. Noel Drago

732 6018

Date: 8/4/2004 Time: 10:40:48 AM

p. 6

Page 2 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
PA

Report Date: 8/4/2004
Sample Receipt Date: 8/3/2004
RJ Lee Group Job No.: ATH300366-954
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (nm ²)	Volume (liter)	Area Analyzed (nm ²)	Concentration	
		Start	Stop							Asbestos Structures Chry Amph	Analytical Sensitivity (S/mm ²) (S/cc)
227212.HT	Area	8/1/2004		99	Not	(SouthWest) - Washington	335	1908.00	0.04396	0 0	522.7 <0.005