

Jun 22 04 03:12p

IBM USER

732 6018

p.10

6/19

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/19/2004
Sample Receipt Date: 6/19/2004
RJ Lee Group Job No.: ATH306366-796
Samples Received: 22
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity (S/m ³) (S/cc)
5220928.HT	Area	6/17/2004 6/17/2004	0	Z	(South) - Decon Exit	385	1644.00	0.05178	0 0	< 19.3 19.3 < 0.005 0.005
5220929.HT	Area	6/17/2004 6/17/2004	0	FF	(South) - Shanty Area	385	1644.00	0.05178	0 0	< 19.3 19.3 < 0.005 0.005
5220930.HT	Area	6/17/2004 6/17/2004	0	Y	(South) - Decon Entrances	385	1644.00	0.05178	0 0	< 19.3 19.3 < 0.005 0.005
5220931.HT	Area	6/17/2004 6/17/2004	0	X	(South) - Ramp	385	1640.00	0.05178	0 0	< 19.3 19.3 < 0.005 0.005
5220932.HT	Field Blank	6/17/2004 6/17/2004	0	X	(South) - Ramp	385	0.000	0.08630	0 0	< 11.6 11.6 N/A N/A
5220933.HT	Field Blank	6/17/2004 6/17/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08630	0 0	< 11.6 11.6 N/A N/A
5220934.HT	Area	6/17/2004 6/17/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1640.00	0.05178	0 0	< 19.3 19.3 < 0.005 0.005
5220935.HT	Area	6/17/2004 6/17/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1738.25	0.05178	0 0	< 19.3 19.3 < 0.004 0.004
5220936.HT	Area	6/17/2004 6/17/2004	99	N/A	(East) - Greenwich	385	1628.00	0.05178	0 0	< 19.3 19.3 < 0.005 0.005
5220937.HT	Area	6/17/2004 6/17/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1620.00	0.05178	1 0	19.3 19.3 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 5

Jun 22 04 03:13p

IBM USER

732 6018

p.11

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-796
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 6/19/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity (S/mm ²) (S/cc)
5220938.HT	Area	6/17/2004 6/17/2004	1	K	(NorthWest) - Cedar Decon	385	1612.00	0.05178	0 0	< 19.3 19.3 < 0.005 0.003
5221540.HT	Area	6/17/2004 6/18/2004	0	Z	(South) - Decon Exit	385	2012.00	0.04315	0 0	< 23.2 23.2 < 0.004 0.004
5221541.HT	Area	6/17/2004 6/18/2004	0	FF	(South) - Shanty Area	385	2012.00	0.04315	0 0	< 23.2 23.2 < 0.004 0.004
5221542.HT	Area	6/17/2004 6/18/2004	0	Y	(South) - Decon Entrance	385	2008.00	0.04315	0 0	< 23.2 23.2 < 0.004 0.004
5221543.HT	Area	6/17/2004 6/18/2004	0	X	(South) - Ramp	385	2008.00	0.04315	0 0	< 23.2 23.2 < 0.004 0.004
5221544.HT	Field Blank	6/17/2004 6/17/2004	0	X	(South) - Ramp	385	0.000	0.08630	0 0	< 11.6 11.6 N/A N/A
5221545.HT	Field Blank	6/17/2004 6/17/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08630	0 0	< 11.6 11.6 N/A N/A
5221546.HT	Area	6/17/2004 6/18/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2020.00	0.04315	0 0	< 23.2 23.2 < 0.004 0.004
5221547.HT	Area	6/17/2004 6/18/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2020.00	0.04315	0 0	< 23.2 23.2 < 0.004 0.004
5221548.HT	Area	6/17/2004 6/18/2004	99	N/A	(East) - Greenwich	385	2020.00	0.04315	0 0	< 23.2 23.2 < 0.004 0.004
5221549.HT	Area	6/17/2004 6/18/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2016.00	0.04315	0 0	< 23.2 23.2 < 0.004 0.004
5221550.HT	Area	6/17/2004 6/18/2004	1	K	(NorthWest) - Cedar Decon	385	2024.00	0.04315	0 0	< 23.2 23.2 < 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5

Jun 22 04 03:14p

IBM USER

732 6018

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/19/2004 Time: 9:05:00 PM

Page 4 of 5 P. 12

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-796
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/19/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
		Start Stop									Analytical Sensitivity (S/m ²)	(S/cc)

Authorized Signature: _____

 /s/b
Kimberly A. Allison, Manager - TEM Analysis**Notes:**

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 4 of 5