

Jul 02 04 02:27p
From: RJ Lee Group, Inc. to: Mr. Noel Urigo

IBM USER

732 6018

P. 12
6/22**RJ LeeGroup, Inc.**350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 6/24/2004
Sample Receipt Date: 6/23/2004
RJ Lee Group Job No.: ATH306366-805
Samples Received: 9
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start/Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mm ²)	(S/cc)
5223717.HT	Area	6/22/2004 6/22/2004	0	Z	(South) - Decon Exit	385	1880.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223718.HT	Area	6/22/2004 6/22/2004	0	FF	(South) - Shanty Area	385	1880.00	0.04317	1 0	23.2 23.2	0.005 0.005
5223719.HT	Area	6/22/2004 6/22/2004	0	Y	(South) - Decon Entrance	385	1880.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223720.HT	Area	6/22/2004 6/22/2004	0	X	(South) - Ramp	385	1880.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
223721.HT	Field Blank	6/22/2004 6/22/2004	0	X	(South) - Ramp	385	0.000	0.08633	0 0	< 11.6 11.6	N/A N/A
5223722.HT	Field Blank	6/22/2004 6/22/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08633	0 0	< 11.6 11.6	N/A N/A
5223723.HT	Area	6/22/2004 6/22/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1884.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223726.HT	Area	6/22/2004 6/22/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1888.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223727.HT	Area	6/22/2004 6/22/2004	1	K	(NorthWest) - Cedar Decon	385	1888.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 02 04 02:28p

IBM USER

732 6018

p.13

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/24/2004 Time: 11:00:00 AM

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-805
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 6/24/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
		Start Stop								Chry	Amph	(S/mm ²)	(S/cc)

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10644) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

Jul 02 04 02:28p

IBM USER

732 6018

P. 14

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/28/2004 Time: 8:39:02 AM

Page 3 of 5

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No. ATH306366-807
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/25/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity (S/mm ²) (S/cc)
5223237.HT	Area	6/22/2004 6/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2016.00	0.04317	0 0	< 23.2 23.2 < 0.004 0.004
5223217.HT	Area	6/22/2004 6/22/2004	0	Z	(South) - Decon Exit	385	1872.00	0.04317	0 0	< 23.2 23.2 < 0.005 0.005
5223219.HT	Area	6/22/2004 6/22/2004	0	Y	(South) - Decon Entrance	385	1868.00	0.04317	1 0	23.2 23.2 < 0.005 0.005
5223218.HT	Area	6/22/2004 6/22/2004	0	FF	(South) - Shanty Area	385	1872.00	0.04317	0 0	< 23.2 23.2 < 0.005 0.005
5223220.HT	Area	6/22/2004 6/22/2004	0	X	(South) - Ramp	385	1864.00	0.04317	0 0	< 23.2 23.2 < 0.005 0.005
5223221.HT	Field Blank	6/22/2004 6/22/2004	0	X	(South) - Ramp	385	0.000	0.08633	0 0	< 11.6 11.6 N/A N/A
5223222.HT	Field Blank	6/22/2004 6/22/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08633	0 0	< 11.6 11.6 N/A N/A
5223223.HT	Area	6/22/2004 6/22/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1743.75	0.05180	0 0	< 19.3 19.3 < 0.004 0.004
5223224.HT	Area	6/22/2004 6/22/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1732.50	0.05180	0 0	< 19.3 19.3 < 0.004 0.004
5223225.HT	Area	6/22/2004 6/22/2004	99	N/A	(East) - Greenwich	385	1836.00	0.04317	0 0	< 23.2 23.2 < 0.005 0.005
5223226.HT	Area	6/22/2004 6/22/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1840.00	0.04317	0 0	< 23.2 23.2 < 0.005 0.005
5223227.HT	Area	6/22/2004 6/22/2004	1	K	(NorthWest) - Cedar Decon	385	1832.00	0.04317	0 0	< 23.2 23.2 < 0.005 0.005

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #01208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5

Jul 02 04 02:29p

IBM USER

732 6018

p. 15

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/28/2004 Time: 9:39:02 AM

Page 2 of 5

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/25/2004
Sample Receipt Date: 6/24/2004
RJ Lee Group Job No.: ATH306366-807
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity (S/mm ²) (S/cc)
5223228.HT	Area	6/22/2004 6/23/2004	0	Z	(South) - Decon Exit	385	2008.00	0.04317	0 0	< 23.2 23.2 < 0.004 0.004
5223229.HT	Area	6/22/2004 6/23/2004	0	FF	(South) - Shanty Area	385	2008.00	0.04317	0 0	< 23.2 23.2 < 0.004 0.004
5223230.HT	Area	6/22/2004 6/23/2004	0	Y	(South) - Decon Entrance	385	2012.00	0.04317	0 0	< 23.2 23.2 < 0.004 0.004
5223231.HT	Area	6/22/2004 6/23/2004	0	X	(South) - Ramp	385	1890.00	0.04317	0 0	< 23.2 23.2 < 0.005 0.005
5223232.HT	Field Blank	6/22/2004 6/23/2004	0	X	(South) - Ramp	385	0.000	0.08633	0 0	< 11.6 11.6 N/A N/A
5223233.HT	Field Blank	6/22/2004 6/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08633	0 0	< 11.6 11.6 N/A N/A
5223235.HT	Area	6/22/2004 6/23/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1890.00	0.04317	0 0	< 23.2 23.2 < 0.005 0.005
5223234.HT	Area	6/22/2004 6/23/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2012.00	0.04317	0 0	< 23.2 23.2 < 0.004 0.004
5223236.HT	Area	6/22/2004 6/23/2004	99	N/A	(East) - Greenwich	385	1893.75	0.04317	0 0	< 23.2 23.2 < 0.005 0.005
5223238.HT	Area	6/22/2004 6/23/2004	1	K	(NorthWest) - Cedar Decor.	385	2020.00	0.04317	0 0	< 23.2 23.2 < 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 5

Jul 02 04 02:30p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago732 6018
Date: 6/25/2004 Time: 9:35:22 AM

Page 4 of 5 p. 16

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-807
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/25/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical	
		Start Stop								Chry	Amph	S/mm ²	(S/cc)

Authorized Signature: _____



/sib

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101298-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 4 of 5