

Jul 02 04 05:23p

IBM USER

732 6018

P. 7

From: RJ Lee Group, Inc. To: Mr. Noel Urago

Date: 06/30/2004 Time: 09:00:00 AM

6/27

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-817
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/30/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
									Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5220542.HT	Area	6/27/2004 6/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1884.00	0.04325	0	0	< 23.1 23.1	< 0.005 0.005
5221762.HT	Area	6/27/2004 6/27/2004	99	N/A	(East) - Greenwich	385	1912.00	0.04325	0	0	< 23.1 23.1	< 0.005 0.005
5221761.HT	Area	6/27/2004 6/27/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1788.75	0.04325	0	0	< 23.1 23.1	< 0.005 0.005
5221763.HT	Area	6/27/2004 6/27/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1936.00	0.04325	0	0	< 23.1 23.1	< 0.005 0.005
5221764.HT	Area	6/27/2004 6/27/2004	1	K	(NorthWest) - Cedar Decon	385	1964.00	0.04325	0	0	< 23.1 23.1	< 0.005 0.005
5223669.HT	Area	6/27/2004 6/27/2004	0	Z	(South) - Decon Exit	385	1896.00	0.04325	0	0	< 23.1 23.1	< 0.005 0.005
5223671.HT	Area	6/27/2004 6/27/2004	0	Y	(South) - Decon Entrance	385	1896.00	0.04325	0	0	< 23.1 23.1	< 0.005 0.005
5223670.HT	Area	6/27/2004 6/27/2004	0	FF	(South) - Shanty Area	385	1896.00	0.04325	0	0	< 23.1 23.1	< 0.005 0.005
5223672.HT	Area	6/27/2004 6/27/2004	0	X	(South) - Ramp	385	1892.00	0.04325	0	0	< 23.1 23.1	< 0.005 0.005
5223673.HT	Field Blank	6/27/2004 6/27/2004	0	X	(South) - Ramp	385	0.000	0.08650	0	0	< 11.6 11.6	N/A N/A
5223675.HT	Area	6/27/2004 6/27/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1777.50	0.05190	0	0	< 19.3 19.3	< 0.004 0.004
5223674.HT	Field Blank	6/27/2004 6/27/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08650	0	0	< 11.6 11.6	N/A N/A

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5

Jul 02 04 05:24p

IBM USER

732 6018

p. 8

From: RJ Lee Group, Inc. To: Mr. Noel Drago

DATE: 07/02/2004 TIME: 05:24 PM

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 6/30/2004
Sample Receipt Date: 6/29/2004
RJ Lee Group Job No.: ATH306366-817
Samples Received: 22
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5220533.HT	Area	6/27/2004 6/28/2004	0	Z	(South) - Decon Exit	385	1912.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220534.HT	Area	6/27/2004 6/28/2004	0	FF	(South) - Shanty Area	385	1908.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220536.HT	Area	6/27/2004 6/28/2004	0	X	(South) - Ramp	385	1904.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220535.HT	Area	6/27/2004 6/28/2004	0	Y	(South) - Decon Entrance	385	1908.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220537.HT	Field Blank	6/27/2004 6/27/2004	0	X	(South) - Ramp	385	0.000	0.08650	0 0	< 11.6 11.6	N/A N/A
5220538.HT	Field Blank	6/27/2004 6/27/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08650	0 0	< 11.6 11.6	N/A N/A
5220539.HT	Area	6/27/2004 6/28/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2023.00	0.04325	0 0	< 23.1 23.1	< 0.004 0.004
5220540.HT	Area	6/27/2004 6/28/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1900.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220541.HT	Area	6/27/2004 6/28/2004	99	N/A	(East) - Greenwich	385	1888.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005
5220543.HT	Area	6/27/2004 6/28/2004	1	K	(NorthWest) - Cedar Decon	385	1884.00	0.04325	0 0	< 23.1 23.1	< 0.005 0.005

Notes:

1. Volumes provided by Ambien were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

Jul 02 04 05:25p

IBM USER

732 6018

P. 8

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-817
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 6/30/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVI.AP #101208-0, NY RI.AP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 4 of 5

Jul 02 04 05:26p

IBM USER

732 6018

p.10

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 6/30/2004
Sample Receipt Date: 6/29/2004
RJ Lee Group Job No.: ATH306366-818
Samples Received: 11
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity (3/min) (S/cc)
5220512.HT	Area	6/27/2004 6/28/2004	0	Z	(South) - Decon Exit	385	7620.00	0.03460	0 0	<28.9 28.9 <0.001 0.001
5220514.HT	Area	6/27/2004 6/28/2004	0	Y	(South) - Decon Entrance	385	7628.00	0.03460	0 0	<28.9 28.9 <0.001 0.001
5220516.HT	Field Blank	6/27/2004 6/28/2004	0	X	(South) - Ramp	385	0.000	0.08650	0 0	<11.6 11.6 N/A N/A
5220515.HT	Area	6/27/2004 6/28/2004	0	X	(South) - Ramp	385	7135.80	0.03460	0 0	<28.9 28.9 <0.002 0.002
5220517.HT	Area	6/27/2004 6/28/2004	0	FF	(South) - Shanty Area	385	7592.00	0.03460	0 0	<28.9 28.9 <0.001 0.001
5220517.HT	Field Blank	6/27/2004 6/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08650	0 0	<11.6 11.6 N/A N/A
5220518.HT	Area	6/27/2004 6/28/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	7632.00	0.03460	0 0	<28.9 28.9 <0.001 0.001
5220520.HT	Area	6/27/2004 6/28/2004	99	N/A	(East) - Greenwich	385	7624.00	0.03460	0 0	<28.9 28.9 <0.001 0.001
5220519.HT	Area	6/27/2004 6/28/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	7147.50	0.03460	00 00	<28.9 28.9 <0.002 0.002
5220521.HT	Area	6/27/2004 6/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	7608.00	0.03460	0 0	<28.9 28.9 <0.001 0.001

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NYLAP #101288-6; NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 02 04 05:27p

IBM USER

732 6018

P. 11

From: RJ Lee Group, Inc. To: Mr. Noel Uruga

DATE: 06/30/2004 TIME: 09:00:00 AM

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-818
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/30/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mn ²)	(S/cc)
5220522.HT	Area	6/27/2004		1	K	(NorthWest) - Cedar Decon	385	7580.00	0.03460	0	0	< 28.9	< 0.001
		6/28/2004										28.9	0.001

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "--" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4