

Jul 09 04 08:26a

IBM USER

732 6018

P. 14

7/2

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/3/2004
Sample Receipt Date: 7/3/2004
RJ Lee Group Job No.: ATH306366-842
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5226102.HT	Area	7/2/2004 7/2/2004	0	Z	(South) - Decon Exit	385	1832.00	0.04358	0 0	< 22.9 22.9	< 0.005 0.005
5226103.HT	Area	7/2/2004 7/2/2004	0	FF	(South) - Shanty Area	385	1832.00	0.04358	0 0	< 22.9 22.9	< 0.005 0.005
5226104.HT	Area	7/2/2004 7/2/2004	0	Y	(South) - Decon Entrance	385	1832.00	0.04358	0 0	< 22.9 22.9	< 0.005 0.005
5226105.HT	Area	7/2/2004 7/2/2004	0	X	(South) - Ramp	385	1828.00	0.04358	1 0	22.9 22.9	0.005 0.005
5226106.HT	Field Blank	7/2/2004 7/2/2004	0	X	(South) - Ramp	385	0.000	0.08717	0 0	< 11.5 11.5	N/A N/A
5226112.HT	Area	7/2/2004 7/2/2004	1	K	(NorthWest) - Cedar Decon	385	1860.00	0.04358	0 0	< 22.9 22.9	< 0.005 0.005

Authorized Signature: _____ /s/b

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

Jul 09 04 08:27

IBM USER

732 6018

p.15

From: RJ Lee Group, Inc. To: Mr. Noel Urugo

Date: 7/23/2004

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
 Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
 350 Hochberg Road
 Monroeville, PA 15146
 USA

Report Date: 7/3/2004
 Sample Receipt Date: 7/3/2004
 RJ Lee Group Job No.: ATH306366-843
 Samples Received: 0
 Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
									Chry	Amph	Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5226108.HT	Area	7/2/2004 7/2/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1832.00	0.04358	0	0	< 22.9 22.9	< 0.005 0.005
5226107.HT	Field Blank	7/2/2004 7/2/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08717	0	0	< 11.5 11.5	N/A N/A
5226109.HT	Area	7/2/2004 7/2/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1840.00	0.04358	0	0	< 22.9 22.9	< 0.005 0.005
5226110.HT	Area	7/2/2004 7/2/2004	99	N/A	(East) - Greenwich	385	1852.00	0.04358	0	0	< 22.9 22.9	< 0.005 0.005
5226111.HT	Area	7/2/2004 7/2/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1852.00	0.04358	0	0	< 22.9 22.9	< 0.005 0.005

Authorized Signature: _____ /s/lb

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/7/2004
Sample Receipt Date: 7/6/2004
RJ Lee Group Job No.: ATH306366-845
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Sensitivity (S/cc)
5226113.HT	Area	7/2/2004 7/2/2004	0	Z	(South) - Decon Exit	385	2284.00	0.03492	0 0	< 28.6 28.6	< 0.005 0.005
5226115.HT	Area	7/2/2004 7/2/2004	0	Y	(South) - Decon Entrance	385	2288.00	0.03492	0 0	< 28.6 28.6	< 0.005 0.005
5226116.HT	Area	7/2/2004 7/2/2004	0	X	(South) - Ramp	385	2292.00	0.03492	0 0	< 28.6 28.6	< 0.005 0.005
5226117.HT	Field Blank	7/2/2004 7/2/2004	0	X	(South) - Ramp	385	0.000	0.08730	0 0	< 11.5 11.5	N/A N/A
5226123.HT	Area	7/2/2004 7/2/2004	1	K	(NorthWest) - Cedar Decon	385	2260.00	0.03492	0 0	< 28.6 28.6	< 0.005 0.005
5226135.HT	Area	7/2/2004 7/3/2004	0	FF	(South) - Shanty Area	385	1660.00	0.05238	0 0	< 19.1 19.1	< 0.004 0.004
5226114.HT	Area	7/2/2004 7/2/2004	0	FF	(South) - Shanty Area	385	2288.00	0.03492	0 0	< 28.6 28.6	< 0.005 0.005
5226136.HT	Area	7/2/2004 7/3/2004	0	Y	(South) - Decon Entrance	385	1656.00	0.05238	0 0	< 19.1 19.1	< 0.004 0.004
5226137.HT	Area	7/2/2004 7/3/2004	0	X	(South) - Ramp	385	1656.00	0.05238	0 0	< 19.1 19.1	< 0.004 0.004
5226144.HT	Area	7/2/2004 7/3/2004	1	K	(NorthWest) - Cedar Decon	385	1640.00	0.05238	0 0	< 19.1 19.1	< 0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 09 04 08:28a IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago732 6018
Date: 7/7/2004 Time: 3:02:58 PMp. 17
Page 3 of 4**RJ Lee Group, Inc.****Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-845
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 7/7/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Concentration		
		Start	Stop							Asbestos Structures Chry Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____



/s/

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/7/2004
Sample Receipt Date: 7/6/2004
RJ Lee Group Job No: ATH306366-844
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5226118.HT	Field Blank	7/2/2004 7/2/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08730	0 0	< 11.5 11.5	N/A N/A
5226119.HT	Area	7/2/2004 7/2/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2276.00	0.03492	0 0	< 28.6 28.6	< 0.005 0.005
5226121.HT	Area	7/2/2004 7/2/2004	99	N/A	(East) - Greenwich	385	2264.00	0.03492	0 0	< 28.6 28.6	< 0.005 0.005
5226120.HT	Area	7/2/2004 7/2/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2276.00	0.03492	0 0	< 28.6 28.6	< 0.005 0.005
5226122.HT	Area	7/2/2004 7/2/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2260.00	0.03492	0 0	< 28.6 28.6	< 0.005 0.005
5226140.HT	Area	7/2/2004 7/3/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1656.00	0.05238	0 0	< 19.1 19.1	< 0.004 0.004
5226139.HT	Field Blank	7/2/2004 7/2/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08730	0 0	< 11.5 11.5	N/A N/A
5226141.HT	Area	7/2/2004 7/3/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1648.00	0.05238	0 0	< 19.1 19.1	< 0.004 0.004
5226142.HT	Area	7/2/2004 7/3/2004	99	N/A	(East) - Greenwich	385	1652.00	0.05238	0 0	< 19.1 19.1	< 0.004 0.004
5226143.HT	Area	7/2/2004 7/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1652.00	0.05238	0 0	< 19.1 19.1	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 09 04 08:30a

IBM USER

732 6018

P. 19

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-844
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 7/7/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "---" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4