

Jul 09 04 08:31a IBM USER

732 6018

p. 20

7/3

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/7/2004
Sample Receipt Date: 7/6/2004
RJ Lee Group Job No.: ATH306366-846
Samples Received: 6
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5226150.HT	Area	7/3/2004 7/3/2004	0	Z	(South) - Decon Exit	385	1892.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5226151.HT	Area	7/3/2004 7/3/2004	0	FF	(South) - Shanty Area	385	1896.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5226152.HT	Area	7/3/2004 7/3/2004	0	Y	(South) - Decon Entrance	385	1900.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5226153.HT	Area	7/3/2004 7/3/2004	0	X	(South) - Ramp	385	1900.00	0.04365	1 0	22.9 22.9	0.005 0.005
5226160.HT	Area	7/3/2004 7/3/2004	1	K	(NorthWest) - Cedar Decon	385	1980.00	0.04365	0 0	< 22.9 22.9	< 0.004 0.004
5226154.HT	Field Blank	7/3/2004 7/3/2004	0	X	(South) - Ramp	385	0.000	0.08730	0 0	< 11.5 11.5	N/A N/A

Authorized Signature: _____



/s/ib

Kimberly A. Allison, Manager - TEM Analysis

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/7/2004
Sample Receipt Date: 7/6/2004
RJ Lee Group Job No.: ATH306366-847
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mm ²)	(S/cc)
5226156.HT	Area	7/3/2004 7/3/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1904.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5226155.HT	Field Blank	7/3/2004 7/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08730	0 0	< 11.5 11.5	N/A N/A
5226158.HT	Area	7/3/2004 7/3/2004	99	N/A	(East) - Greenwich	385	1948.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5226159.HT	Area	7/3/2004 7/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1972.00	0.04365	0 0	< 22.9 22.9	< 0.004 0.004
5226157.HT	Area	7/3/2004 7/3/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1928.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005

Authorized Signature: _____



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "----" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/8/2004
Sample Receipt Date: 7/7/2004
RJ Lee Group Job No: ATH306366-855
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5223606.HT	Area	7/3/2004 7/3/2004	99	N/A	(East) - Greenwich	385	1888.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5223605.HT	Area	7/3/2004 7/3/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1904.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5223604.HT	Area	7/3/2004 7/3/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1920.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5223603.HT	Field Blank	7/3/2004 7/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08730	0 0	< 11.5 11.5	N/A N/A
5220752.HT	Area	7/3/2004 7/4/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1908.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5223607.HT	Area	7/3/2004 7/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1747.50	0.05238	0 0	< 19.1 19.1	< 0.004 0.004
5220753.HT	Area	7/3/2004 7/4/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2137.50	0.04365	0 0	< 22.9 22.9	< 0.004 0.004
5220754.HT	Area	7/3/2004 7/4/2004	99	N/A	(East) - Greenwich	385	1892.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5220553.HT	Area	7/3/2004 7/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2006.00	0.04365	0 0	< 22.9 22.9	< 0.004 0.004
5220751.HT	Field Blank	7/3/2004 7/3/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08730	0 0	< 11.5 11.5	N/A N/A

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4


Jul 09 04 08:33a IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Urigo732 6018
Date: 7/8/2004 Time: 4:29:46 PM

Page 3 of 4 P. 23

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No. ATH306366-855
Building: 130 LibertyRJ Lee Group, Inc.
Report Date 7/8/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mmf)	(S/cc)

Authorized Signature



/slb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0), NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

Jul 09 04 08:34a

IBM USER

732 6018

p. 24

From: RJ Lee Group, Inc. To: Mr. Noel Urzigo

Date: 7/8/2004 Time: 4:20:34 PM

Page 2 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/8/2004
Sample Receipt Date: 7/7/2004
RJ Lee Group Job No.: ATH306366-853
Samples Received: 12
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5220554.HT	Area	7/3/2004 7/4/2004	1	K	(NorthWest) - Cedar Decon	385	1888.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5220746.HT	Area	7/3/2004 7/4/2004	0	Z	(South) - Decon Exit	385	1920.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5220748.HT	Area	7/3/2004 7/4/2004	0	Y	(South) - Decon Entrance	385	1916.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5220749.HT	Area	7/3/2004 7/4/2004	0	X	(South) - Ramp	385	1912.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5220747.HT	Area	7/3/2004 7/4/2004	0	FF	(South) - Shanty Area	385	1916.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5223598.HT	Area	7/3/2004 7/3/2004	0	Z	(South) - Decon Exit	385	1920.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5220750.HT	Field Blank	7/3/2004 7/3/2004	0	X	(South) - Ramp	385	0.000	0.08730	0 0	< 11.5 11.5	N/A N/A
5223599.HT	Area	7/3/2004 7/3/2004	0	FF	(South) - Shanty Area	385	1928.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5223601.HT	Area	7/3/2004 7/3/2004	0	X	(South) - Ramp	385	1920.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5223600.HT	Area	7/3/2004 7/3/2004	0	Y	(South) - Decon Entrance	385	1800.00	0.04365	0 0	< 22.9 22.9	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "---" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 09 04 08:34a IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 7/8/2004 Time: 4:20:04 PM

Page 3 of 4 p. 25

RJ Lee Group, Inc.


Laboratory Report (cont.)

RJ Lee Group Job No: ATH306366-853
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 7/8/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures				Concentration Analytical Sensitivity	
									Chry	Amph	S-Structures		(S/mm ²)	(S/cc)
5223608.HT	Area	7/3/2004 7/3/2004	1	K	(NorthWest) - Cedar Decon	385	1864.00	0.04365	0	0			< 22.9 22.9	< 0.005 0.005
5223602.HT	Field Blank	7/3/2004 7/3/2004	0	X	(South) - Ramp	385	0.000	0.08730	0	0			< 11.5 11.5	N/A N/A

Authorized Signature: _____

 /sib
Kimberly A. Allison, Manager - TEM Analysis

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4