

Jul 09 04 08:35a IBM USER

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 7/8/2004 Time: 8:57:40 AM 732 6018

Page 2 of 4 P. 26

7/4

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/8/2004
Sample Receipt Date: 7/7/2004
RJ Lee Group Job No.: ATH306366-852
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
									Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5223628.HT	Area	7/4/2004 7/4/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1946.50	0.04365	0	0	< 22.9 22.9	< 0.005 0.005
5223629.HT	Area	7/4/2004 7/4/2004	99	N/A	(East) - Greenwich	385	1808.00	0.04365	1	0	22.9 22.9	0.005 0.005
5222714.HT	Area	7/4/2004 7/5/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1916.25	0.04365	0	0	< 22.9 22.9	< 0.005 0.005
5222715.HT	Area	7/4/2004 7/5/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2048.00	0.04365	0	0	< 22.9 22.9	< 0.004 0.004
5222713.HT	Field Blank	7/4/2004 7/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08730	0	0	< 11.5 11.5	N/A N/A
5222717.HT	Area	7/4/2004 7/5/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2048.00	0.04365	0	0	< 22.9 22.9	< 0.004 0.004
5223630.HT	Area	7/4/2004 7/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1744.00	0.05238	0	0	< 19.1 19.1	< 0.004 0.004
5223619.HT	Area	7/4/2004 7/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2104.00	0.04365	0	0	< 22.9 22.9	< 0.004 0.004
5223627.HT	Area	7/4/2004 7/4/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1736.25	0.05238	0	0	< 19.1 19.1	< 0.004 0.004
5223618.HT	Area	7/4/2004 7/4/2004	99	N/A	(East) - Greenwich	385	2036.00	0.04365	0	0	< 22.9 22.9	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 09 04 08:36a IBM USER

732 6018

p.27

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No. ATH305366-852
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 7/8/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
									Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5223617.HT	Area	7/4/2004 7/4/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2012.00	0.04365	0	0	< 22.9 22.9	< 0.004 0.004
5223616.HT	Area	7/4/2004 7/4/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1992.00	0.04365	0	0	< 22.9 22.9	< 0.004 0.004
5223615.HT	Field Blank	7/4/2004 7/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08730	0	0	< 11.5 11.5	N/A N/A

Authorized Signature.



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambienta were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NYLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/8/2004
Sample Receipt Date: 7/7/2004
RJ Lee Group Job No: ATH306366-851
Samples Received: 19
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5222708.HT	Area	7/4/2004 7/5/2004	0	Z	(South) - Decon Exit	385	2040.00	0.04365	0 0	< 22.9 22.9	< 0.004 0.004
5222709.HT	Area	7/4/2004 7/5/2004	0	FF	(South) - Shanty Area	385	1916.25	0.04365	0 0	< 22.9 22.9	< 0.005 0.005
5222710.HT	Area	7/4/2004 7/5/2004	0	Y	(South) - Decon Entrance	385	2044.00	0.04365	0 0	< 22.9 22.9	< 0.004 0.004
5222711.HT	Area	7/4/2004 7/5/2004	0	X	(South) - Ramp	385	2044.00	0.04365	0 0	< 22.9 22.9	< 0.004 0.004
5222712.HT	Field Blank	7/4/2004 7/4/2004	0	X	(South) - Ramp	385	0.000	0.08730	0 0	< 11.5 11.5	N/A N/A
5223611.HT	Area	7/4/2004 7/4/2004	0	FF	(South) - Shanty Area	385	1988.00	0.04365	0 0	< 22.9 22.9	< 0.004 0.004
5222718.HT	Area	7/4/2004 7/5/2004	1	K	(North West) - Cedar Decon	385	2044.00	0.04365	1 0	22.9 22.9	0.004 0.004
5223610.HT	Area	7/4/2004 7/4/2004	0	Z	(South) - Decon Exit	385	1984.00	0.04365	0 0	< 22.9 22.9	< 0.004 0.004
5223612.HT	Area	7/4/2004 7/4/2004	0	Y	(South) - Decon Entrance	385	1984.00	0.04365	0 0	< 22.9 22.9	< 0.004 0.004
5223613.HT	Area	7/4/2004 7/4/2004	0	X	(South) - Ramp	385	1984.00	0.04365	0 0	< 22.9 22.9	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101268-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 09 04 08:37a

IBM USER

732 6018

p. 29

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 7/8/2004 Time: 8:49:15 AM

Page 3 of 4

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No. ATH306366-851
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 7/8/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
									Chry	Amph	(S/mm ²)	(S/cc)
5223614.HT	Field Blank	7/4/2004 7/4/2004	0	X	(South) - Ramp	385	0.000	0.08730	0	0	< 11.5 11.5	N/A N/A
5223622.HT	Area	7/4/2004 7/4/2004	0	FF	(South) - Shanty Area	385	1852.00	0.04365	0	0	< 22.9 22.9	< 0.005 0.005
5223620.HT	Area	7/4/2004 7/4/2004	1	K	(NorthWest) - Cedar Decon	385	2136.00	0.04365	0	0	< 22.9 22.9	< 0.004 0.004
5223621.HT	Area	7/4/2004 7/4/2004	0	Z	(South) - Decon Exit	385	1856.00	0.04365	0	0	< 22.9 22.9	< 0.005 0.005
5223625.HT	Field Blank	7/4/2004 7/4/2004	0	X	(South) - Ramp	385	0.000	0.08730	0	0	< 11.5 11.5	N/A N/A
5223623.HT	Area	7/4/2004 7/4/2004	0	Y	(South) - Decon Entrance	385	1740.00	0.05238	0	0	< 19.1 19.1	< 0.004 0.004
5223624.HT	Area	7/4/2004 7/4/2004	0	X	(South) - Ramp	385	1860.00	0.04365	0	0	< 22.9 22.9	< 0.005 0.005
5223626.HT	Field Blank	7/4/2004 7/4/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08730	0	0	< 11.5 11.5	N/A N/A
5223631.HT	Area	7/4/2004 7/4/2004	1	K	(NorthWest) - Cedar Decon	385	1708.00	0.05238	0	0	< 19.1 19.1	< 0.004 0.004

Authorized Signature: _____



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4