

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
 Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
 350 Hochberg Road
 Monroeville, PA 15146
 USA

Report Date: 6/10/2004
 Sample Receipt Date: 6/9/2004
 RJ Lee Group Job No.: ATH306366-774
 Samples Received: 0
 Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
		Start	Stop							Chry	Amph	(S/m ²)	(S/cc)
5220806.HT	Area	6/8/2004	6/8/2004	1	K	(NorthWest) - Cedar Decon	385	2000.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220805.HT	Area	6/8/2004	6/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1996.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220804.HT	Area	6/8/2004	6/8/2004	99	N/A	(East) - Greenwich	385	1996.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220803.HT	Area	6/8/2004	6/8/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1976.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220801.HT	Field Blank	6/8/2004	6/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08537	0	0	< 11.7 11.7	N/A N/A
5220796.HT	Area	6/8/2004	6/8/2004	0	Z	(South) - Decon Exit	385	1952.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220802.HT	Area	6/8/2004	6/8/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1964.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220797.HT	Area	6/8/2004	6/8/2004	0	FF	(South) - Shanty Area	385	1948.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220798.HT	Area	6/8/2004	6/8/2004	0	Y	(South) - Decon Entrance	385	1960.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220799.HT	Area	6/8/2004	6/8/2004	0	X	(South) - Ramp	385	1960.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jun 25 04 12:52p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Urrego

Date: 6/10/2004 Time: 0:11:17 PM 732 6018

P. 3

RJ Lee Group, Inc.

Laboratory Report (cont.)

RJ Lee Group Job No: ATH306366-774
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 6/10/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5220800.HT	Field Blank	6/8/2004	6/8/2004	0	X	(South) - Ramp	385	0.000	0.08537	0	0	< 11.7 11.7	N/A N/A

Authorized Signature: _____



/s/

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NYLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
 Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
 350 Hochberg Road
 Monroeville, PA 15146
 USA

Report Date: 6/11/2004
 Sample Receipt Date: 6/10/2004
 RJ Lee Group Job No.: ATH306366-776
 Samples Received: 22
 Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5216883.HT	Area	6/8/2004 6/8/2004	0	Z	(South) - Decon Exit	385	1908.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5216885.HT	Area	6/8/2004 6/8/2004	0	Y	(South) - Decon Entrance	385	1896.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5216886.HT	Area	6/8/2004 6/8/2004	0	X	(South) - Ramp	385	1892.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5216884.HT	Area	6/8/2004 6/8/2004	0	FF	(South) - Shanty Area	385	1908.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5216887.HT	Field Blank	6/8/2004 6/8/2004	0	X	(South) - Ramp	385	0.000	0.08615	0 0	< 11.6 11.6	N/A N/A
5216890.HT	Area	6/8/2004 6/8/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1880.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5216888.HT	Field Blank	6/8/2004 6/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08615	0 0	< 11.6 11.6	N/A N/A
5216889.HT	Area	6/8/2004 6/8/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1892.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5216892.HT	Area	6/8/2004 6/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1864.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5216893.HT	Area	6/8/2004 6/8/2004	1	K	(NorthWest) - Cedar Decon	385	1864.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 5

Jun 25 04 12:53p

IBM USER

732 6018

p. 5

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-776
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 6/11/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity (S/mm ²) (S/cc)
5216891.HT	Area	6/8/2004 6/8/2004	99	N/A	(East) - Greenwich	385	1868.00	0.04308	0 0	< 23.2 23.2 < 0.005 0.005
5216913.HT	Area	6/8/2004 6/9/2004	0	Z	(South) - Decon Exit	385	1888.00	0.04308	0 0	< 23.2 23.2 < 0.005 0.005
5216916.HT	Area	6/8/2004 6/9/2004	0	FF	(South) - Shanty Area	385	1888.00	0.04308	0 0	< 23.2 23.2 < 0.005 0.005
5216917.HT	Area	6/8/2004 6/9/2004	0	Y	(South) - Decon Entrance	385	1888.00	0.04308	0 0	< 23.2 23.2 < 0.005 0.005
5216919.HT	Field Blank	6/8/2004 6/8/2004	0	X	(South) - Ramp	385	0.000	0.08615	0 0	< 11.6 11.6 N/A N/A
5216918.HT	Area	6/8/2004 6/9/2004	0	X	(South) - Ramp	385	1888.00	0.04308	0 0	< 23.2 23.2 < 0.005 0.005
5216920.HT	Field Blank	6/8/2004 6/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08615	0 0	< 11.6 11.6 N/A N/A
5216922.HT	Area	6/8/2004 6/9/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1892.00	0.04308	0 0	< 23.2 23.2 < 0.005 0.005
5216923.HT	Area	6/8/2004 6/9/2004	99	N/A	(East) - Greenwich	385	1888.00	0.04308	0 0	< 23.2 23.2 < 0.005 0.005
5216921.HT	Area	6/8/2004 6/9/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1888.00	0.04308	0 0	< 23.2 23.2 < 0.005 0.005
5216924.HT	Area	6/8/2004 6/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1896.00	0.04308	0 0	< 23.2 23.2 < 0.005 0.005
5216925.HT	Area	6/8/2004 6/9/2004	1	K	(NorthWest) - Cedar Decon	385	1892.00	0.04308	0 0	< 23.2 23.2 < 0.005 0.005

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5