

Jun 18 04 01:39p

IBM USER

732 6018

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/12/2004 Time: 7:19:34 PM

Page 2 of 4 P. 2
6/11**RJ LeeGroup, Inc.**

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report**TEM Air Analysis**RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 6/12/2004
Sample Receipt Date: 6/12/2004
RJ Lee Group Job No: ATH306366-781
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
		Start	Stop								Analytical Sensitivity (S/mm ²)	(S/cc)
5220255.HT	Area	6/11/2004	6/11/2004	0	Z	(South) - Decon Exit	385	1968.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5220256.HT	Area	6/11/2004	6/11/2004	0	FF	(South) - Shanty Area	385	1972.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5220258.HT	Area	6/11/2004	6/11/2004	0	X	(South) - Ramp	385	1976.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5220257.HT	Area	6/11/2004	6/11/2004	0	Y	(South) - Decon Entrance	385	1972.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5220259.HT	Field Blank	6/11/2004	6/11/2004	0	X	(South) - Ramp	385	0.000	0.08615	0 0	< 11.6 11.6	N/A N/A
5220260.HT	Field Blank	6/11/2004	6/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08615	0 0	< 11.6 11.6	N/A N/A
5220261.HT	Area	6/11/2004	6/11/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1976.00	0.04308	0 0	< 23.2 23.2	< 0.005 0.005
5220263.HT	Area	6/11/2004	6/11/2004	99	N/A	(East) - Greenwich	385	1996.00	0.04308	0 0	< 23.2 23.2	< 0.004 0.004
5220262.HT	Area	6/11/2004	6/11/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2108.00	0.04308	0 0	< 23.2 23.2	< 0.004 0.004
5220265.HT	Area	6/11/2004	6/11/2004	1	K	(NorthWest) - Cedar Decon	385	2032.00	0.04308	0 0	< 23.2 23.2	< 0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jun 18 04 01:39p

IBM USER

732 6018

p. 3

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/12/2004 Time: 7:19:34 PM

Page 3 of 4

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-781
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/12/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical	
		Start	Stop							Chry	Amph	(S/mm ²)	(S/cc)
5220264.HT	Area	6/11/2004	6/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2012.00	0.04308	0	0	< 23.2 23.2	< 0.004 0.004

Authorized Signature: _____ /sib

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

Jun 18 04 01:40p

IBM USER

732 6018

P. 4

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/18/2004 Time 2:51:30 PM

Page 2 of 5

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 6/16/2004
Sample Receipt Date: 6/14/2004
RJ Lee Group Job No.: ATH306366-782
Samples Received: 22
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5220031.HT	Area	6/11/2004	6/12/2004	0	Z	(South) - Decon Exit	385	1520.00	0.05201	0	0	< 19.2 19.2	< 0.005 0.005
5220032.HT	Area	6/11/2004	6/12/2004	0	FF	(South) - Shanty Area	385	1524.00	0.05201	0	0	< 19.2 19.2	< 0.005 0.005
5220034.HT	Area	6/11/2004	6/12/2004	0	X	(South) - Ramp	385	1528.00	0.05201	0	0	< 19.2 19.2	< 0.005 0.005
5220253.HT	Field Blank	6/11/2004	6/11/2004	0	X	(South) - Ramp	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5220254.HT	Field Blank	6/11/2004	6/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5220566.HT	Area	6/11/2004	6/11/2004	0	Z	(South) - Decon Exit	385	2272.00	0.03467	0	0	< 28.8 28.8	< 0.005 0.005
5220033.HT	Area	6/11/2004	6/12/2004	0	Y	(South) - Decon Entrances	385	1528.00	0.05201	0	0	< 19.2 19.2	< 0.005 0.005
5220567.HT	Area	6/11/2004	6/11/2004	0	FF	(South) - Shanty Area	385	2268.00	0.03467	0	0	< 28.8 28.8	< 0.005 0.005
5220569.HT	Area	6/11/2004	6/11/2004	0	X	(South) - Ramp	385	2268.00	0.03467	0	0	< 28.8 28.8	< 0.005 0.005
5220570.HT	Field Blank	6/11/2004	6/11/2004	0	X	(South) - Ramp	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 5

Jun 18 04 01:40p

IBM USER

732 6018

P. 5

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/18/2004 Time: 2:51:30 PM

Page 3 of 5

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-782
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/16/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
									Chry	Amph	(S/mm ²)	(S/cc)
5220568.HT	Area	6/11/2004 6/11/2004	0	Y	(South) - Decon Entrance	385	2268.00	0.03467	0	0	< 28.8 28.8	< 0.005 0.005
5220571.HT	Field Blank	6/11/2004 6/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5220572.HT	Area	6/11/2004 6/11/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2264.00	0.03467	0	0	< 28.8 28.8	< 0.005 0.005
5220574.HT	Area	6/11/2004 6/11/2004	99	N/A	(East) - Greenwich	385	2244.00	0.03467	0	0	< 28.8 28.8	< 0.005 0.005
5220573.HT	Area	6/11/2004 6/11/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2256.00	0.03467	0	0	< 28.8 28.8	< 0.005 0.005
5220575.HT	Area	6/11/2004 6/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2228.00	0.03467	0	0	< 28.8 28.8	< 0.005 0.005
5220850.HT	Area	6/11/2004 6/12/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1532.00	0.05201	0	0	< 19.2 19.2	< 0.005 0.005
5220576.HT	Area	6/11/2004 6/11/2004	1	K	(NorthWest) - Cedar Decon	385	2208.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5220851.HT	Area	6/11/2004 6/12/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1536.00	0.05201	0	0	< 19.2 19.2	< 0.005 0.005
5220852.HT	Area	6/11/2004 6/12/2004	99	N/A	(East) - Greenwich	385	1540.00	0.05201	0	0	< 19.2 19.2	< 0.005 0.005
5220853.HT	Area	6/11/2004 6/12/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1548.00	0.05201	0	0	< 19.2 19.2	< 0.005 0.005
5220854.HT	Area	6/11/2004 6/12/2004	1	K	(NorthWest) - Cedar Decon	385	1544.00	0.05201	0	0	< 19.2 19.2	< 0.005 0.005

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5