

Jun 18 04 01:41p

IBM USER

732 6018

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/16/2004 Time: 11:48:38 AM

Page 2 of 4

P. 6

6/18/12

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 6/16/2004
Sample Receipt Date: 6/14/2004
RJ Lee Group Job No.: ATH306366-783
Samples Received: 11
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chrys	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5216944.HT	Area	6/12/2004	6/12/2004	0	Z	(South) - Decon Exit	385	1980.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5216945.HT	Area	6/12/2004	6/12/2004	0	FF	(South) - Shanty Area	385	1996.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5216948.HT	Field Blank	6/12/2004	6/12/2004	0	X	(South) - Ramp	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5216947.HT	Area	6/12/2004	6/12/2004	0	X	(South) - Ramp	385	1996.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5216949.HT	Field Blank	6/12/2004	6/12/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5216951.HT	Area	6/12/2004	6/12/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2000.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5216952.HT	Area	6/12/2004	6/12/2004	99	N/A	(East) - Greenwich	385	2004.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5216953.HT	Area	6/12/2004	6/12/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2004.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5216950.HT	Area	6/12/2004	6/12/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2000.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5216954.HT	Area	6/12/2004	6/12/2004	1	K	(NorthWest) - Cedar Decon	385	2008.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "----" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jun 18 04 01:42p

IBM USER

732 6018

Page 3 of 4 P. 7


From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/16/2004 Time: 11:40:38 AM

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-783
Building: 130 LibertyRJ Lee Group, Inc.
Report Date:

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
									Chry	Amph	Analytical Sensitivity (S/mm ²)	(Sec)
5216946.HT	Area	6/12/2004 6/12/2004	0	Y	(South) - Decon Entrance	385	1996.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004

Authorized Signature:



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

Jun 18 04 01:42p

IBM USER

732 6018

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/18/2004 Time: 11:11:38 AM

Page 2 of 5 P. 8

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 6/16/2004
Sample Receipt Date: 6/15/2004
RJ Lee Group Job No.: ATH306366-784
Samples Received: 22
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mn ²)	(S/cc)
5220555.HT	Area	6/12/2004	6/12/2004	0	Z	(South) - Decon Exit	385	1860.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5220556.HT	Area	6/12/2004	6/12/2004	0	FF	(South) - Shanty Area	385	1844.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5220557.HT	Area	6/12/2004	6/12/2004	0	Y	(South) - Decon Entrance	385	1844.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5220558.HT	Area	6/12/2004	6/12/2004	0	X	(South) - Ramp	385	1728.75	0.05201	0	0	< 19.2 19.2	< 0.004 0.004
5220559.HT	Field Blank	6/12/2004	6/12/2004	0	X	(South) - Ramp	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5220560.HT	Field Blank	6/12/2004	6/12/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5220562.HT	Area	6/12/2004	6/12/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1836.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5220561.HT	Area	6/12/2004	6/12/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1836.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5220563.HT	Area	6/12/2004	6/12/2004	99	N/A	(East) - Greenwich	385	1832.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5220565.HT	Area	6/12/2004	6/12/2004	1	K	(NorthWest) - Cedar Decon	385	1824.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 5

Jun 18 04 01:43p IBM USER

From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 6/16/2004 Time: 11:11:38 AM

Page 3 of 5 P. 9

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-784
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/16/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
									Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5220564.HT	Area	6/12/2004 6/12/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1824.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223076.HT	Area	6/12/2004 6/13/2004	0	Z	(South) - Decon Exit	385	1996.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5223078.HT	Area	6/12/2004 6/13/2004	0	Y	(South) - Decon Entrance	385	1996.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5223077.HT	Area	6/12/2004 6/13/2004	0	FF	(South) - Shanty Area	385	1871.25	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223079.HT	Area	6/12/2004 6/13/2004	0	X	(South) - Ramp	385	1996.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5223080.HT	Field Blank	6/12/2004 6/12/2004	0	X	(South) - Ramp	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5223081.HT	Field Blank	6/12/2004 6/12/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5223082.HT	Area	6/12/2004 6/13/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1996.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5223083.HT	Area	6/12/2004 6/13/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1996.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5223085.HT	Area	6/12/2004 6/13/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1992.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5223084.HT	Area	6/12/2004 6/13/2004	99	N/A	(East) - Greenwich	385	1992.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5223086.HT	Area	6/12/2004 6/13/2004	1	K	(NorthWest) - Cedar Decon	385	1996.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5

Jun 18 04 01:44p

IBM USER

732 6018

Page 7 of 10 P. 10

From: RJ Lee Group, Inc. To: Mr. Noel Drago

DATE: 06/16/2004 TIME: 11:11:55 AM

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-784
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/16/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
		Start	Stop							Chry	Amph	(S/mm ²)	(S/cc)

Authorized Signature:



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 4 of 5