

Jun 18 04 01:45p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
DATE: 6/16/2004 TIME: 11:29:30 AM

Page 2 of 5 P. 11
6/13

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/16/2004
Sample Receipt Date: 6/15/2004
RJ Lee Group Job No.: ATH306366-785
Samples Received: 22
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5223087.HT	Area	6/13/2004	6/13/2004	0	Z	(South) - Decon Exit	385	1944.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223088.HT	Area	6/13/2004	6/13/2004	0	FF	(South) - Shanty Area	385	1822.50	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223090.HT	Area	6/13/2004	6/13/2004	0	X	(South) - Ramp	385	1940.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223089.HT	Area	6/13/2004	6/13/2004	0	Y	(South) - Decon Entrance	385	1944.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223091.HT	Field Blank	6/13/2004	6/13/2004	0	X	(South) - Ramp	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5223092.HT	Field Blank	6/13/2004	6/13/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5223094.HT	Area	6/13/2004	6/13/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1952.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223093.HT	Area	6/13/2004	6/13/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1940.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223095.HT	Area	6/13/2004	6/13/2004	99	N/A	(East) - Greenwich	385	1960.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223096.HT	Area	6/13/2004	6/13/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1960.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-3, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 5

Jun 18 04 01:45p

IBM USER

732 6018

p. 12

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/16/2004 Time: 11:24:38 AM

Page 3 of 5

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-785
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/16/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
		Start	Stop							Chry	Amph	(S/mm ²)	(S/cc)
5223097.HT	Area	6/13/2004	6/13/2004	1	K	(NorthWest) - Cedar Decon	385	2000.00	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5223099.HT	Area	6/13/2004	6/13/2004	0	FF	(South) - Shanty Area	385	1860.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223098.HT	Area	6/13/2004	6/13/2004	0	Z	(South) - Decon Exit	385	1860.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223101.HT	Area	6/13/2004	6/13/2004	0	X	(South) - Ramp	385	1976.25	0.04334	0	0	< 23.1 23.1	< 0.004 0.004
5223100.HT	Area	6/13/2004	6/13/2004	0	Y	(South) - Decon Entrance	385	1856.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223102.HT	Field Blank	6/13/2004	6/13/2004	0	X	(South) - Ramp	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5223104.HT	Area	6/13/2004	6/13/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1860.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223103.HT	Field Blank	6/13/2004	6/13/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08668	0	0	< 11.5 11.5	N/A N/A
5223106.HT	Area	6/13/2004	6/13/2004	99	N/A	(East) - Greenwich	385	1836.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223105.HT	Area	6/13/2004	6/13/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1844.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223107.HT	Area	6/13/2004	6/13/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1820.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005
5223108.HT	Area	6/13/2004	6/13/2004	1	K	(NorthWest) - Cedar Decon	385	1796.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #1 01208-0, NY ELAP #1 0844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5

Jun 18 04 01:46p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago732 6018
DATE: 01/04/2004 TIME: 11:29:30 AM

Page 4 of 5 P. 13

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-785
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/16/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature:



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #01208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 4 of 5

Jun 18 04 01:47p

IBM USER

732 6018

Page 2 of 4 P. 14

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/16/2004
Sample Receipt Date: 6/15/2004
RJ Lee Group Job No: ATH306366-786
Samples Received: 11
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Fiber	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5223119.HT	Area	6/13/2004 6/14/2004	0	Z	(South) - Decon Exit	385	1880.00	0.04334	0 0	< 23.1 23.1	< 0.005 0.005
5223120.HT	Area	6/13/2004 6/14/2004	0	FF	(South) - Shanty Area	385	1758.75	0.05201	0 0	< 19.2 19.2	< 0.004 0.004
5223121.HT	Area	6/13/2004 6/14/2004	0	Y	(South) - Decon Entrance	385	1884.00	0.04334	0 0	< 23.1 23.1	< 0.005 0.005
5223124.HT	Field Blank	6/13/2004 6/13/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08668	0 0	< 11.5 11.5	N/A N/A
5223122.HT	Area	6/13/2004 6/14/2004	0	X	(South) - Ramp	385	1770.00	0.05201	0 0	< 19.2 19.2	< 0.004 0.004
5223123.HT	Field Blank	6/13/2004 6/13/2004	0	X	(South) - Ramp	385	0.000	0.08668	0 0	< 11.5 11.5	N/A N/A
5223125.HT	Area	6/13/2004 6/14/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1888.00	0.04334	0 0	< 23.1 23.1	< 0.005 0.005
5223126.HT	Area	6/13/2004 6/14/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1888.00	0.04334	0 0	< 23.1 23.1	< 0.005 0.005
5223127.HT	Area	6/13/2004 6/14/2004	99	N/A	(East) - Greenwich	385	1892.00	0.04334	0 0	< 23.1 23.1	< 0.005 0.005
5223128.HT	Area	6/13/2004 6/14/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1892.00	0.04334	0 0	< 23.1 23.1	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jun 18 04 01:48p IBM USER

732 6018
DATE: 6/16/2004 TIME: 11:00:15 AM

Page 3 of 4 P. 15

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-786

RJ Lee Group, Inc.

Building: 130 Liberty

Report Date: 6/16/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5223129.HT	Area	6/13/2004	6/14/2004	1	K	(NorthWest) - Cedar Decon	385	1896.00	0.04334	0	0	< 23.1 23.1	< 0.005 0.005

Authorized Signature:



/s/

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "--" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4