

Jul 02 04 02:23p

IBM USER

732 6018

P. 7

6/21

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 6/23/2004
Sample Receipt Date: 6/22/2004
RJ Lee Group Job No.: ATH306366-803
Samples Received: 11
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5223853.HT	Area	6/21/2004 6/21/2004	0	Z	(South) - Decon Exit	385	1896.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223854.HT	Area	6/21/2004 6/21/2004	0	FF	(South) - Shanty Area	385	1900.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223856.HT	Area	6/21/2004 6/21/2004	0	X	(South) - Ramp	385	1896.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223857.HT	Field Blank	6/21/2004 6/21/2004	0	X	(South) - Ramp	385	0.000	0.08633	0 0	< 11.6 11.6	N/A N/A
5223855.HT	Area	6/21/2004 6/21/2004	0	Y	(South) - Decon Entrance	385	1896.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223858.HT	Field Blank	6/21/2004 6/21/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08633	0 0	< 11.6 11.6	N/A N/A
5223859.HT	Area	6/21/2004 6/21/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1908.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223861.HT	Area	6/21/2004 6/21/2004	99	N/A	(East) - Greenwich	385	1932.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223860.HT	Area	6/21/2004 6/21/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1920.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223862.HT	Area	6/21/2004 6/21/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1956.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 02 04 02:24p

IBM USER

732 6018

p. 8

From: RJ Lee Group, Inc. To: Mr. Noah Drago

Date: 6/23/2004 Time: 10:00:00 AM

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-803
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/23/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Concentration			
									Asbestos Structures		Analytical Sensitivity	
									Chry	Amph	(S/mm ²)	(S/cc)
5223863.HT	Area	6/21/2004 6/21/2004	1	K	(NorthWest) - Cedar Decon	385	1984.00	0.04317	0	0	< 23.2 23.2	< 0.004 0.004

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-804
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date 6/24/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical	
									Chry	Amph	(S/mm ²)	(S/cc)
5223738.HT	Area	6/21/2004 6/22/2004	1	K	(NorthWest) - Cedar Decon	385	2184.00	0.04317	0	0	< 23.2 23.2	< 0.004 0.004
5223748.HT	Area	6/21/2004 6/21/2004	0	Z	(South) - Decon Exit	385	1724.00	0.05180	0	0	< 19.3 19.3	< 0.004 0.004
5223749.HT	Area	6/21/2004 6/21/2004	0	FF	(South) - Shanty Area	385	1616.25	0.05180	0	0	< 19.3 19.3	< 0.005 0.005
5223750.HT	Area	6/21/2004 6/21/2004	0	Y	(South) - Decon Entrance	385	1616.25	0.05180	0	0	< 19.3 19.3	< 0.005 0.005
5223751.HT	Area	6/21/2004 6/21/2004	0	X	(South) - Ramp	385	1620.00	0.05180	0	0	< 19.3 19.3	< 0.005 0.005
5223752.HT	Field Blank	6/21/2004 6/21/2004	0	X	(South) - Ramp	385	0.000	0.08633	0	0	< 11.6 11.6	N/A N/A
5223753.HT	Field Blank	6/21/2004 6/21/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08633	0	0	< 11.6 11.6	N/A N/A
5223754.HT	Area	6/21/2004 6/21/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1720.00	0.05180	0	0	< 19.3 19.3	< 0.004 0.004
5223755.HT	Area	6/21/2004 6/21/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1601.25	0.05180	0	0	< 19.3 19.3	< 0.005 0.005
5223756.HT	Area	6/21/2004 6/21/2004	99	N/A	(East) - Greenwich	385	1700.00	0.05180	0	0	< 19.3 19.3	< 0.004 0.004
5223757.HT	Area	6/21/2004 6/21/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1676.00	0.05180	0	0	< 19.3 19.3	< 0.004 0.004
5223758.HT	Area	6/21/2004 6/21/2004	1	K	(NorthWest) - Cedar Decon	385	1648.00	0.05180	0	0	< 19.3 19.3	< 0.005 0.005

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10644) facility
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/24/2004
Sample Receipt Date: 6/23/2004
RJ Lee Group Job No.: ATH306366-804
Samples Received: 22
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5223728.HT	Area	6/21/2004 6/22/2004	0	Z	(South) - Decon Exit	385	2112.00	0.04317	0 0	< 23.2 23.2	< 0.004 0.004
5223729.HT	Area	6/21/2004 6/22/2004	0	FF	(South) - Shanty Area	385	2152.00	0.04317	0 0	< 23.2 23.2	< 0.004 0.004
5223730.HT	Area	6/21/2004 6/22/2004	0	Y	(South) - Decon Entrance	385	2021.25	0.04317	0 0	< 23.2 23.2	< 0.004 0.004
5223731.HT	Area	6/21/2004 6/22/2004	0	X	(South) - Ramp	385	2156.00	0.04317	0 0	< 23.2 23.2	< 0.004 0.004
5223732.HT	Field Blank	6/21/2004 6/21/2004	0	X	(South) - Ramp	385	0.000	0.08633	0 0	< 11.6 11.6	N/A N/A
5223733.HT	Field Blank	6/21/2004 6/21/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08633	0 0	< 11.6 11.6	N/A N/A
5223734.HT	Area	6/21/2004 6/22/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2160.00	0.04317	0 0	< 23.2 23.2	< 0.004 0.004
5223735.HT	Area	6/21/2004 6/22/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2032.50	0.04317	0 0	< 23.2 23.2	< 0.004 0.004
5223736.HT	Area	6/21/2004 6/22/2004	99	N/A	(East) - Greenwich	385	2172.00	0.04317	0 0	< 23.2 23.2	< 0.004 0.004
5223737.HT	Area	6/21/2004 6/22/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2176.00	0.04317	0 0	< 23.2 23.2	< 0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 5

Jul 02 04 02:26p

IBM USER

732 6018

p. 11

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-804
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 6/24/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	S/mm ²	S/cc

Authorized Signature: _____



/slb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "--" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 4 of 5