

Jul 02 04 02:31p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 6/25/2004 Time: 9:20:14 AM

Page 2 of 4 P. 17
6/23

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/25/2004
Sample Receipt Date: 6/24/2004
RJ Lee Group Job No.: ATH306366-808
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5223716.HT	Area	6/23/2004 6/23/2004	1	K	(NorthWest) - Cedar Decon	385	1956.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223715.HT	Area	6/23/2004 6/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1956.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223713.HT	Area	6/23/2004 6/23/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1948.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223714.HT	Area	6/23/2004 6/23/2004	99	N/A	(East) - Greenwich	385	1948.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223712.HT	Area	6/23/2004 6/23/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1944.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223710.HT	Field Blank	6/23/2004 6/23/2004	0	X	(South) - Ramp	385	0.000	0.08633	0 0	< 11.6 11.6	N/A N/A
5223711.HT	Field Blank	6/23/2004 6/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08633	0 0	< 11.6 11.6	N/A N/A
5223709.HT	Area	6/23/2004 6/23/2004	0	X	(South) - Ramp	385	1936.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223707.HT	Area	6/23/2004 6/23/2004	0	FF	(South) - Shanty Area	385	1912.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005
5223708.HT	Area	6/23/2004 6/23/2004	0	Y	(South) - Decon Entrance	385	1920.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 02 04 02:31p IBM USER

From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018

Date: 9/28/2004 Time: 9:28:12 AM

Page 3 of 4 P. 18

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-808
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/25/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (8/mm ²)	(S/cc)
5223706.HT	Area	6/23/2004 6/23/2004	0	Z	(South) - Decon Exit	385	1896.00	0.04317	0 0	< 23.2 23.2	< 0.005 0.005

Authorized Signature: _____



/sib

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10644) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 6/25/2004
Sample Receipt Date: 6/25/2004
RJ Lee Group Job No.: ATH306366-809
Samples Received: 22
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity (S/mm ²) (S/cc)
5220665.HT	Area	6/23/2004 6/24/2004	0	Z	(South) - Devon Exit	385	2000.00	0.04336	0 0	< 23.1 23.1 < 0.004 0.004
5220666.HT	Area	6/23/2004 6/24/2004	0	FF	(South) - Shanty Area	385	2004.00	0.04336	0 0	< 23.1 23.1 < 0.004 0.004
5220667.HT	Area	6/23/2004 6/24/2004	0	Y	(South) - Devon Entrance	385	2008.00	0.04336	0 0	< 23.1 23.1 < 0.004 0.004
5220668.HT	Area	6/23/2004 6/24/2004	0	X	(South) - Ramp	385	1886.25	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5220669.HT	Field Blank	6/23/2004 6/23/2004	0	X	(South) - Ramp	385	0.000	0.08672	0 0	< 11.5 11.5 N/A N/A
5220670.HT	Field Blank	6/23/2004 6/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08672	0 0	< 11.5 11.5 N/A N/A
5220671.HT	Area	6/23/2004 6/24/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2020.00	0.04336	0 0	< 23.1 23.1 < 0.004 0.004
5220672.HT	Area	6/23/2004 6/24/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1897.50	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5220673.HT	Area	6/23/2004 6/24/2004	99	N/A	(East) - Greenwich	385	2028.00	0.04336	0 0	< 23.1 23.1 < 0.004 0.004
5220674.HT	Area	6/23/2004 6/24/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2028.00	0.04336	0 0	< 23.1 23.1 < 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 5

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No. ATH306366-809
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 6/25/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity (S/cc)
5220675.HT	Area	6/23/2004 6/24/2004	1	K	(NorthWest) - Cedar Decon	385	2060.00	0.04336	0 0	< 23.1 23.1 < 0.004 0.004
5223685.HT	Area	6/23/2004 6/23/2004	0	Z	(South) - Decon Exit	385	1864.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5223686.HT	Area	6/23/2004 6/23/2004	0	FF	(South) - Shanty Area	385	1844.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5223687.HT	Area	6/23/2004 6/23/2004	0	Y	(South) - Decon Entrance	385	1832.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5223688.HT	Area	6/23/2004 6/23/2004	0	X	(South) - Ramp	385	1812.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5223689.HT	Field Blank	6/23/2004 6/23/2004	0	X	(South) - Ramp	385	0.000	0.08672	0 0	< 11.5 11.5 N/A N/A
5223690.HT	Field Blank	6/23/2004 6/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08672	0 0	< 11.5 11.5 N/A N/A
5223691.HT	Area	6/23/2004 6/23/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1687.50	0.05203	0 0	< 19.2 19.2 < 0.004 0.004
5223692.HT	Area	6/23/2004 6/23/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1683.75	0.05203	0 0	< 19.2 19.2 < 0.004 0.004
5223693.HT	Area	6/23/2004 6/23/2004	99	N/A	(East) - Greenwich	385	1796.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5223694.HT	Area	6/23/2004 6/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1792.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5223695.HT	Area	6/23/2004 6/23/2004	1	K	(NorthWest) - Cedar Decon	385	1680.00	0.05203	0 0	< 19.2 19.2 < 0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5

Jul 02 04 02:34p

IBM USER

732 6018

P. 21

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 01/29/2004 Time: 11:10:00 PM

Page 4 of 5

RJ Lee Group, Inc.

Laboratory Report (cont.)

RJ Lee Group Job No. ATH306366-809
Building 130 Liberty

RJ Lee Group, Inc.
Report Date:

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature:



/s/

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 4 of 5