

Jul 02 04 02:38p

IBM USER

732 6018

p. 27

Final Laboratory Report**TEM Air Analysis**

RJ Lee Group, Inc
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/29/2004
Sample Receipt Date: 6/28/2004
RJ Lee Group Job No: ATH306366-813
Samples Received: 11
Building: 130 Liberty

6/25

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
		Start	Stop								Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5221750.HT	Area	6/25/2004	6/25/2004	0	Z	(South) - Decon Exit	385	1844.00	0.04336	0 0	< 23.1 23.1	< 0.005 0.005
5221751.HT	Area	6/25/2004	6/25/2004	0	FF	(South) - Shanty Area	385	1840.00	0.04336	0 0	< 23.1 23.1	< 0.005 0.005
5221752.HT	Area	6/25/2004	6/25/2004	0	Y	(South) - Decon Entrance	385	1840.00	0.04336	0 0	< 23.1 23.1	< 0.005 0.005
5221753.HT	Area	6/25/2004	6/25/2004	0	X	(South) - Ramp	385	1836.00	0.04336	0 0	< 23.1 23.1	< 0.005 0.005
5221754.HT	Field Blank	6/25/2004	6/25/2004	0	X	(South) - Ramp	385	0.000	0.08672	0 0	< 11.5 11.5	N/A N/A
5221755.HT	Field Blank	6/25/2004	6/25/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08672	0 0	< 11.5 11.5	N/A N/A
5221756.HT	Area	6/25/2004	6/25/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1836.00	0.04336	0 0	< 23.1 23.1	< 0.005 0.005
5221757.HT	Area	6/25/2004	6/25/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1840.00	0.04336	0 0	< 23.1 23.1	< 0.005 0.005
5221758.HT	Area	6/25/2004	6/25/2004	99	N/A	(East) - Greenwich	385	1840.00	0.04336	0 0	< 23.1 23.1	< 0.005 0.005
5221759.HT	Area	6/25/2004	6/25/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1980.50	0.04336	0 0	< 23.1 23.1	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 02 04 02:39p

IBM USER

732 6018

Page 3 of 4 P. 28


From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/28/2004 Time: 8:50:32 AM

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No. ATH306366-813
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/29/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5221760.HT	Area	6/25/2004	6/25/2004	1	K	(NorthWest) - Cedar Decon	385	1876.00	0.04336	0	0	< 23.1 23.1	< 0.005 0.005

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

Jul 02 04 02:40p

IBM USER

732 6018

p. 29

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/29/2004
Sample Receipt Date: 6/28/2004
RJ Lee Group Job No.: ATH306366-811
Samples Received: 20
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5220694.HT	Area	6/25/2004 6/25/2004	0	Z	(South) - Decon Exit	385	1984.00	0.04336	0 0	< 23.1 23.1	< 0.004 0.004
5220697.HT	Area	6/25/2004 6/25/2004	0	X	(South) - Ramp	385	1984.00	0.04336	0 0	< 23.1 23.1	< 0.004 0.004
5220696.HT	Area	6/25/2004 6/25/2004	0	Y	(South) - Decon Entrance	385	1984.00	0.04336	0 0	< 23.1 23.1	< 0.004 0.004
5220695.HT	Area	6/25/2004 6/25/2004	0	FF	(South) - Shanty Area	385	1860.00	0.04336	0 0	< 23.1 23.1	< 0.005 0.005
5220698.HT	Field Blank	6/25/2004 6/25/2004	0	X	(South) - Ramp	385	0.000	0.08672	0 0	< 11.5 11.5	N/A N/A
5220699.HT	Field Blank	6/25/2004 6/25/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08672	0 0	< 11.5 11.5	N/A N/A
5220700.HT	Area	6/25/2004 6/25/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1976.00	0.04336	0 0	< 23.1 23.1	< 0.004 0.004
5220703.HT	Area	6/25/2004 6/25/2004	1	K	(NorthWest) - Cedar Decon	385	1920.00	0.04336	0 0	< 23.1 23.1	< 0.005 0.005
5220701.HT	Area	6/25/2004 6/25/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1841.25	0.04336	0 0	< 23.1 23.1	< 0.005 0.005
5220704.HT	Area	6/25/2004 6/25/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1936.00	0.04336	0 0	< 23.1 23.1	< 0.005 0.005

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101203-0, NY ELAP #10644) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 02 04 02:41p

IBM USER

732 6018

p.30

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-811
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 6/29/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity (S/m ²) (S/cc)
5220715 HT	Area	6/25/2004 6/26/2004	0	Z	(South) - Decon Exit	385	1932.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5220717 HT	Area	6/25/2004 6/26/2004	0	Y	(South) - Decon Entrance	385	1936.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5220716 HT	Area	6/25/2004 6/26/2004	0	FF	(South) - Shanty Area	385	1936.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5220718 HT	Area	6/25/2004 6/26/2004	0	X	(South) - Ramp	385	1818.75	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5220719 HT	Field Blank	6/25/2004 6/26/2004	0	X	(South) - Ramp	385	0.000	0.08672	0 0	< 11.5 11.5 N/A N/A
5220720 HT	Field Blank	6/25/2004 6/26/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08672	0 0	< 11.5 11.5 N/A N/A
5220721 HT	Area	6/25/2004 6/26/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1948.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5220722 HT	Area	6/25/2004 6/26/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1833.75	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5220724 HT	Area	6/25/2004 6/26/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1960.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005
5220725 HT	Area	6/25/2004 6/26/2004	1	K	(NorthWest) - Cedar Decon	385	1964.00	0.04336	0 0	< 23.1 23.1 < 0.005 0.005

Authorized Signature:



/sib

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4