

Jul 13 04 02:18p

IBM USER

732 6018

Page 2 of 3 P. 8

7/8

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report**TEM Air Analysis**

RJ Lee Group, Inc
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/10/2004
Sample Receipt Date: 7/9/2004
RJ Lee Group Job No: ATH306366-860
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5225715.HT	Field Blank	7/8/2004 7/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08773	0 0	< 11.4 11.4	N/A N/A
5225717.HT	Area	7/8/2004 7/8/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1717.50	0.05264	0 0	< 19.0 19.0	< 0.004 0.004
5225718.HT	Area	7/8/2004 7/8/2004	99	N/A	(East) - Greenwich	385	1832.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225719.HT	Area	7/8/2004 7/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1840.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225716.HT	Area	7/8/2004 7/8/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1832.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005

Authorized Signature: _____ /s/b

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

Jul 13 04 02:19p

IBM USER

732 6018

P. 9

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/10/2004
Sample Receipt Date: 7/10/2004
RJ Lee Group Job No.: ATH306366-864
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5225174.HT	Field Blank	7/8/2004 7/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08773	0 0	< 11.4 11.4	N/A N/A
5225175.HT	Area	7/8/2004 7/8/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2040.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5225176.HT	Area	7/8/2004 7/8/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2040.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5225177.HT	Area	7/8/2004 7/8/2004	99	N/A	(East) - Greenwich	385	2040.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5225178.HT	Area	7/8/2004 7/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2040.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5225748.HT	Field Blank	7/8/2004 7/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08773	0 0	< 11.4 11.4	N/A N/A
5225752.HT	Area	7/8/2004 7/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1960.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5225749.HT	Area	7/8/2004 7/9/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1940.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005

Authorized Signature: _____ /s/b

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3