

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 7/13/2004 Time: 10:55:42 AM

Page 2 of 3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/13/2004
Sample Receipt Date: 7/12/2004
RJ Lee Group Job No.: ATH306366-869
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mmf ²)	(S/cc)
5225638.HT	Area	7/10/2004 7/10/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1896.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225639.HT	Area	7/10/2004 7/10/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1900.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225637.HT	Field Blank	7/10/2004 7/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08773	0 0	< 11.4 11.4	N/A N/A
5225640.HT	Area	7/10/2004 7/10/2004	99	N/A	(East) - Greenwich	385	1916.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225641.HT	Area	7/10/2004 7/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1904.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005

Authorized Signature: _____

Kimberly A. Allison, Manager - TEM Analysis

/s/lb

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/14/2004
Sample Receipt Date: 7/13/2004
RJ Lee Group Job No: ATH306366-877
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5225374.HT	Field Blank	7/10/2004 7/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08788	0 0	< 11.4 11.4	N/A N/A
5225376.HT	Area	7/10/2004 7/10/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2052.75	0.04394	0 0	< 22.8 22.8	< 0.004 0.004
5225375.HT	Area	7/10/2004 7/10/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1811.25	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5225377.HT	Area	7/10/2004 7/10/2004	99	N/A	(East) - Greenwich	385	1928.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5225378.HT	Area	7/10/2004 7/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1928.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5225395.HT	Field Blank	7/10/2004 7/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08788	0 0	< 11.4 11.4	N/A N/A
5225396.HT	Area	7/10/2004 7/11/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2040.00	0.04394	0 0	< 22.8 22.8	< 0.004 0.004
5225397.HT	Area	7/10/2004 7/11/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1920.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5225398.HT	Area	7/10/2004 7/11/2004	99	N/A	(East) - Greenwich	385	1912.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5225399.HT	Area	7/10/2004 7/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1904.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005

Notes:

1. Volumes provided by Ambiera were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-877
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 7/14/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start Stop								Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NYLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4