

Aug 03 04 03:15p

IBM USER

732 6018

p. 5

**RJ LeeGroup, Inc.**

350 Hochberg Road, Monroeville, PA 15146  
 Phone: (724) 325-1776 Fax: (724) 733-1799

## Final Laboratory Report

### TEM Air Analysis

RJ Lee Group, Inc.  
 350 Hochberg Road  
 Monroeville, PA 15146  
 USA

Report Date: 7/29/2004  
 Sample Receipt Date: 7/28/2004  
 RJ Lee Group Job No: ATH306366-931  
 Samples Received: 5  
 Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

| RJLG Sample Number | Sample Type | Date Collected |           | Floor | Grid         | Sub Location                        | Filter Area (mm <sup>2</sup> ) | Volume (liter) | Area Analyzed (mm <sup>2</sup> ) | Asbestos Structures |      | Concentration                               |                  |
|--------------------|-------------|----------------|-----------|-------|--------------|-------------------------------------|--------------------------------|----------------|----------------------------------|---------------------|------|---------------------------------------------|------------------|
|                    |             | Start          | Stop      |       |              |                                     |                                |                |                                  | Chry                | Amph | Analytical Sensitivity (S/mm <sup>2</sup> ) | (S/cc)           |
| 5227555.HT         | Area        | 7/27/2004      | 7/27/2004 | 99    | Not Acquired | (SouthWest) - Washington and Albany | 385                            | 1924.00        | 0.04394                          | 0                   | 0    | < 22.8<br>22.8                              | < 0.005<br>0.005 |
| 5227556.HT         | Area        | 7/27/2004      | 7/27/2004 | 99    | Not Acquired | (SouthEast) - Greenwich and Albany  | 385                            | 1932.00        | 0.04394                          | 0                   | 0    | < 22.8<br>22.8                              | < 0.005<br>0.005 |
| 5227557.HT         | Area        | 7/27/2004      | 7/27/2004 | 99    | N/A          | (East) - Greenwich                  | 385                            | 1944.00        | 0.04394                          | 0                   | 0    | < 22.8<br>22.8                              | < 0.005<br>0.005 |
| 5227558.HT         | Area        | 7/27/2004      | 7/27/2004 | 99    | Not Acquired | (NorthWest) - Washington and Cedar  | 385                            | 1948.00        | 0.04394                          | 0                   | 0    | < 22.8<br>22.8                              | < 0.004<br>0.004 |
| 5227868.HT         | Field Blank | 7/27/2004      | 7/27/2004 | 99    | Not Acquired | (NorthWest) - Washington and Cedar  | 385                            | 0.000          | 0.08789                          | 0                   | 0    | < 11.4<br>11.4                              | N/A<br>N/A       |

Authorized Signature: \_\_\_\_\_

Kimberly A. Allison, Manager - TEM Analysis

#### Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

**RJ LeeGroup, Inc.**

350 Hochberg Road, Monroeville, PA 15146  
Phone: (724) 325-1776 Fax: (724) 733-1799

## Final Laboratory Report

### TEM Air Analysis

RJ Lee Group, Inc.  
350 Hochberg Road  
Monroeville, PA 15146  
USA

Report Date: 7/30/2004  
Sample Receipt Date: 7/29/2004  
RJ Lee Group Job No.: ATH306366-954  
Samples Received: 10  
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

| RJLG Sample Number | Sample Type | Date Collected<br>Start<br>Stop | Floor | Grid         | Sub Location                                                                        | Filter Area (mm <sup>2</sup> ) | Volume (liter) | Area Analyzed (mm <sup>2</sup> ) | Asbestos Structures<br>Chry Amph | Concentration                               |                  |
|--------------------|-------------|---------------------------------|-------|--------------|-------------------------------------------------------------------------------------|--------------------------------|----------------|----------------------------------|----------------------------------|---------------------------------------------|------------------|
|                    |             |                                 |       |              |                                                                                     |                                |                |                                  |                                  | Analytical Sensitivity (S/mm <sup>2</sup> ) | (S/cc)           |
| 5226550.HT         | Field Blank | 7/27/2004<br>7/27/2004          | 99    | Not Acquired | (NorthWest) - Washington and Cedar                                                  | 385                            | 0.000          | 0.08792                          | 0 0                              | < 11.4<br>11.4                              | N/A<br>N/A       |
| 5226551.HT         | Area        | 7/27/2004<br>7/28/2004          | 99    | Not Acquired | (SouthWest) - Washington and Albany                                                 | 385                            | 2088.00        | 0.04396                          | 0 0                              | < 22.7<br>22.7                              | < 0.004<br>0.004 |
| 5226552.HT         | Area        | 7/27/2004<br>7/28/2004          | 99    | Not Acquired | (SouthEast) - Greenwich and Albany                                                  | 385                            | 2096.00        | 0.04396                          | 0 0                              | < 22.7<br>22.7                              | < 0.004<br>0.004 |
| 5226553.HT         | Area        | 7/27/2004<br>7/28/2004          | 99    | N/A          | (East) - Greenwich                                                                  | 385                            | 2104.00        | 0.04396                          | 0 0                              | < 22.7<br>22.7                              | < 0.004<br>0.004 |
| 5226554.HT         | Area        | 7/27/2004<br>7/28/2004          | 99    | Not Acquired | (NorthWest) - Washington and Cedar                                                  | 385                            | 2116.00        | 0.04396                          | 0 0                              | < 22.7<br>22.7                              | < 0.004<br>0.004 |
| 5226694.HT         | Field Blank | 7/27/2004<br>7/27/2004          | 99    | Not Acquired | (NorthWest) - Washington and Cedar                                                  | 385                            | 0.000          | 0.08792                          | 0 0                              | < 11.4<br>11.4                              | N/A<br>N/A       |
| 5226695.HT         | Area        | 7/27/2004<br>7/27/2004          | 99    | Not Acquired | (SouthWest) - Washington and Albany. It was raining as I was setting up the sample. | 385                            | 1732.00        | 0.05275                          | 0 0                              | < 19.0<br>19.0                              | < 0.004<br>0.004 |
| 5226696.HT         | Area        | 7/27/2004<br>7/27/2004          | 99    | Not Acquired | (SouthEast) - Greenwich and Albany                                                  | 385                            | 1724.00        | 0.05275                          | 0 0                              | < 19.0<br>19.0                              | < 0.004<br>0.004 |
| 5226697.HT         | Area        | 7/27/2004<br>7/27/2004          | 99    | N/A          | (East) - Greenwich. It was raining as the sample was being set up.                  | 385                            | 1712.00        | 0.05275                          | 0 0                              | < 19.0<br>19.0                              | < 0.004<br>0.004 |
| 5226698.HT         | Area        | 7/27/2004<br>7/27/2004          | 99    | Not Acquired | (NorthWest) - Washington and Cedar. It was raining as the sample was being set up.  | 385                            | 1700.00        | 0.05275                          | 0 0                              | < 19.0<br>19.0                              | < 0.004<br>0.004 |

#### Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 1 of 3

Aug 03 04 03:16p

IBM USER

732 6018

p. 7

# **RJ Lee Group, Inc.**


## **Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-934  
Building: 130 Liberty

RJ Lee Group, Inc.  
Report Date: 7/30/2004

| RJLG Sample<br>Number | Sample<br>Type | Date<br>Collected |      | Floor | Grid | Sub Location | Filter<br>Area<br>(mm <sup>2</sup> ) | Volume<br>(liter) | Area<br>Analyzed<br>(mm <sup>2</sup> ) | Asbestos<br>Structures |      | Concentration                                     |        |
|-----------------------|----------------|-------------------|------|-------|------|--------------|--------------------------------------|-------------------|----------------------------------------|------------------------|------|---------------------------------------------------|--------|
|                       |                | Start             | Stop |       |      |              |                                      |                   |                                        | Chry                   | Amph | Analytical<br>Sensitivity<br>(S/mm <sup>2</sup> ) | (S/cc) |

Authorized Signature: \_\_\_\_\_



/sib

Kimberly A. Allison, Manager - TEM Analysis

### Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

Aug 05 04 12:41p

IBM USER

732 6018

p. 2

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 7/29/2004 Time: 0:00:00

**RJ LeeGroup, Inc.**350 Hochberg Road, Monroeville, PA 15146  
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**  
TEM Air AnalysisRJ Lee Group, Inc.  
350 Hochberg Road  
Monroeville, PA 15146  
USAReport Date: 7/29/2004  
Sample Receipt Date: 7/28/2004  
RJ Lee Group Job No.: ATH306366-931  
Samples Received: 5  
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

| RJLG Sample Number | Sample Type | Date Collected<br>Start<br>Stop | Floor | Grid         | Sub Location                        | Filter Area (mm <sup>2</sup> ) | Volume (liter) | Area Analyzed (mm <sup>2</sup> ) | Asbestos Structures |      | Concentration                               |                               |
|--------------------|-------------|---------------------------------|-------|--------------|-------------------------------------|--------------------------------|----------------|----------------------------------|---------------------|------|---------------------------------------------|-------------------------------|
|                    |             |                                 |       |              |                                     |                                |                |                                  | Chry                | Amph | Analytical Sensitivity (S/mm <sup>2</sup> ) | Analytical Sensitivity (S/cc) |
| 5227555.HT         | Area        | 7/27/2004<br>7/27/2004          | 99    | Not Acquired | (SouthWest) - Washington and Albany | 385                            | 1924.00        | 0.04394                          | 0                   | 0    | < 22.8<br>22.8                              | < 0.005<br>0.005              |
| 5227556.HT         | Area        | 7/27/2004<br>7/27/2004          | 99    | Not Acquired | (SouthEast) - Greenwich and Albany  | 385                            | 1932.00        | 0.04394                          | 0                   | 0    | < 22.8<br>22.8                              | < 0.005<br>0.005              |
| 5227557.HT         | Area        | 7/27/2004<br>7/27/2004          | 99    | N/A          | (East) - Greenwich                  | 385                            | 1944.00        | 0.04394                          | 0                   | 0    | < 22.8<br>22.8                              | < 0.005<br>0.005              |
| 5227558.HT         | Area        | 7/27/2004<br>7/27/2004          | 99    | Not Acquired | (NorthWest) - Washington and Cedar  | 385                            | 1948.00        | 0.04394                          | 0                   | 0    | < 22.8<br>22.8                              | < 0.004<br>0.004              |
| 5227868.HT         | Field Blank | 7/27/2004<br>7/27/2004          | 99    | Not Acquired | (NorthWest) - Washington and Cedar  | 385                            | 0.000          | 0.08789                          | 0                   | 0    | < 11.4<br>11.4                              | N/A<br>N/A                    |

Authorized Signature:



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

**Notes:**

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3