

Jul 27 04 11:55a

IBM USER

732 6018

p.2

7/20

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
 Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
 350 Hochberg Road
 Monroeville, PA 15146
 USA

Report Date: 7/22/2004
 Sample Receipt Date: 7/21/2004
 RJ Lee Group Job No.: ATH306366-905
 Samples Received: 5
 Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
									Chry	Amph	Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5227961.HT	Field Blank	7/20/2004 7/20/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08772	0	0	< 11.4 11.4	N/A N/A
5227962.HT	Area	7/20/2004 7/20/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1980.00	0.04386	0	0	< 22.8 22.8	< 0.004 0.004
5227963.HT	Area	7/20/2004 7/20/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2012.00	0.04386	0	0	< 22.8 22.8	< 0.004 0.004
5227964.HT	Area	7/20/2004 7/20/2004	99	N/A	(East) - Greenwich	385	2028.00	0.04386	0	0	< 22.8 22.8	< 0.004 0.004
5227965.HT	Area	7/20/2004 7/20/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2032.00	0.04386	0	0	< 22.8 22.8	< 0.004 0.004

Authorized Signature: _____

Kimberly A. Allison, Manager - TEM Analysis

/s/lb

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/23/2004
Sample Receipt Date: 7/22/2004
RJ Lee Group Job No.: ATH306366-908
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5225907.HT	Field Blank	7/20/2004 7/20/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08772	0 0	< 11.4 11.4	N/A N/A
5225908.HT	Area	7/20/2004 7/20/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1827.50	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225909.HT	Area	7/20/2004 7/20/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1802.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225910.HT	Area	7/20/2004 7/20/2004	99	N/A	(East) - Greenwich	385	1676.00	0.05263	0 0	< 19.0 19.0	< 0.004 0.004
5226474.HT	Field Blank	7/20/2004 7/20/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08772	0 0	< 11.4 11.4	N/A N/A
5225911.HT	Area	7/20/2004 7/20/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1772.25	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5226475.HT	Area	7/20/2004 7/21/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2064.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5226476.HT	Area	7/20/2004 7/21/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2064.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5226477.HT	Area	7/20/2004 7/21/2004	99	N/A	(East) - Greenwich	385	2060.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5226478.HT	Area	7/20/2004 7/21/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2064.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 27 04 11:55a IBM USER
FROM: RJ Lee Group, Inc. TO: Mr. Noel Drago732 6018
DATE: 7/23/2004 TIME: 10:48:00 AM

Page 3 of 4 P. 4

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-908
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 7/23/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start Stop								Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4