

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/24/2004
Sample Receipt Date: 7/23/2004
RJ Lee Group Job No.: ATH306366-914
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5227786.HT	Area	7/22/2004 7/22/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1788.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5227787.HT	Area	7/22/2004 7/22/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1788.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5227788.HT	Area	7/22/2004 7/22/2004	99	N/A	(East) - Greenwich	385	1800.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5227789.HT	Area	7/22/2004 7/22/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1804.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5227785.HT	Field Blank	7/22/2004 7/22/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08772	0 0	< 11.4 11.4	N/A N/A

Authorized Signature: _____ /s/b

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/25/2004
Sample Receipt Date: 7/24/2004
RJ Lee Group Job No.: ATH306366-917
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5227796.HT	Field Blank	7/22/2004 7/22/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08772	0 0	< 11.4 11.4	N/A N/A
5227797.HT	Area	7/22/2004 7/22/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1833.75	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5227798.HT	Area	7/22/2004 7/22/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1948.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5227799.HT	Area	7/22/2004 7/22/2004	99	N/A	(East) - Greenwich	385	1936.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5227800.HT	Area	7/22/2004 7/22/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1936.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5227826.HT	Field Blank	7/22/2004 7/22/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08772	0 0	< 11.4 11.4	N/A N/A
5227827.HT	Area	7/22/2004 7/23/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2024.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5227828.HT	Area	7/22/2004 7/23/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2024.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5227830.HT	Area	7/22/2004 7/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1893.75	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5227829.HT	Area	7/22/2004 7/23/2004	99	N/A	(East) - Greenwich	385	2024.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-917
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 7/25/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____ /slb

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

JUL 27 04 11:57a IBM USER
 From: RJ Lee Group, Inc. To: Mr. Noel Urigo

732 6018
 Date: 7/25/2004 Time: 4:11:40 PM

Page 2 of 3 P. 11

7/22

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
 Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
 350 Hochberg Road
 Monroeville, PA 15146
 USA

Report Date: 7/25/2004
 Sample Receipt Date: 7/24/2004
 RJ Lee Group Job No.: ATH306366-918
 Samples Received: 0
 Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start							Stop	Chry	Amph	Analytical Sensitivity (S/mm ²)
5225967.HT	Field Blank	7/23/2004 7/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08772	0	0	< 11.4 11.4	N/A N/A
5225968.HT	Area	7/23/2004 7/23/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1724.00	0.05263	0	0	< 19.0 19.0	< 0.004 0.004
5227832.HT	Area	7/23/2004 7/23/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1732.00	0.05263	0	0	< 19.0 19.0	< 0.004 0.004
5227833.HT	Area	7/23/2004 7/23/2004	99	N/A	(East) - Greenwich	385	1744.00	0.05263	0	0	< 19.0 19.0	< 0.004 0.004
5227834.HT	Area	7/23/2004 7/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1748.00	0.05263	0	0	< 19.0 19.0	< 0.004 0.004

Authorized Signature: _____ /slb

Notes:

1. Volumes provided by Ambicx were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

JUL 27 04 11:57a IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 7/27/2004 Time: 8:55:58 AM 732 6018

Page 2 of 4 P. 12

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/27/2004
Sample Receipt Date: 7/26/2004
RJ Lee Group Job No.: ATH306366-923
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5226506.HT	Field Blank	7/23/2004 7/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar. Hydrometer malfunction.	385	0.000	0.08789	0 0	< 11.4 11.4	N/A N/A
5226508.HT	Area	7/23/2004 7/24/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany. Hydrometer malfunction.	385	1864.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5226507.HT	Area	7/23/2004 7/24/2004	99	Not Acquired	(SouthWest) - Washington and Albany. Hydrometer malfunction.	385	1880.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5226510.HT	Area	7/23/2004 7/24/2004	99	Not Acquired	(NorthWest) - Washington and Cedar. Hydrometer malfunction.	385	1856.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5227841.HT	Field Blank	7/23/2004 7/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08789	0 0	< 11.4 11.4	N/A N/A
5226509.HT	Area	7/23/2004 7/24/2004	99	N/A	(East) - Greenwich. Hydrometer malfunction.	385	1860.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5227842.HT	Area	7/23/2004 7/23/2004	99	Not Acquired	(SouthWest) - Washington and Albany. Its raining, sample affected by	385	2100.00	0.04394	0 0	< 22.8 22.8	< 0.004 0.004
5227843.HT	Area	7/23/2004 7/23/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany. Raining as at time of sample takedown.	385	2235.50	0.03515	0 0	< 28.4 28.4	< 0.005 0.005
5227845.HT	Area	7/23/2004 7/23/2004	99	Not Acquired	(NorthWest) - Washington and Cedar. Raining at sample takedown, sample affected by	385	2092.00	0.04394	0 0	< 22.8 22.8	< 0.004 0.004
5227844.HT	Area	7/23/2004 7/23/2004	99	N/A	(East) - Greenwich. Raining as at time of sample takedown	385	2096.00	0.04394	0 0	< 22.8 22.8	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 27 04 11:58a IBM USER
 From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
 Date: 7/27/2004 Time: 0:00:00 AM

Page 3 of 4 P. 13

RJ Lee Group, Inc.

Laboratory Report (cont.)

RJ Lee Group Job No: ATH306366-923
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 7/27/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4