

Jul 28 04 12:15p

IBM USER

732 6018

p. 4

7/25


RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-925
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 7/28/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
									Chry	Amph	(S/mmf)	(S/cc)
5227517.HT	Field Blank	7/25/2004 7/25/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08789	0	0	< 11.4 11.4	N/A N/A
5227518.HT	Area	7/25/2004 7/26/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1920.00	0.04394	0	0	< 22.8 22.8	< 0.005 0.005
5227519.HT	Area	7/25/2004 7/26/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1924.00	0.04394	0	0	< 22.8 22.8	< 0.005 0.005
5227521.HT	Area	7/25/2004 7/26/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1920.00	0.04394	0	0	< 22.8 22.8	< 0.005 0.005
5227520.HT	Area	7/25/2004 7/26/2004	99	N/A	(East) - Greenwich	385	1928.00	0.04394	0	0	< 22.8 22.8	< 0.005 0.005

Authorized Signature:



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/28/2004
Sample Receipt Date: 7/27/2004
RJ Lee Group Job No.: ATH306366-925
Samples Received: 15
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5226539.HT	Field Blank	7/25/2004 7/25/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08789	0 0	< 11.4 11.4	N/A N/A
5226541.HT	Area	7/25/2004 7/25/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1716.00	0.05273	0 0	< 19.0 19.0	< 0.004 0.004
5226542.HT	Area	7/25/2004 7/25/2004	99	N/A	(East) - Greenwich	385	1732.00	0.05273	0 0	< 19.0 19.0	< 0.004 0.004
5226543.HT	Area	7/25/2004 7/25/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1740.00	0.05273	0 0	< 19.0 19.0	< 0.004 0.004
5227497.HT	Area	7/25/2004 7/25/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2112.00	0.04394	0 0	< 22.8 22.8	< 0.004 0.004
5227496.HT	Field Blank	7/25/2004 7/25/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08789	0 0	< 11.4 11.4	N/A N/A
5226540.HT	Area	7/25/2004 7/25/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1704.00	0.05273	0 0	< 19.0 19.0	< 0.004 0.004
5227498.HT	Area	7/25/2004 7/25/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2104.00	0.04394	0 0	< 22.8 22.8	< 0.004 0.004
5227499.HT	Area	7/25/2004 7/25/2004	99	N/A	(East) - Greenwich	385	2088.00	0.04394	0 0	< 22.8 22.8	< 0.004 0.004
5227500.HT	Area	7/25/2004 7/25/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2088.00	0.04394	0 0	< 22.8 22.8	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 28 04 12:15p

IBM USER

732 6018

p. 6

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-928
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 7/28/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start Stop								Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "--" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4