

Jun 08 04 10:19a

IBM USER

From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018

Date: 6/2/2004 Time: 9:53:26 AM

P. 2

Page 2 of 4

5/24

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USReport Date: 6/2/2004
Sample Receipt Date: 6/1/2004
RJ Lee Group Job No.: ATH306306-756
Samples Received: 11
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (nm ²)	Volume (liter)	Area Analyzed (nm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
219084 HT	Area	5/29/2004 5/29/2004	0	Z	(South) - Decon Exit	335	1916.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
219085 HT	Area	5/29/2004 5/29/2004	0	FF	(South) - Shanty Area	335	1920.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
219086 HT	Area	5/29/2004 5/29/2004	0	Y	(South) - Decon Entrance	335	1920.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
219087 HT	Area	5/29/2004 5/29/2004	0	X	(South) - Ramp	335	1924.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
219089 HT	Field Blank	5/29/2004 5/29/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
219088 HT	Field Blank	5/29/2004 5/29/2004	0	X	(South) - Ramp	335	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
219090 HT	Area	5/29/2004 5/29/2004	99	Not Acquired	(SouthWest) - Washington and Albany	335	1912.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
219092 HT	Area	5/29/2004 5/29/2004	99	N/A	(East) - Greenwich	335	1944.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
219091 HT	Area	5/29/2004 5/29/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	335	1924.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
219093 HT	Area	5/29/2004 5/29/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	335	1960.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.

2. "—" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.

3. Samples for this project were analyzed at our Monroeville, PA (NVLAP #101205-0, NY ELAP #10844) facility.

4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.

5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.

6. Samples will be held for 90 days and then disposed of per Federal regulations.

7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Jun 08 04 10:20a IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 6/2/2004 Time: 9:53:26 AM

P. 3
Page 3 of 4

RJ Lee Group, Inc.

Laboratory Report (cont.)

RJ Lee Group Job No: ATP306366-755
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 6/2/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
		Start	Stop							Chry	Amph	(S/mm ²)	(S/cc)
3219094.HIT	Area	5/29/2004	5/29/2004	1	K	(NorthWest) - Cedar Decon	335	1992.00	0.04354	0	0	<23.0	<0.004
												23.0	0.004

Authorized Signature: _____



/s/

Kimberly A. Allison, Manager - TEM Analysis

Notes

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101263-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

Jun 08 04 10:20a IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 6/11/2004 Time: 9:11:20 PM

Page 2 of 4 P. 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/3/2004
Sample Receipt Date: 6/2/2004
RJ Lee Group Job No.: ATH306366-756
Samples Received: 20
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mm ³)	(S/cc)
5219095.HT	Area	5/29/2004 5/29/2004	0	Z	(South) - Decon Exit	385	2095.25	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5219096.HT	Area	5/29/2004 5/29/2004	0	FF	(South) - Shanty Area	385	1968.00	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5219097.HT	Area	5/29/2004 5/29/2004	0	Y	(South) - Decon Entrance	385	2091.00	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5219098.HT	Area	5/29/2004 5/29/2004	0	X	(South) - Ramp	385	1848.75	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5219099.HT	Field Blank	5/29/2004 5/29/2004	0	X	(South) - Ramp	385	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
5219100.HT	Field Blank	5/29/2004 5/29/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
5219101.HT	Area	5/29/2004 5/29/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1980.00	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5219102.HT	Area	5/29/2004 5/29/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1968.00	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5219103.HT	Area	5/29/2004 5/29/2004	99	N/A	(East) - Greenwich	385	1952.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5221031.HT	Area	5/29/2004 5/30/2004	0	Z	(South) - Decon Exit	385	1872.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005

Notes:

1. Volumes provided by Ambienta were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jun 08 04 10:20a

IBM USER


732 6018

p.5

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-756
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/3/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
		Start	Stop							Chry	Amph	(S/mm ²)	(S/cc)
5221032.HT	Area	5/29/2004	5/30/2004	0	FF	(South) - Shanty Area	385	1876.00	0.04354	0	0	< 23.0 23.0	< 0.005 0.005
5221034.HT	Area	5/29/2004	5/30/2004	0	X	(South) - Ramp	385	1868.00	0.04354	0	0	< 23.0 23.0	< 0.005 0.005
5221035.HT	Field Blank	5/29/2004	5/29/2004	0	X	(South) - Ramp	385	0.000	0.08707	0	0	< 11.5 11.5	N/A N/A
5221037.HT	Area	5/29/2004	5/30/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1860.00	0.04354	0	0	< 23.0 23.0	< 0.005 0.005
5221033.HT	Area	5/29/2004	5/30/2004	0	Y	(South) - Decon Entrance	385	1872.00	0.04354	0	0	< 23.0 23.0	< 0.005 0.005
5221038.HT	Area	5/29/2004	5/30/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1864.00	0.04354	0	0	< 23.0 23.0	< 0.005 0.005
5221036.HT	Field Blank	5/29/2004	5/29/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08707	0	0	< 11.5 11.5	N/A N/A
5221040.HT	Area	5/29/2004	5/30/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1860.00	0.04354	0	0	< 23.0 23.0	< 0.005 0.005
5221039.HT	Area	5/29/2004	5/30/2004	99	N/A	(East) - Greenwich	385	1864.00	0.04354	0	0	< 23.0 23.0	< 0.005 0.005
5221041.HT	Area	5/29/2004	5/30/2004	1	K	(NorthWest) - Cedar Decon	385	1972.00	0.04354	0	0	< 23.0 23.0	< 0.004 0.004

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4