

Jun 08 04 10:23a IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 6/3/2004 Time: 8:32:34 AM

Page 2 of 4 P. 8
5/30

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/3/2004
Sample Receipt Date: 6/2/2004
RJ Lee Group Job No.: ATH306366-760
Samples Received: 11
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5221009.HT	Area	5/30/2004 5/30/2004	0	Z	(South) - Decon Exit	385	2223.00	0.03483	0 0	< 28.7 28.7	< 0.005 0.005
5221010.HT	Area	5/30/2004 5/30/2004	0	FF	(South) - Shanty Area	385	1984.00	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5221012.HT	Area	5/30/2004 5/30/2004	0	X	(South) - Ramp	385	2000.00	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5221011.HT	Area	5/30/2004 5/30/2004	0	Y	(South) - Decon Entrance	385	2120.75	0.04354	1 0	23.0 23.0	0.004 0.004
5221013.HT	Field Blank	5/30/2004 5/30/2004	0	X	(South) - Ramp	385	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
5221014.HT	Field Blank	5/30/2004 5/30/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
5221015.HT	Area	5/30/2004 5/30/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2000.00	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5221016.HT	Area	5/30/2004 5/30/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2012.00	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5221017.HT	Area	5/30/2004 5/30/2004	99	N/A	(East) - Greenwich	385	2020.00	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5221019.HT	Area	5/30/2004 5/30/2004	1	K	(NorthWest) - Cedar Decon	385	2052.00	0.04354	1 0	23.0 23.0	0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10644) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jun 08 04 10:23a IBM USER
 From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
 Date: 6/3/2004 Time: 8:32:39 AM

Page 3 of 4 P. 9

RJ Lee Group, Inc.

Laboratory Report (cont.)

RJ Lee Group Job No. ATH306366-760
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 6/3/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liters)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5221018.HT	Area	5/30/2004 5/30/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2052.00	0.04354	0 0	< 23.0 23.0	< 0.004 0.004

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

Jun 08 04 10:24a

IBM USER

732 6018

P. 10

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-757
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 6/3/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity (S/mm ²) (S/cc)
5220968.HT	Area	5/30/2004 5/30/2004	0	Y	(South) - Decon Entrance	385	1888.00	0.04354	0 0	< 23.0 23.0 < 0.005 0.005
5220969.HT	Area	5/30/2004 5/30/2004	0	X	(South) - Ramp	385	1848.00	0.04354	0 0	< 23.0 23.0 < 0.005 0.005
5220967.HT	Area	5/30/2004 5/30/2004	0	FF	(South) - Shanty Area	385	1740.00	0.05224	0 0	< 19.1 19.1 < 0.004 0.004
5220970.HT	Field Blank	5/30/2004 5/30/2004	0	X	(South) - Ramp	385	0.000	0.08707	0 0	< 11.5 11.5 N/A N/A
5220972.HT	Area	5/30/2004 5/30/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1848.00	0.04354	0 0	< 23.0 23.0 < 0.005 0.005
5220971.HT	Field Blank	5/30/2004 5/30/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08707	0 0	< 11.5 11.5 N/A N/A
5220974.HT	Area	5/30/2004 5/30/2004	99	N/A	(East) - Greenwich	385	1828.00	0.04354	0 0	< 23.0 23.0 < 0.005 0.005
5220973.HT	Area	5/30/2004 5/30/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1844.00	0.04354	0 0	< 23.0 23.0 < 0.005 0.005
5220975.HT	Area	5/30/2004 5/30/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1812.00	0.04354	0 0	< 23.0 23.0 < 0.005 0.005
5220976.HT	Area	5/30/2004 5/30/2004	1	K	(NorthWest) - Cedar Decon	385	1808.00	0.04354	0 0	< 23.0 23.0 < 0.005 0.005

Authorized Signature:



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/3/2004
Sample Receipt Date: 6/2/2004
RJ Lee Group Job No.: ATH306366-757
Samples Received: 20
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mmf) (S/cc)	
5215628.HT	Area	5/30/2004 5/31/2004	0	Z	(South) - Decon Exit	385	1960.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215629.HT	Area	5/30/2004 5/31/2004	0	FF	(South) - Shanty Area	385	2086.75	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5215631.HT	Area	5/30/2004 5/31/2004	0	X	(South) - Ramp	385	1952.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215630.HT	Area	5/30/2004 5/31/2004	0	Y	(South) - Decon Entrance	385	1960.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215632.HT	Field Blank	5/30/2004 5/30/2004	0	X	(South) - Ramp	385	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
5215633.HT	Field Blank	5/30/2004 5/30/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
5215634.HT	Area	5/30/2004 5/31/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1952.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215637.HT	Area	5/30/2004 5/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1952.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215638.HT	Area	5/30/2004 5/31/2004	1	K	(NorthWest) - Cedar Decon	385	1952.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5220966.HT	Area	5/30/2004 5/30/2004	0	Z	(South) - Decon Exit	385	1864.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4