

Jun 08 04 10:26a IBM USER
From: RJ Lee Group, Inc. TO: Mr. Noel Drago

732 6018

p.12

5/31

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/3/2004
Sample Receipt Date: 6/2/2004
RJ Lee Group Job No.: ATH306366-758
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/m ²)	(S/cc)
5220170.HT	Area	5/31/2004 5/31/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2220.00	0.03483	0 0	< 28.7 28.7	< 0.005 0.005
5220171.HT	Area	5/31/2004 5/31/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2212.00	0.03483	0 0	< 28.7 28.7	< 0.005 0.005
5220172.HT	Area	5/31/2004 5/31/2004	99	N/A	(East) - Greenwich	385	2212.00	0.03483	0 0	< 28.7 28.7	< 0.005 0.005
5219692.HT	Area	5/31/2004 5/31/2004	0	Z	(South) - Decon Exit	385	1588.00	0.05224	0 0	< 19.1 19.1	< 0.005 0.005
5220174.HT	Area	6/1/2004 6/1/2004	1	K	(NorthWest) - Cedar Decon	385	2204.00	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5220173.HT	Area	5/31/2004 5/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2066.25	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5221042.HT	Field Blank	5/31/2004 5/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08707	0 0	< 11.5 11.3	N/A N/A
5219694.HT	Area	5/31/2004 5/31/2004	0	Y	(South) - Decon Entrance	385	1592.00	0.05224	0 0	< 19.1 19.1	< 0.005 0.005
5221043.HT	Area	5/31/2004 5/31/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1596.00	0.05224	0 0	< 19.1 19.1	< 0.005 0.005
5219693.HT	Area	5/31/2004 5/31/2004	0	FF	(South) - Shanty Area	385	1492.50	0.05224	0 0	< 19.1 19.1	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "---" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10644) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 5

Jun 08 04 10:27a

IBM USER

732 6018

p. 13

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/3/2004 Time: 6:41:04 AM

Page 3 of 5

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-758
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/3/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mmf)	(S/cc)
5221044.HT	Area	5/31/2004 5/31/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1600.00	0.05224	0 0	< 19.1 19.1	< 0.005 0.005
5221045.HT	Area	5/31/2004 5/31/2004	99	N/A	(East) - Greenwich	385	1596.00	0.05224	0 0	< 19.1 19.1	< 0.005 0.005
5221046.HT	Area	5/31/2004 5/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1604.00	0.05224	0 0	< 19.1 19.1	< 0.005 0.005
5221047.HT	Area	5/31/2004 5/31/2004	1	K	(NorthWest) - Cedar Decon	385	1604.00	0.05224	0 0	< 19.1 19.1	< 0.005 0.005
5219853.HT	Area	5/31/2004 5/31/2004	0	X	(South) - Ramp	385	1596.00	0.05224	0 0	< 19.1 19.1	< 0.005 0.005
5219854.HT	Field Blank	5/31/2004 5/31/2004	0	X	(South) - Ramp	385	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
5220169.HT	Field Blank	5/31/2004 5/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
5220168.HT	Field Blank	5/31/2004 5/31/2004	0	X	(South) - Ramp	385	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
5220167.HT	Area	5/31/2004 5/31/2004	0	X	(South) - Ramp	385	2081.25	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5220166.HT	Area	5/31/2004 5/31/2004	0	Y	(South) - Decon Entrance	385	2216.00	0.03483	0 0	< 28.7 28.7	< 0.005 0.005
5220165.HT	Area	5/31/2004 5/31/2004	0	FF	(South) - Shanty Area	385	2216.00	0.03483	0 0	< 28.7 28.7	< 0.005 0.005
5220164.HT	Area	5/31/2004 5/31/2004	0	Z	(South) - Decon Exit	385	2224.00	0.03483	0 0	< 28.7 28.7	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5

Juh 08 04 10:28a IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018

P. 14

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-758
Building: 130 Liberty

RJ Lee Group, Inc
Report Date: 6/3/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____



/sib

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "--" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10644) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 4 of 5

Jun 08 04 10:28a

IBM USER

732 6018

p. 15

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/3/2004
Sample Receipt Date: 6/2/2004
RJ Lee Group Job No.: ATH306366-759
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5215639.HT	Area	5/31/2004 6/1/2004	0	Z	(South) - Decon Exit	385	2069.75	0.04354	0 0	< 23.0 23.0	< 0.004 0.004
5215640.HT	Area	5/31/2004 6/1/2004	0	FF	(South) - Shanty Area	385	1826.25	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215641.HT	Area	5/31/2004 6/1/2004	0	Y	(South) - Decon Entrance	385	1952.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215642.HT	Area	5/31/2004 6/1/2004	0	X	(South) - Ramp	385	1948.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215645.HT	Area	5/31/2004 6/1/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1952.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215643.HT	Field Blank	5/31/2004 5/31/2004	0	X	(South) - Ramp	385	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A
5215646.HT	Area	5/31/2004 6/1/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1948.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215649.HT	Area	5/31/2004 6/1/2004	1	K	(NorthWest) - Cedar Decon	385	1956.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215648.HT	Area	5/31/2004 6/1/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1952.00	0.04354	0 0	< 23.0 23.0	< 0.005 0.005
5215644.HT	Field Blank	5/31/2004 5/31/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08707	0 0	< 11.5 11.5	N/A N/A

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jun 08 04 10:29a IBM USER
 From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
 Date: 6/3/2004 Time: 3:05:30 PM

Page 3 of 4 P. 16

RJ Lee Group, Inc.


Laboratory Report (cont.)

RJ Lee Group Job No: ATH306366-759
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 6/3/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4