

Jun 10 04 02:56p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 6/10/2004 Time: 10:10:10 AM

P. 12

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/9/2004
Sample Receipt Date: 6/8/2004
RJ Lee Group Job No.: ATH306366-771
Samples Received: 11
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mm ²)	(S/cc)
5220110.HT	Area	6/7/2004 6/7/2004	0	Z	(South) - Decon Exit	385	1864.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220111.HT	Area	6/7/2004 6/7/2004	0	FF	(South) - Shanty Area	385	1864.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220112.HT	Area	6/7/2004 6/7/2004	0	Y	(South) - Decon Entrance	385	1864.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220113.HT	Area	6/7/2004 6/7/2004	0	X	(South) - Ramp	385	1864.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220115.HT	Field Blank	6/7/2004 6/7/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08537	0 0	< 11.7 11.7	N/A N/A
5220114.HT	Field Blank	6/7/2004 6/7/2004	0	X	(South) - Ramp	385	0.000	0.08537	0 0	< 11.7 11.7	N/A N/A
5220116.HT	Area	6/7/2004 6/7/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1884.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220117.HT	Area	6/7/2004 6/7/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1896.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220119.HT	Area	6/7/2004 6/7/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1924.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220118.HT	Area	6/7/2004 6/7/2004	99	N/A	(East) - Greenwich	385	1916.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jun 10 04 02:56p IBM USER
 From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
 Date: 6/9/2004 Time: 10:15:16 AM

Page 3 of 4 P. 13

RJ Lee Group, Inc.


Laboratory Report (cont.)

RJ Lee Group Job No: ATH306366-771
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 6/9/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5220120.HT	Area	6/7/2004	6/7/2004	I	K	(NorthWest) - Cedar Devon	385	1936.00	0.04268	0	0	< 23.4	< 0.005
												23.4	0.005

Authorized Signature: _____

 /s/ Kimberly A. Allison, Manager - TEM Analysis

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

Jun 10 04 02:57p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Urigo

732 6018

P. 14

RJ LeeGroup, Inc.350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 6/10/2004
Sample Receipt Date: 6/9/2004
RJ Lee Group Job No.: ATH306366-775
Samples Received: 22
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5220755.HT	Area	6/7/2004 6/7/2004	0	Z	(South) - Decon Exit	385	1952.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220756.HT	Area	6/7/2004 6/7/2004	0	FF	(South) - Shanty Area	385	2074.00	0.04268	0 0	< 23.4 23.4	< 0.004 0.004
5220757.HT	Area	6/7/2004 6/7/2004	0	Y	(South) - Decon Entrance	385	1948.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220759.HT	Field Blank	6/7/2004 6/7/2004	0	X	(South) - Ramp	385	0.000	0.08537	0 0	< 11.7 11.7	N/A N/A
5220758.HT	Area	6/7/2004 6/7/2004	0	X	(South) - Ramp	385	1822.50	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220760.HT	Field Blank	6/7/2004 6/7/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08537	0 0	< 11.7 11.7	N/A N/A
5220761.HT	Area	6/7/2004 6/7/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1932.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220763.HT	Area	6/7/2004 6/7/2004	99	N/A	(East) - Greenwich	385	1904.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220764.HT	Area	6/7/2004 6/7/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1892.00	0.04268	0 0	< 23.4 23.4	< 0.005 0.005
5220765.HT	Area	6/7/2004 6/7/2004	1	K	(NorthWest) - Cedar Decon	385	1884.00	0.04268	1 0	23.4 23.4	0.005 0.005

Notes:

1. Volumes provided by Ambien were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 5

Jun 10 04 02:58p

IBM USER

732 6018

P. 15

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-775

RJ Lee Group, Inc.

Building: 130 Liberty

Report Date: 6/10/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
									Chry	Amph	(S/mm ²)	(S/cc)
5220762.HT	Area	6/7/2004 6/7/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1920.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220785.HT	Area	6/7/2004 6/8/2004	0	Z	(South) - Decon Exit	385	1932.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220786.HT	Area	6/7/2004 6/8/2004	0	FF	(South) - Shanty Area	385	1932.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220787.HT	Area	6/7/2004 6/8/2004	0	Y	(South) - Decon Entrances	385	1932.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220788.HT	Area	6/7/2004 6/8/2004	0	X	(South) - Ramp	385	1936.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220789.HT	Field Blank	6/7/2004 6/7/2004	0	X	(South) - Ramp	385	0.000	0.08537	0	0	< 11.7 11.7	N/A N/A
5220791.HT	Area	6/7/2004 6/8/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1924.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220792.HT	Area	6/7/2004 6/8/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1924.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220790.HT	Field Blank	6/7/2004 6/7/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08537	0	0	< 11.7 11.7	N/A N/A
5220793.HT	Area	6/7/2004 6/8/2004	99	N/A	(East) - Greenwich	385	1916.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220795.HT	Area	6/7/2004 6/8/2004	1	K	(NorthWest) - Cedar Decon	385	1920.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220794.HT	Area	6/7/2004 6/8/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1920.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5

Jun 10 04 02:59p

IBM USER

732 6018

p. 16

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/10/2004 Time: 8:32:18 AM

Page 4 of 5

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-775
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 6/10/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start Stop								Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature:



/slb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "----" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 4 of 5