

Jun 25 04 12:58p

IBM USER

732 6018

Page 2 of 4 P. 12

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 6/12/2004 Time: 10:04:00 AM

6/10

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 6/12/2004
Sample Receipt Date: 6/11/2004
RJ Lee Group Job No.: ATH306366-779
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
									Chrys	Amph	(S/mm ²)	(S/cc)
5220839.HT	Area	6/10/2004 6/10/2004	0	Z	(South) - Decon Exit	385	1992.00	0.04308	3	0	69.6 23.2	0.013 0.004
5220840.HT	Area	6/10/2004 6/10/2004	0	FF	(South) - Shanty Area	385	2000.00	0.04308	0	0	< 23.2 23.2	< 0.004 0.004
5220841.HT	Area	6/10/2004 6/10/2004	0	Y	(South) - Decon Entrance	385	2004.00	0.04308	0	0	< 23.2 23.2	< 0.004 0.004
5220842.HT	Area	6/10/2004 6/10/2004	0	X	(South) - Ramp	385	2012.00	0.04308	0	0	< 23.2 23.2	< 0.004 0.004
5220843.HT	Field Blank	6/10/2004 6/10/2004	0	X	(South) - Ramp	385	0.000	0.08615	0	0	< 11.6 11.6	N/A N/A
5220844.HT	Field Blank	6/10/2004 6/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08615	0	0	< 11.6 11.6	N/A N/A
5220845.HT	Area	6/10/2004 6/10/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2000.00	0.00000	0	0	N/A N/A	N/A N/A
5220846.HT	Area	6/10/2004 6/10/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2004.00	0.04308	0	0	< 23.2 23.2	< 0.004 0.004
5220847.HT	Area	6/10/2004 6/10/2004	99	N/A	(East) - Greenwich	385	2020.00	0.04308	0	0	< 23.2 23.2	< 0.004 0.004
5220848.HT	Area	6/10/2004 5/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2028.00	0.04308	0	0	< 23.2 23.2	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101209-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jun 25 04 12:59p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 6/12/2004 Time: 10:04:00 AM

Page 3 of 4 P. 13

RJ Lee Group, Inc.

Laboratory Report (cont.)

RJ Lee Group Job No: ATH306366-779
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 6/12/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
		Start	Stop							Chry	Amph	(S/mm ²)	(S/cc)
5220849-HT	Area	6/10/2004	6/10/2004	1	K	(NorthWest) - Cedar Decon	385	2028.00	0.04308	0	0	<23.2 23.2	<0.004 0.004

Authorized Signature: _____ /slb

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

Jun 25 04 12:59p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 6/12/2004 Time: 10:04:00 AM

Page 3 of 4 P. 13

RJ Lee Group, Inc.

Laboratory Report (cont.)

RJ Lee Group Job No: ATH306366-779
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 6/12/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5220849.HT	Area	6/10/2004	6/10/2004	1	K	(NorthWest) - Cedar Decon	385	2028.00	0.04308	0	0	< 23.2 23.2	< 0.004 0.004

Authorized Signature: _____ /s/b

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

Jun 25 04 01:00p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 6/12/2004 Time: 7:14:45 PM

Page 2 of 5 P. 14

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/12/2004
Sample Receipt Date: 6/12/2004
RJ Lee Group Job No: ATH306366-780
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
		Start	Stop								Analytical Sensitivity (S/mm ²)	(S/cc)
5220130.HT	Area	6/10/2004	6/10/2004	0	Z	(South) - Decon Exit	385	2032.50	0.04308	0 0	< 23.2 23.2	< 0.004 0.004
5220132.HT	Area	6/10/2004	6/10/2004	0	Y	(South) - Decon Entrance	385	2156.00	0.04308	0 0	< 23.2 23.2	< 0.004 0.004
5220133.HT	Area	6/10/2004	6/10/2004	0	X	(South) - Ramp	385	2148.00	0.04308	0 0	< 23.2 23.2	< 0.004 0.004
5220131.HT	Area	6/10/2004	6/10/2004	0	FF	(South) - Shanty Area	385	2160.00	0.04308	0 0	< 23.2 23.2	< 0.004 0.004
5220134.HT	Field Blank	6/10/2004	6/10/2004	0	X	(South) - Ramp	385	0.000	0.08615	0 0	< 11.6 11.6	N/A N/A
5220136.HT	Area	6/10/2004	6/10/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2017.50	0.04308	0 0	< 23.2 23.2	< 0.004 0.004
5220135.HT	Field Blank	6/10/2004	6/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08615	0 0	< 11.6 11.6	N/A N/A
5220138.HT	Area	6/10/2004	6/10/2004	99	N/A	(East) - Greenwich	385	2132.00	0.04308	0 0	< 23.2 23.2	< 0.004 0.004
5220137.HT	Area	6/10/2004	6/10/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2152.00	0.04308	0 0	< 23.2 23.2	< 0.004 0.004
5220139.HT	Area	6/10/2004	6/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2120.00	0.04308	0 0	< 23.2 23.2	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 5

Jun 25 04 01:00p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 6/12/2004 Time: 7:14:48 PM

Page 3 of 5 P. 15

RJ Lee Group, Inc.

Laboratory Report (cont.)

RJ Lee Group Job No: ATH306366-780
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 6/12/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
									Chry	Amph	(S/mmf)	(S/cc)
5220140.HT	Area	6/10/2004 6/10/2004	1	K	(NorthWest) - Cedar Decon	385	2120.00	0.04308	0	0	< 23.2 23.2	< 0.004 0.004
5220267.HT	Area	6/10/2004 6/11/2004	0	FF	(South) - Shanty Area	385	1660.00	0.05169	0	0	< 19.3 19.3	< 0.004 0.004
5220266.HT	Area	6/10/2004 6/11/2004	0	Z	(South) - Decon Exit	385	1660.00	0.05169	0	0	< 19.3 19.3	< 0.004 0.004
5220268.HT	Area	6/10/2004 6/11/2004	0	Y	(South) - Decon Entrance	385	1660.00	0.05169	0	0	< 19.3 19.3	< 0.004 0.004
5220269.HT	Area	6/10/2004 6/11/2004	0	X	(South) - Ramp	385	1660.00	0.05169	0	0	< 19.3 19.3	< 0.004 0.004
5220270.HT	Field Blank	6/10/2004 6/10/2004	0	X	(South) - Ramp	385	0.000	0.08615	0	0	< 11.6 11.6	N/A N/A
5220271.HT	Field Blank	6/10/2004 6/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08615	0	0	< 11.6 11.6	N/A N/A
5220273.HT	Area	6/10/2004 6/11/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1660.00	0.05169	0	0	< 19.3 19.3	< 0.004 0.004
5220274.HT	Area	6/10/2004 6/11/2004	99	N/A	(East) - Greenwich	385	1664.00	0.05169	0	0	< 19.3 19.3	< 0.004 0.004
5220275.HT	Area	6/10/2004 6/11/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1664.00	0.05169	0	0	< 19.3 19.3	< 0.004 0.004
5220272.HT	Area	6/10/2004 6/11/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1664.00	0.05169	0	0	< 19.3 19.3	< 0.004 0.004
5220276.HT	Area	6/10/2004 6/11/2004	1	K	(NorthWest) - Cedar Decon	385	1664.00	0.05169	0	0	< 19.3 19.3	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 5