

Jul 13 04 02:20p

IBM USER

732 6018

P. 10

1/9

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
 Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
 350 Hochberg Road
 Monroeville, PA 15146
 USA

Report Date: 7/10/2004
 Sample Receipt Date: 7/10/2004
 RJ Lee Group Job No: ATH306366-866
 Samples Received: 0
 Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5225738.HT	Area	7/9/2004 7/9/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1812.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225737.HT	Field Blank	7/9/2004 7/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08773	0 0	< 11.4 11.4	N/A N/A
5225739.HT	Area	7/9/2004 7/9/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1816.00	0.04386	4 0	91.2 22.8	0.019 0.005
5225740.HT	Area	7/9/2004 7/9/2004	99	N/A	(East) - Greenwich	385	1808.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225741.HT	Area	7/9/2004 7/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1812.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005

Authorized Signature: _____ /sib

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

Jul 13 04 02:21p

IBM USER

732 6018

P.11

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/13/2004
Sample Receipt Date: 7/12/2004
RJ Lee Group Job No.: ATH306366-870
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5225204.HT	Field Blank	7/9/2004 7/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08773	0 0	< 11.4 11.4	N/A N/A
5225205.HT	Area	7/9/2004 7/9/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1880.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225206.HT	Area	7/9/2004 7/9/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1876.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225207.HT	Area	7/9/2004 7/9/2004	99	N/A	(East) - Greenwich	385	1864.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225208.HT	Area	7/9/2004 7/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1860.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225626.HT	Field Blank	7/9/2004 7/9/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08773	0 0	< 11.4 11.4	N/A N/A
5225628.HT	Area	7/9/2004 7/10/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2072.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5225629.HT	Area	7/9/2004 7/10/2004	99	N/A	(East) - Greenwich	385	2068.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5225630.HT	Area	7/9/2004 7/10/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2080.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5225627.HT	Area	7/9/2004 7/10/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2072.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "----" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 13 04 02:21p

IBM USER

732 6018

p. 12

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 7/13/2004 Time: 11:36:58 AM

Page 3 of 4

RJ Lee Group, Inc.**Laboratory Report (cont.)**RJ Lee Group Job No: ATH306366-870
Building: 130 LibertyRJ Lee Group, Inc.
Report Date: 7/13/2004

RJLG Sample Number	Sample Type	Date Collected Start Stop		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph		Concentration	
												Analytical Sensitivity (S/mm ²)	(S/cc)

Authorized Signature: _____



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4

Jul 13 04 02:22p IBM USER
From: RJ Lee Group, Inc. To: Mr. Noel Drago

732 6018
Date: 7/13/2004 Time: 1:38:10 PM

Page 2 of 4 P. 13

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/13/2004
Sample Receipt Date: 7/12/2004
RJ Lee Group Job No.: ATH306366-871
Samples Received: 12
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5225199.HT	Area	7/9/2004 7/9/2004	0	Z	(South) - Decon Exit	385	1920.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225200.HT	Area	7/9/2004 7/9/2004	0	FF	(South) - Shanty Area	385	1892.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225201.HT	Area	7/9/2004 7/9/2004	0	Y	(South) - Decon Entrance	385	1888.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225202.HT	Area	7/9/2004 7/9/2004	0	X	(South) - Ramp	385	1884.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225203.HT	Field Blank	7/9/2004 7/9/2004	0	X	(South) - Ramp	385	0.000	0.08773	0 0	< 11.4 11.4	N/A N/A
5225209.HT	Area	7/9/2004 7/9/2004	1	K	(NorthWest) - Cedar Decon	385	1852.00	0.04386	0 0	< 22.8 22.8	< 0.005 0.005
5225621.HT	Area	7/9/2004 7/10/2004	0	Z	(South) - Decon Exit	385	2060.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5225622.HT	Area	7/9/2004 7/10/2004	0	FF	(South) - Shanty Area	385	2060.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5225623.HT	Area	7/9/2004 7/10/2004	0	Y	(South) - Decon Entrance	385	2060.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004
5225624.HT	Area	7/9/2004 7/10/2004	0	X	(South) - Ramp	385	2068.00	0.04386	0 0	< 22.8 22.8	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

Jul 13 04 02:23p

IBM USER

732 6018

P. 14

RJ Lee Group, Inc.**Laboratory Report (cont.)**

RJ Lee Group Job No: ATH306366-871
 Building: 130 Liberty

RJ Lee Group, Inc.
 Report Date: 7/13/2004

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
		Start	Stop							Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5225625.HT	Field Blank	7/9/2004	7/9/2004	0	X	(South) - Ramp	385	0.000	0.08773	0	0	< 11.4 11.4	N/A N/A
5225631.HT	Area	7/9/2004	7/10/2004	1	K	(NorthWest) - Cedar Decon	385	2084.00	0.04386	0	0	< 22.8 22.8	< 0.004 0.004

Authorized Signature: _____



/sib

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 3 of 4