

7/28

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/30/2004
Sample Receipt Date: 7/29/2004
RJ Lee Group Job No.: ATH306366-935
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5226556.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1816.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227565.HT	Field Blank	7/28/2004 7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0 0	< 11.4 11.4	N/A N/A
5227566.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1792.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227567.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1812.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227568.HT	Area	7/28/2004 7/28/2004	99	N/A	(East) - Greenwich	385	1816.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005

Authorized Signature: _____



/slb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 1 of 2

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/29/2004
Sample Receipt Date: 7/28/2004
RJ Lee Group Job No.: ATH306366-932
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5226674.HT	Field Blank	7/26/2004 7/26/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08789	0 0	< 11.4 11.4	N/A N/A
5226675.HT	Area	7/26/2004 7/27/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1920.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5226676.HT	Area	7/26/2004 7/27/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1920.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5226677.HT	Area	7/26/2004 7/27/2004	99	N/A	(East) - Greenwich	385	1912.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5226678.HT	Area	7/26/2004 7/27/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1908.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5227540.HT	Area	7/26/2004 7/26/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1948.00	0.04394	0 0	< 22.8 22.8	< 0.004 0.004
5227539.HT	Field Blank	7/26/2004 7/26/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08789	0 0	< 11.4 11.4	N/A N/A
5227541.HT	Area	7/26/2004 7/26/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1924.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5227542.HT	Area	7/26/2004 7/26/2004	99	N/A	(East) - Greenwich	385	1920.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5227543.HT	Area	7/26/2004 7/26/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1924.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 1 of 3