

Aug 03 04 03:17p

IBM USER

732 6018

p. 8

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/30/2004
Sample Receipt Date: 7/29/2004
RJ Lee Group Job No.: ATH306366-935
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
		Start	Stop							Chry	Amph	(S/mm ²)	(S/cc)
5226556.HT	Area	7/28/2004	7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1816.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5227565.HT	Field Blank	7/28/2004	7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0	0	< 11.4 11.4	N/A N/A
5227566.HT	Area	7/28/2004	7/28/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1792.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5227567.HT	Area	7/28/2004	7/28/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1812.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5227568.HT	Area	7/28/2004	7/28/2004	99	N/A	(East) - Greenwich	385	1816.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005

Authorized Signature: _____

Kimberly A. Allison, Manager - TEM Analysis

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY E!AP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 1 of 2

Aug 03 04 03:18p

IBM USER

From: RJ Lee Group, Inc To: Mr. Noel Drago

Date: 7/31/2004 Time: 8:54:42 AM

732 6018

Page 2 of 4 P. 9

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report**TEM Air Analysis**

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/31/2004
Sample Receipt Date: 7/30/2004
RJ Lee Group Job No: ATH306366-938
Samples Received: 0
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start/Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration	
									Chry	Amph	Analytical Sensitivity (S/mm ²)	(S/cc)
5226715.HT	Field Blank	7/28/2004 7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0	0	< 11.4 11.4	N/A N/A
5226716.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1892.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5226718.HT	Area	7/28/2004 7/28/2004	99	N/A	(East) - Greenwich	385	1856.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5226719.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1844.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5226746.HT	Field Blank	7/28/2004 7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0	0	< 11.4 11.4	N/A N/A
5226747.HT	Area	7/28/2004 7/29/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1923.75	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5226748.HT	Area	7/28/2004 7/29/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2056.00	0.04396	0	0	< 22.7 22.7	< 0.004 0.004
5226717.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1864.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5226749.HT	Area	7/28/2004 7/29/2004	99	N/A	(East) - Greenwich	385	2056.00	0.04396	0	0	< 22.7 22.7	< 0.004 0.004
5226750.HT	Area	7/28/2004 7/29/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2060.00	0.04396	0	0	< 22.7 22.7	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-G, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/30/2004
Sample Receipt Date: 7/29/2004
RJ Lee Group Job No.: ATH306366-935
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

R.J.L.G Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mmf)	(S/cc)
5226556.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1816.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227565.HT	Field Blank	7/28/2004 7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0 0	< 11.4 11.4	N/A N/A
5227566.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1792.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227567.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1812.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005
5227568.HT	Area	7/28/2004 7/28/2004	99	N/A	(East) - Greenwich	385	1816.00	0.04396	0 0	< 22.7 22.7	< 0.005 0.005

Authorized Signature: _____



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes.

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "N/A" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NYLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 1 of 2

Aug 05 04 12:35p

IBM USER

732 6018

p. 4

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146


Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/30/2004
Sample Receipt Date: 7/29/2004
RJ Lee Group Job No.: ATH306366-935
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
									Chry	Amph	(S/mm ²)	(S/cc)
5226556.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1816.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5227565.HT	Field Blank	7/28/2004 7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0	0	< 11.4 11.4	N/A N/A
5227566.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1792.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5227567.HT	Area	7/28/2004 7/28/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1812.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005
5227568.HT	Area	7/28/2004 7/28/2004	99	N/A	(East) - Greenwich	385	1816.00	0.04396	0	0	< 22.7 22.7	< 0.005 0.005

Authorized Signature: _____



/s/b

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 1 of 2