

Aug 05 04 12:24p

IBM USER

732 6018

p. 2

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 7/29/2004 Time: 9:23:24 AM

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 7/29/2004
Sample Receipt Date: 7/28/2004
RJ Lee Group Job No.: ATH306366-931
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	Analytical Sensitivity (S/cc)
5227555.HT	Area	7/27/2004 7/27/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1924.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5227556.HT	Area	7/27/2004 7/27/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1932.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5227557.HT	Area	7/27/2004 7/27/2004	99	N/A	(East) - Greenwich	385	1944.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5227558.HT	Area	7/27/2004 7/27/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1948.00	0.04394	0 0	< 22.8 22.8	< 0.004 0.004
5227868.HT	Field Blank	7/27/2004 7/27/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08789	0 0	< 11.4 11.4	N/A N/A

Authorized Signature: _____



/s/lb

Kimberly A. Allison, Manager - TEM Analysis

Notes:

1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

Aug 05 04 12:34p

IBM USER

732 6018

Page 2 of 3 P. 2

From: RJ Lee Group, Inc. To: Mr. Noel Drago

Date: 7/29/2004 Time: 9:23:24 AM

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146

Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report**TEM Air Analysis**

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/29/2004
Sample Receipt Date: 7/28/2004
RJ Lee Group Job No.: AT11306366-931
Samples Received: 5
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
										Analytical Sensitivity (S/mm ²)	(S/cc)
5227555.HT	Area	7/27/2004 7/27/2004	99	Not Acquired	(South West) - Washington and Albany	385	1924.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5227556.HT	Area	7/27/2004 7/27/2004	99	Not Acquired	(South East) - Greenwich and Albany	385	1932.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5227557.HT	Area	7/27/2004 7/27/2004	99	N/A	(East) - Greenwich	385	1944.00	0.04394	0 0	< 22.8 22.8	< 0.005 0.005
5227558.HT	Area	7/27/2004 7/27/2004	99	Not Acquired	(North West) - Washington and Cedar	385	1943.00	0.04394	0 0	< 22.8 22.8	< 0.004 0.004
5227868.HT	Field Blank	7/27/2004 7/27/2004	99	Not Acquired	(North West) - Washington and Cedar	385	0.000	0.08789	0 0	< 11.4 11.4	N/A N/A

Authorized Signature: _____



/s/

Kimberly A. Allison, Manager - TEM Analysis

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "..." indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 2 of 3

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 7/30/2004
Sample Receipt Date: 7/29/2004
RJ Lee Group Job No.: ATH306366-934
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected		Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration	
		Start	Stop								Analytical Sensitivity (S/mm ²)	(S/cc)
5226550.HT	Field Blank	7/27/2004	7/27/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08792	0 0	< 11.4 11.4	N/A N/A
5226551.HT	Area	7/27/2004	7/28/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2088.00	0.04396	0 0	< 22.7 22.7	< 0.004 0.004
5226552.HT	Area	7/27/2004	7/28/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2096.00	0.04396	0 0	< 22.7 22.7	< 0.004 0.004
5226553.HT	Area	7/27/2004	7/28/2004	99	N/A	(East) - Greenwich	385	2104.00	0.04396	0 0	< 22.7 22.7	< 0.004 0.004
5226554.HT	Area	7/27/2004	7/28/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2116.00	0.04396	0 0	< 22.7 22.7	< 0.004 0.004
5226694.HT	Field Blank	7/27/2004	7/27/2004	99	Not Acquired	(North West) - Washington and Cedar	385	0.000	0.08792	0 0	< 11.4 11.4	N/A N/A
5226695.HT	Area	7/27/2004	7/27/2004	99	Not Acquired	(South West) - Washington and Albany. It was raining as I was setting up the sample.	385	1732.00	0.05275	0 0	< 19.0 19.0	< 0.004 0.004
5226696.HT	Area	7/27/2004	7/27/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1724.00	0.05275	0 0	< 19.0 19.0	< 0.004 0.004
5226697.HT	Area	7/27/2004	7/27/2004	99	N/A	(East) - Greenwich It was raining as the sample was being set up.	385	1712.00	0.05275	0 0	< 19.0 19.0	< 0.004 0.004
5226698.HT	Area	7/27/2004	7/27/2004	99	Not Acquired	(NorthWest) - Washington and Cedar. It was raining as the sample was being set up.	385	1706.00	0.05275	0 0	< 19.0 19.0	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures
- Samples will be held for 90 days and then disposed of per Federal regulations
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

Page 1 of 3