

ADDENDUM #2

World Trade Center Dust Cleaning Program Monitoring Contract Scope of Work

- Outside air intake louvers, grates and screens
- Outside air duct
- Outside air dampers
- Return air grilles
- Return air plenum
- Return air plenum damper
- Return air ducts
- Turning vanes
- Mixing chambers
- Filter rack
- Filter banks/media
- Pre-heat coils
- Cooling coils
- Re-heat coils
- Humidification and/or air cleaning equipment
- Fire dampers
- In-line re-heat coils
- Interior insulation
- Duct connectors
- Blower assembly including blower wheel, blower housing, air vanes, in-line noise attenuators, acoustical treatments (e.g., baffles, duct linings)
- Condensate drain pan
- Condensate accumulator
- Supply air plenum
- Supply air plenum damper
- Supply plenum or supply duct linings
- Supply air ducts (high and low pressure)
- Supply air diffusers
- Terminal boxes
- Open or ducted passive ventilation shafts

6.5 Evaluation Procedures

6.5.1 Accessibility

6.5.1.1 Locate System Components Accessible for Visual Inspection

The HVAC/Electrical Professional shall make an assessment of the accessibility of the various components of the system. For example, components may be enclosed within permanent sheet metal panels, or may be located above or behind solid plaster ceilings and walls.