

- q. Dishwashers toe plates will be removed and the floor beneath the appliance will be cleaned.
 - r. Protective covers on finned radiant heaters and baseboard heaters will be removed to expose heat elements. Fins are to be brushed and vacuumed to remove dust.
 - s. All cleaning equipment will be vacuumed and/or wet wiped for use on the residence.
7. HEPA air filtration devices (AFDs) will run continuously during all cleaning activities as appropriate given site conditions. A minimum of one air change every 30-minutes shall be provided. A standard 1200 cfm device shall be installed per 36,000 cubic feet.
 8. An adequate number of asbestos supervisors shall be present at each work place (work place is defined in Title 15, Chapter 1 RCNY as the work area and the decontamination enclosure system).
 9. A cleaning checklist (to be developed) will be completed by the supervisor at the completion of the cleaning.
 10. A thorough visual inspection will be conducted by the Project Monitor to verify the absence of visible dust accumulations. Additional clean-up procedures shall be performed where visible dust is observed.
 11. Air sampling shall be performed by the Air Sampling Technician after the area is free of dust accumulations as determined by the Project Monitor. If the apartment does not meet the 30 year 10-04 risk based clean up criteria the apartment will be recleaned and retested.
 12. Any damage or loss to that occurs during cleaning is the responsibility of the cleaning contractor. The cleaning contractor is not responsible for damage or loss caused by the acts of parties not involved in the cleanup.
 13. All waste generated shall be treated as asbestos containing material. Transportation and disposal of generated waste shall be in compliance with all applicable rules and regulations.