

ADDENDUM #2

World Trade Center Dust Cleaning Program Monitoring Contract Scope of Work

4. The minimum personal protective equipment required for use by the HVAC/Electrical Professional includes:
 - a. a supply of disposable protective coveralls
 - b. a supply of disposable protective gloves
 - c. safety glasses
 - d. respiratory protection as specified in item 4 below
5. The HVAC/Electrical Professional shall be capable of wearing and shall be provided with a P100 air purifying respirator with appropriate medical determination, fit testing and training as required under OSHA's personal protective equipment standard.
6. The HVAC/Electrical Professional shall have received 2-hour asbestos awareness training.
7. The HVAC/Electrical Professional shall be responsible for:
 - a. the lockout/tagout of electrical or mechanical hazards required to safely perform the evaluations;
 - b. the HVAC/Electrical Professional's firm shall provide sound equipment as needed to meet OSHA's fall protection requirements that may be applicable to parts of the evaluations and the HVAC/Electrical Professional shall be responsible for implementing the use of such equipment;
 - c. locating and identifying ventilation system components to be included in the evaluation;
 - d. any disassembly of any ventilation equipment and components required to complete the evaluation, and proper re-assembly following the evaluation; and
 - e. assist the Environmental Professional in making determinations required in Item 6.4.

5.3 Sheet Metal Professional – Requirements

Requirements for the Sheet Metal Professional, if part of the evaluation team, are identical to those listed in item 5.2 for the HVAC/Electrical Professional.

5.4 Environmental Professional - Requirements

The Environmental Professional shall hold a current EPA accreditation as an AHERA Building Inspector. The primary purpose of the asbestos certification requirement is to be able to identify asbestos-containing materials and asbestos-related hazards in order to avoid the disturbance of asbestos-containing materials during the evaluations.

1. The Environmental Professional shall have current EPA accreditation as an AHERA Building Inspector in any U.S. state.