

ADDENDUM #2

World Trade Center Dust Cleaning Program Monitoring Contract Scope of Work

- Rotary metal cutting saw
- For covering service openings, sheet metal plates, panels or access doors meeting NADCA 9705, NFPA 90A/90B and SMACNA specifications
- Telescoping inspection mirrors and flashlights
- Boroscope
- HEPA vacuum

6.4 Typical system components for each equipment category

The ventilation systems may contain, but may not necessarily be limited to combinations of the listed components in each category.

6.4.1 Ventilators, wall air conditioning units and window air conditioning units in common spaces

- Outside air intake louvers, grates and screens
- Outside air duct
- Outside air dampers
- Return air grille
- Return air plenum
- Filter rack
- Filter media
- Coils (evaporator)
- Blower assembly
- Condensate drain pan
- In-line electrical resistance strip heaters (in supply ducts connected to unit ventilators)
- Fire dampers
- Turning vanes
- Supply plenum or supply duct liner
- Supply air diffuser

6.4.2 Fan coil/heat pump units in common spaces

- Return grille
- Return air plenum
- Filter rack
- Filter media
- Blower assembly
- Thermal coils
- Supply plenum
- Supply diffusers

6.4.3 Central air system