



Pilot Confirmation Cleaning Study USEPA Region 2



Summary of Cleaning Techniques and Reasons for Additional Cleaning

Residential	Cleaning Technique	First-Cleaning	Second-Cleaning	Third-Cleaning
2A	Ridgid shop vacuum and Hoover upright, w/AFD	Asbestos overload	Cleared for everything	
2B	Industrial HEPA vacuum	Cleared for everything		
2nd Floor	Industrial HEPA vacuum, w/AFD	Cleared for everything		
3A	Craftsman shop vacuum and Eureka upright, w/HEPA and AFD	Cleared for everything		
3B	Industrial HEPA vacuum, w/AFD	Asbestos and lead (wipe) exceedance	Cleared for everything	
3C	Craftsman shop vacuum and Eureka upright	Asbestos overload and lead (microvac) exceedance	Asbestos overload and MMVF (air) exceedance	Cleared for everything
3D	Ridgid shop vacuum and Hoover upright	Asbestos overload	Cleared for everything	
3rd Floor	Industrial HEPA vacuum, w/AFD	Cleared for everything		
4A	Craftsman shop vacuum and Eureka upright, w/HEPA	Asbestos overload and silica (air) exceedance	Cleared for everything	
4B	Ridgid shop vacuum and Hoover upright, w/HEPA and AFD	Cleared for everything		
4C	Craftsman shop vacuum and Eureka upright	Cleared for everything		
4D	Ridgid shop vacuum and Eureka upright, w/HEPA	Pre-cleaning wipe lead exceedance w/post-cleaning samples not analyzed	Cleared for everything	
4th Floor	Industrial HEPA vacuum, w/AFD	Cleared for everything		
5A	Industrial HEPA vacuum, w/AFD	Lead (wipe) exceedance	Cleared for everything	
5C	Industrial HEPA vacuum	Asbestos overload and MMVF (air) exceedance	Asbestos overload and MMVF (air) exceedance	Cleared for everything (asbestos @ modified-aggressive sampling)
5D	Industrial HEPA vacuum, w/AFD	Cleared for everything		
5th Floor	Industrial HEPA vacuum, w/AFD	Asbestos overload	Cleared for everything	

75% test low
Aggressive