

THE CITY RECORD

VOL. CI NUMBER 30329

NEW YORK, WEDNESDAY, JUNE 6, 1973

PRICE 25 CENTS

THE CITY RECORD

OFFICIAL JOURNAL OF THE CITY OF NEW YORK

Published by the Municipal Service Administration of The City of New York
under authority of Subdivision 7 of Section 1603 of The New York City Charter.

JOHN V. LINDSAY, Mayor

MILTON MUSICUS, Administrator, Municipal Service Administration HENRY M. CHRISTMAN, Director of The City Record
EDWARD MURPHY, Deputy Director

City Record Editorial Office
2223 Municipal Building
New York, N. Y. 10007
Telephone: 566-2613



City Record Sales Office
31 Chambers Street
New York, N. Y. 10007
Telephone: 566-2618

Published daily, at 9 a. m., except Sundays and legal holidays. Subscription: \$50 a year; \$25 six months; \$12.50 three months. Daily issue, 25 cents a copy (by mail, 50 cents).
Second class postage paid at New York, N. Y.

OTHER CITY RECORD PUBLICATIONS

Order must be accompanied by currency, money order or check drawn to the order of "Director of THE CITY RECORD." Checks for \$20 or more must be certified.
All orders for publications to be sent by mail (except subscription to THE CITY RECORD) must be accompanied by payment in advance of the price quoted below per publication to cover the cost of postage and handling. Responsibility is accepted for Insured Mail only.

MEA 55-73-M

Report of Material and Equipment Acceptance Division

Manufacturer—Rapco Chemical Inc., Route 76, Mayesville, South Carolina 29104.

Trade Name—Rapco Foam.

Product—Thermal insulation.

Pertinent Code Section—C26-201.0.

Prescribed Test—ASTM E136-65 and toxicity.

Test Report—American Standards Testing Bureau, Inc. No. 15071, dated January 9, 1973.

Description—A urea formaldehyde resin which is treated under air pressure with a foaming agent to produce a foamy liquid. This material flows into and fills all cavities and spaces, and after it cold sets acts as a thermal insulating material.

Recommendation—That the above described material be accepted as complying with the definition of a non-combustible material for use where permitted in the Building Code. It shall not be used to give a fire resistance rating to an assembly unless the entire assembly is tested for such fire resistance rating. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable, for use, as provided for in sub-article 106.0 of the Building Code.