



LEAK DETECTION JULY - DECEMBER 2001

WARDS ISLAND

1/11/2002

PLANT	WPCP	BOROUGH	ADDRESS	CONDITION	LEAKTYP	GPDAMOUNT	MONTH	COMPLAINT OR SURVEY
-------	------	---------	---------	-----------	---------	-----------	-------	---------------------

WIWI01NEW YORK

WI	WI01	NEW YORK	62 EAST 83RD STREET	DEFECTIVE HYDT VALVE	HYDT	1440	SEPTEMBER	SURV.
WI	WI01	NEW YORK	110 EST 71ST STREET	3/4" TAP, 1" LINE	SERVICE	24480	OCTOBER	COMP.
WI	WI01	NEW YORK	114 EAST 71ST STREET	3/4" TAP, 1" LINE	SERVICE	24480	DECEMBER	COMP.

WATER SAVINGS FOR WI01 50,400 GALLONS

WI02NEW YORK

WI	WI02	NEW YORK	1217 PARK AVENUE	12"X3"W.C.TAKEN AS JT LEAK	SERVICE	41300	NOVEMBER	COMP.
----	------	----------	------------------	----------------------------	---------	-------	----------	-------

WATER SAVINGS FOR WI02 41,300 GALLONS

WI03

NC = NEWTOWN CREEK NR = NORTH RIVER WI = WARDS ISLAND

1/11/2002

PLANT	WPCP	BOROUGH	ADDRESS	CONDITION	LEAKTYP	GPDAMOUNT	MONTH	COMPLAINT OR SURVEY
<u>NEW YORK</u>								
WI	WI03	NEW YORK	1365 5TH AVENUE	3/4" TAP, 1" LINE	SERVICE	24480	JULY	COMP.
WI	WI03	NEW YORK	2ND AVENUE && EAST 105TH STREET	ABANDONED 3/4" TAP, 1" LINE	SERVICE	24480	JULY	COMP.
WI	WI03	NEW YORK	W/S FDR DRIVE S/O EAST 111TH STREET	DEFECTIVE HYDT VALVE	HYDT	1440	SEPTEMBER	SURV.
WI	WI03	NEW YORK	N/S EAST 119TH STREET W/O 1ST AVENUE	DEFECTIVE HYDT VALVE	HYDT	1440	SEPTEMBER	SURV.
WATER SAVINGS FOR					WI03	51,840	GALLONS	
<u>WI04</u>								
<u>NEW YORK</u>								
WI	WI04	NEW YORK	531 LENOX AVENUE	3/4" TAP, 1" LINE	SERVICE	24480	AUGUST	COMP.
WI	WI04	NEW YORK	N/S WEST 126TH STREET E/O ST. NICHOLAS AVENUE	DEFECTIVE HYDT VALVE	HYDT	1440	OCTOBER	SURV.
WATER SAVINGS FOR					WI04	25,920	GALLONS	
<u>WI05</u>								
<u>NEW YORK</u>								
WI	WI05	NEW YORK	N/S WEST 142ND STREET W/O 7TH AVENUE	DEFECTIVE HYDT VALVE	HYDT	1440	SEPTEMBER	SURV.
WI	WI05	NEW YORK	121 WEST 144TH STREET	DEFECTIVE HYDT VALVE	HYDT	1440	SEPTEMBER	SURV.

NC = NEWTOWN CREEK NR = NORTH RIVER WI = WARDS ISLAND

1/11/2002

PLANT	WPCP	BOROUGH	ADDRESS	CONDITION	LEAKTYP	GPDAMOUNT	MONTH	COMPLAINT OR SURVEY
WI	WI05	NEW YORK	WEST 128TH STREET && ST NICHOLAS AVENUE	PACKING LEAK ON 12" VALVE	VALVE	1440	SEPTEMBER	SURV.
WATER SAVINGS FOR				WI05	4,320	GALLONS		
<u>WI06</u>								
<u>NEW YORK</u>								
WI	WI06	NEW YORK	E/S ADAM POWELL BLVD N/O WEST 146TH STREET	6" JOINT LEAK	JOINT	41300	SEPTEMBER	SURV.
WATER SAVINGS FOR				WI06	41,300	GALLONS		
<u>WI07</u>								
<u>NEW YORK</u>								
WI	WI07	NEW YORK	N/S WEST 170TH STREET W/O AMSTERDAM AVENUE	DEFECTIVE HYDT VALVE	HYDT	1440	OCTOBER	SURV.
WATER SAVINGS FOR				WI07	1,440	GALLONS		
<u>WI08</u>								
<u>BRONX</u>								
WI	WI08	BRONX	ELTON AVENUE B/T E.154TH & E.155TH STREET	ABANDONED 12'X4'W.C.TAKEN AS J	VALVE	1440	SEPTEMBER	SURV.
WI	WI08	BRONX	429 EAST 154TH STREET	5/8" TAP, 3/4" LINE	SERVICE	12240	SEPTEMBER	SURV.
WI	WI08	BRONX	N/S EAST 142ND STREET W/O BROOK AVENUE	PACKING LEAK ON 6" VALVE	VALVE	1400	SEPTEMBER	SURV.

NC = NEWTOWN CREEK NR = NORTH RIVER WI = WARDS ISLAND

1/11/2002

PLANT	WPCP	BOROUGH	ADDRESS	CONDITION	LEAKTYP	GPDAMOUNT	MONTH	COMPLAINT OR SURVEY
WI	WI08	BRONX	465 EAST 140TH STREET	1-1/2" TAP, 2" LINE	SERVICE	158400	SEPTEMBER	SURV.
WI	WI08	BRONX	N/S EAST 136TH STREET W/O WALNUT AVENUE	PACKING LEAK ON 6" VALVE	VALVE	1440	OCTOBER	SURV.

WATER SAVINGS FOR WI08 174,920 GALLONS

WI09BRONX

WI	WI09	BRONX	1225 SHERIDAN AVENUE	PACKING LEAK ON 6" VALVE	VALVE	1440	OCTOBER	SURV.
WI	WI09	BRONX	W/S SHERIDAN AVENUE S/O EAST 164TH STREET	DEFECTIVE HYDT VALVE	HYDT	1440	OCTOBER	SURV.
WI	WI09	BRONX	W/S EAGLE AVENUE S/O EAST 159TH STREET	DEFECTIVE HYDT VALVE	HYDT	1440	OCTOBER	SURV.
WI	WI09	BRONX	1225 SHERIDAN AVENUE	6" CIRCUALR BREAK	MAIN BREAK	259490	OCTOBER	SURV.
WI	WI09	BRONX	1881 WALTON AVENUE	3/4" TAP, 1" LINE	SERVICE	24480	NOVEMBER	COMP.
WI	WI09	BRONX	20 MOUNT HOPE PLACE	3/4" TAP, 1" LINE	SERVICE	24480	DECEMBER	COMP.

NEW YORK

WI	WI09	NEW YORK	N/S WEST 182ND STREET W/O AUDABON AVENUE	DEFECITIVE HYDT VALVE	HYDT	1440	AUGUST	SURV.
----	------	----------	--	-----------------------	------	------	--------	-------

WATER SAVINGS FOR WI09 314,210 GALLONS

WI10

NC = NEWTOWN CREEK NR = NORTH RIVER WI = WARDS ISLAND

1/11/2002

PLANT	WPCP	BOROUGH	ADDRESS	CONDITION	LEAKTYP	GPDAMOUNT	MONTH	COMPLAINT OR SURVEY
		<u>BRONX</u>						
WI	WI10	BRONX	2257 WALTON AVENUE	3/4" TAP, 1" LINE	SERVICE	24480	OCTOBER	SURV.
WI	WI10	BRONX	2257 WALTON AVENUE	DEFECTIVE HYDT VALVE	HYDT	1440	OCTOBER	SURV.
WATER SAVINGS FOR				WI10	25,920	GALLONS		
		<u>WI11</u>						
		<u>BRONX</u>						
WI	WI11	BRONX	189 EAST MOSHOLU PARKWAY NORTH	3/4" TAP, 1" LINE	SERVICE	24480	AUGUST	COMP.
WI	WI11	BRONX	2776 VALENTINE AVENUE	1" TAP, 1-1/2" LINE	SERVICE	64800	OCTOBER	COMP.
WI	WI11	BRONX	525 WEST 235TH STREET	DEFECTIVE HYDT VALVE	HYDT	1440	OCTOBER	SURV.
WI	WI11	BRONX	2530 DEKALB AVENUE	3/4" TAP, 1" LINE	SERVICE	24480	DECEMBER	COMP.
WI	WI11	BRONX	20 GUN HILL ROAD	1" HOLE IN 48" MAIN	MAIN BREAK	47740	DECEMBER	COMP.
WATER SAVINGS FOR				WI11	162,940	GALLONS		
		<u>WI12</u>						
		<u>BRONX</u>						
WI	WI12	BRONX	6141 TYNDELL AVE	8" CIRCUALR BREAK	MAIN BREAK	345880	JULY	COMP.

NC = NEWTOWN CREEK NR = NORTH RIVER WI = WARDS ISLAND

1/11/2002

PLANT	WPCP	BOROUGH	ADDRESS	CONDITION	LEAKTYP	GPDAMOUNT	MONTH	COMPLAINT OR SURVEY
WI	WI12	BRONX	RIVERDALE AVENUE && WE3ST 8" CIRCULAR BREAK 236TH STREET		MAIN BREAK	345990	AUGUST	COMP.
WI	WI12	BRONX	E/S BROADWAY S/O WEST 252NDDEFFECTIVE HYDT VALVE STREET		HYDT	1440	OCTOBER	SURV.
WI	WI12	BRONX	5470 MOSHOLU AVENUE	12" JOINT LEAK	JOINT	41300	DECEMBER	COMP.

WATER SAVINGS FOR WI12 734,610 GALLONS

WI WATER SAVINGS FOR WI 1,629,120.00 GALLONS

Grand Total:

TOTAL WATER SAVINGS FOR WARDS ISLAND 1,629,120.00 GALLONS

NC = NEWTOWN CREEK NR = NORTH RIVER WI = WARDS ISLAND