

3/12/02 I called
back the Toronto 20m
(ms. **PII**) - gave
her reports given me by mg -
Per DS - 9/30-10/5 date
① When were the tests taken? 9/13
② Someone coming tomorrow to
ck. the duct. (betw 10-2)
③ Wants to see report (told her
to call LeFrak)

2 Called in Shuella - BWTCH
Ref # 419243 DEP

13373

time	question	answer	category	comment	status	first
4:49:00	WTC SURVIVOR NEEDS MENTAL	GAVE FAMILY A			O	
4:45:00	PERSON NEEDS 9/11 AID DUE TO	GAVE SAFE HO			O	
4:22:00	CALLER NEEDS MONEY TO PAY B	GAVE SAFE HO			O	
4:08:00	CALLER NEEDS WTC STATISTICS	GAVE OEM OFF			O	
3:55:00	CALLER NEEDS WTC GROUND ZE	GAVE OEM PHCE			O	
3:18:00	CALLER NEEDS RED CROSS NUME	GAVE RED CRCO			O	
3:05:00	CALLER NEEDS NYC MEDICAL EX	GAVE NYS MEDO			O	

ID ~~13373~~ Date 3/11/02 Time 11:10 AM Category INDOOR AIR Status C = Close

Question Wants the Air tested in the apt; wants a prof. Hazard abatement

Answer Said landlord LeFrak did a cursory clean-up - still has duct in apt.

Comments Son is on medication (a Pump) which is getting worse

First Name **PII** Last Name **PII**

Address1 200 Gateway Plaza Address2 (near Liberty st.)

Address3 355 So. End Ave. Address4 **PII** City NYC State Zip Code

Phone1 (212) 786-3405 Phone2 Referral Agency/Org Referral/Follow-Up

~~DEP~~ D.O.H. N = No Yes

11/3/02 Left message that I have info. re the
Feet. To call me by 7:00pm on tomorrow 3/12/

Ree Marabetti

See ref. # 419243

13378

PII

Name of Operator Harold Robinson Date: 3/11/02 Time: 12:05 P

Category: (circle one)

Environment

Cleaning

Health

Specific Contaminant

School

Other _____

Question:

Can someone do an inspection of this apartment
bdg. because the landlord did not have a proper cleaning
done with hepa vacuums of the carpeting and vents
etc. Caller's son has asthma and is on medication.
Call has used a hepa vacuum in his own apartment.

Answer:

DEP will be notified and will respond.

Comments:

May need further info concerning asthma

Caller Information:

First Name:

PII

Last Name:

PII

Address 1:

355 South End Avenue

Apt:

PII

Address 2:

City

NYC

State:

NY

Zip:

Phone #1

W

(973)

Phone #2

H

PII

Follow up:

Referral/Follow-Up Needed? (circle one)

YES

NO

Referral Agency/Organization:

DEP

3/11/02

355 So. End Avenue (aka 200 Gateway Plaza) Apt. 20m

5 air samples taken on each floor Date
3 apt. + 2 common areas in hallways

All air samples were found to be below the AHERA.

(Asbestos Hazardous Emergency Response Act) Restriction millimeter²
for kids to reoccupy schools after an ACM clean-up)

Note : 9 bulk samples were taken on floor 20 - all
were found negative for asbestos

199 bulk samples were taken in the bldg.

193 samples were negative for asbestos

6 samples came back with trace amts.

of asbestos in apartments. These apts. were
abated for asbestos by a licensed asbestos
Contractor from an Environmental Consulting Firm.

NYC DEP

59-17 Junction Blvd.
Corona, NY 11358
(718)DEP-HELP Fax (718)596-4086

Service Request Inspection Detail

Report Date 03/11/2002 03:58 PM

Submitted By

Page 1

Service # 419243

Problem BWTCB WTC RELATED (HOT LINE)

Address 355 S END AVE 1

10280

Cross Streets ALBANY ST
LIBERTY ST

Compass Direction

Building ID 10833

Block 00016

Lot 0100

CMBD 101

Location

Area

Sub-Area 101

District

Parcel

of Calls 1

Duration of Call 00:00

Call Date 03/11/2002 13:51

Taken By 7146

MAYFIELD, CHERELLE

Responsibility BHZ

BANHAZMAT (AIR, NOISE, HAZ. MAT)

Scheduled Date

Priority

Inspector

Start Date

Due Date

Inspection Date

Resolution Code

☐ No Work Orders Required

Asset

Resolution Date

Avg Insp Duration

☐ Customer Contact Req

Avg Insp Days 0

Budget #

Avg Insp Hrs 0

Avg Insp Mins 0

Problem Comments

Last Name

First Name, MI

Address

PII

Monitoring & bulk sampling - no elevated asbestos levels (from Reso 178)

Title MS

City, State/Province, ZIP/PG

☐ Foreign

Day Phone (212)786-3405 x

Evening Phone

Call Date 03/11/2002 13:51

Reference #

Caller Comments

CLEAN UP ACCURRED IN APT HOWE-VER COMPLAINT FEEL THAT IT WAS NOT DONE PROPERLY, REQUESTING DEP TO INSPECT AND TEST AIR AND WANTS A PROFESSIONAL HAZMAT ABATEMENT. AS PER ROSE MARABETTI FROM LOWER MANHATTAN AIR QUALITY HOTLINE.

There are no work orders for this service number

There are no assets

No Linked Requests for this Service Request Inspection

Mar 11 '02 16:57 P.04

NYC DEP BANHAZMAT Exec Fax: 7185953744

NYC DEP

59-17 Junction Blvd.
 Corona, NY 11368
 (718)DEP-HELP Fax (718)595-4086

Service Request Inspection Detail

Report Date 03/13/2002 04:55 PM

Submitted By

Page 1

Service # 418243

Problem BWTCH WTC RELATED (HOT LINE)

Address 355 S END AVE 1
10280Cross Streets ALBANY ST
LIBERTY ST

Compass Direction

Building ID 10833

Block 00016

Lot 0100

CMBD 101

Location

Area

Sub-Area 101

District

Parcel

of Calls 1

Duration of Call 00:00

Call Date 03/11/2002 13:51

Taken By 7145

MAYFIELD, CHERELLE

Responsibility BH2

BANHAZMAT (AIR, NOISE, HAZ. MAT)

Priority

Scheduled Date

Start Date

Inspector

Inspection Date

Due Date

☐ No Work Orders Required

Resolution Code B35

AIR TESTING REQUESTED (WTC)

Resolution Date 03/13/2002 14:27

Asset

Avg Insp Duration

☐ Customer Contact Req

Budget #

Avg Insp Days 0

Avg Insp Hrs 0

Avg Insp Mins 0

Problem Comments The owner indicated to DEP that both air monitoring and bulk sampling were conducted in the building. The results indicated no elevated asbestos levels.

Last Name

First Name, MI

Address

PII

Title MS

City, State/Province, ZIP/PC

☐ Foreign

Day Phone

PII

Evening Phone

Call Date 03/11/2002 13:51

Reference #

Caller Comments

CLEAN UP ACCURRED IN APT HOWE=EVER COMPLAINT FEEL THAT IT WAS NOT DONE PROPERLY. REQUESTING DEP TO INSPECT AND TEST AIR AND WANTS A PROFESSIONAL HAZMAT ABATEMENT. AS PER ROSE MARABETTI FROM LOWER MANHATTAN AIR QUALITY HOTLINE.

There are no work orders for this service number

There are no assets