

DONOHUE ENVIRONMENTAL, INC.

39 Bowery #684 New York, New York 10002

Phone: 212 260-9818

Fax: 212 673-7215

February 7, 2002

PII
380 Rector Place, PII
New York, New York 10280

Re: Wipe sampling at 380 Rector Place, Apartment 16 G in New York City on 2/14/02.

Dear PII


Enclosed are the results of the fiber analysis for the TEM wipe samples collected on February 14, 2002. Results are presented on the enclosed tables.

Wipe samples were collected from the small bedroom window, living room window, and master bedroom window. Samples were analyzed with ASTM Method D-6480-99. Some asbestos fibers were found on the wipe samples. Asbestos structures were detected on all of the samples. We recommend that the apartment be wet wiped, HEPA vacuumed and the exposed furniture covering be washed. The dust on the outside of the windows should be considered asbestos containing dust and cleaned properly.

Bulk samples were collected from the air filters in the bedrooms and analyzed with PLM Microscopy, neither sample contained asbestos.

All analyses were performed by EMSE Analytical (ELAP 11506, NVLAP 101048-9). Feel free to call if you have any problems or need more information.

Sincerely,



Timothy J. Donohue
Donohue Environmental, Inc.

Post-It® Fax Note 7671		Date 3-4	# of pages 2
To Krish Radha Krishnan		From Jane	
Co./Dept.		Co.	
Phone # FYI		Phone #	
Fax #		Fax #	

2/15/2002 11:44 . 212-290-0058

EMSL MANHATTAN

PAGE 01

New York Lab

17 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

**Attn:** Donohoe Environmental, Inc.
80 Bowery #684
New York, NY 10002**Customer ID:** DHUE21
Customer PO:**Received:** 02/14/02 10:10 AM
EMSL Order: 030201084
EMSL Project ID:**Analysis Date:** 2/16/02**Phone:** (212) 673-7215 **Phone:** 212-290-0018
Project: 380 Rector Pl Apt 16G**Asbestos Analysis via Transmission Electron Microscopy ASTM Method D6480-99**

CELL ID	AREA SAMPLED (cm ²)	ASBESTOS TYPE	ASBESTOS STRUCTURES	Sensitivity (pcf/cm ²)	CONCENTRATION (pcf/cm ²)	COMMENTS
212TD001 02/15/2002	39	Chrysotile	106	8117.333	880437.333	
212TD002 02/15/2002	39	Chrysotile	112	6784.444	757617.778	
212TD003 02/15/2002	39	Chrysotile	85	4058.667	349045.333	

Laboratory Manager
or other approved signatoryThis report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc.
Micro-1

D.C. Robert Avaltroni

TEL:718-595-4544

Mar 04 02

7:54

Transmit Confirmation Report

No. : 1
 Receiver : D.C. LEF BANHezma
 Transmitter : D.C. Robert Avaltroni
 Date : Mar 04 02 7:54
 Time : 02'08
 Mode : Norm
 Pages : 02
 Result : OK