



Exhibit B:

Results from Asbestos, Mercury, and other Heavy Metals Testing

AMBIENT GROUP, INC.
10 MOFFATT AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: JOHN LEITNER

DATE COLLECTED: 9/27/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/29/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-04 DB2678	2ND FLOOR: SOUTH MIDDLE	CELLULOSE	14.0%
		FIBER GLASS	35.0%
		GRAVEL ROAD DUST	39.0%
		CARBON PARTICLES	10.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%
211453-05 DB2679	2ND FLOOR: NORTHWEST	CELLULOSE	13.0%
		FIBER GLASS	47.0%
		GRAVEL ROAD DUST	21.0%
		CARBON PARTICLES	10.0%
		CHRYSTILE	9.0%
		TOTAL	100.0%
211453-06 DB2680	2ND FLOOR: NORTH MIDDLE	CELLULOSE	17.0%
		FIBER GLASS	46.0%
		GRAVEL ROAD DUST	27.0%
		CARBON PARTICLES	10.0%
		CHRYSTILE	TRACE
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed, There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:35 PM

FAX NO.

P. 07

NYC-WTC_000154871

AMBIENT GROUP, INC.
10 MOFFAT AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: JOHN LEITNER

DATE COLLECTED: 9/27/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/29/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-07 DB2681	2ND FLOOR: SOUTHWEST	CELLULOSE	18.0%
		FIBER GLASS	41.0%
		GRAVEL ROAD DUST	29.0%
		CARBON PARTICLES	10.0%
		RUST	TRACE
		CHRYSTILE	2.0%
		TOTAL	100.0%
211453-08 DB2682	3RD FLOOR: EAST MIDDLE	CELLULOSE	15.0%
		FIBER GLASS	46.0%
		GRAVEL ROAD DUST	27.0%
		CARBON PARTICLES	10.0%
		CHRYSTILE	2.0%
211453-09 DB2683	3RD FLOOR: NORTHEAST	CELLULOSE	15.0%
		FIBER GLASS	55.0%
		GRAVEL ROAD DUST	20.0%
		CARBON PARTICLES	10.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed, There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:36 PM

FAX NO.

P. 08

NYC-WTC_000154872

1000 AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: JOHN LEITNER

DATE COLLECTED: 9/27/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/29/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-10 DB2684	3RD FLOOR: SOUTHEAST	CELLULOSE	15.0%
		FIBER GLASS	50.0%
		GRAVEL ROAD DUST	23.0%
		CARBON PARTICLES	10.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%
211453-11 DB2685	3RD FLOOR: SOUTHWEST CORNER	CELLULOSE	15.0%
		FIBER GLASS	30.0%
		GRAVEL ROAD DUST	33.0%
		CARBON PARTICLES	20.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%
211453-12 DB2686	3RD FLOOR: "A" STAIRWAY	CELLULOSE	15.0%
		WOOD FIBER	40.0%
		GRAVEL ROAD DUST	30.0%
		CARBON PARTICLES	15.0%
		DECAYED ORGANIC MATTER	TRACE
		AMOSITE	TRACE
		CHRYSTILE	TRACE
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed, There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:36 PM

FAX NO.

P. 10

NYC-WTC_000154873

AMBIENT GROUP, INC.
10 MOI AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: JOHN LEITNER

DATE COLLECTED: 9/27/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/29/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-13 DB2687	3RD FLOOR: WEST MIDDLE	CELLULOSE	15.0%
		FIBER GLASS	45.0%
		GRAVEL ROAD DUST	20.0%
		CARBON PARTICLES	18.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%
211453-14 DB2688	4TH FLOOR: WEST, CAFETERIA	CELLULOSE	15.0%
		FIBER GLASS	40.0%
		GRAVEL ROAD DUST	30.0%
		CARBON PARTICLES	13.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%
211453-15 DB2689	4TH FLOOR: NORTHWEST	CELLULOSE	15.0%
		FIBER GLASS	45.0%
		GRAVEL ROAD DUST	20.0%
		CARBON PARTICLES	18.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed, There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:36 PM

FAX NO.

P. 11

NYC-WTC_000154874

10 MOI AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: JOHN LEITNER

DATE COLLECTED: 9/27/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/29/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-16 DB2690	4TH FLOOR: NORTHWEST	CELLULOSE	10.0%
		FIBER GLASS	45.0%
		GRAVEL ROAD DUST	23.0%
		CARBON PARTICLES	20.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%
211453-17 DB2691	4TH FLOOR: NORTH MIDDLE	CELLULOSE	10.0%
		FIBER GLASS	45.0%
		GRAVEL ROAD DUST	26.0%
		CARBON PARTICLES	15.0%
		CHRYSTILE	4.0%
		TOTAL	100.0%
211453-18 DB2692	4TH FLOOR: NORTHEAST	CELLULOSE	10.0%
		FIBER GLASS	40.0%
		GRAVEL ROAD DUST	25.0%
		CARBON PARTICLES	20.0%
		CHRYSTILE	5.0%
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed, There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:37 PM

FAX NO.

P. 13

NYC-WTC_000154875

10 MO. AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: JOHN LEITNER

DATE COLLECTED: 9/27/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/29/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-19 DB2693	4TH FLOOR: WEST MIDDLE	CELLULOSE	15.0%
		FIBER GLASS	45.0%
		GRAVEL ROAD DUST	20.0%
		CARBON PARTICLES	18.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%
211453-20 DB2694	4TH FLOOR: SOUTHEAST	CELLULOSE	10.0%
		FIBER GLASS	45.0%
		GRAVEL ROAD DUST	28.0%
		CARBON PARTICLES	15.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%
211453-21 DB2695	4TH FLOOR: EAST	CELLULOSE	10.0%
		FIBER GLASS	45.0%
		GRAVEL ROAD DUST	25.0%
		CARBON PARTICLES	15.0%
		CHRYSTILE	5.0%
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed, There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:37 PM

FAX NO.

AMBIENT GROUP, INC.
10 MCARDEN AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: JOHN LEITNER

DATE COLLECTED: 9/27/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/29/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-25 DB2699	5TH FLOOR: MER	CELLULOSE	10.0%
		FIBER GLASS	50.0%
		GRAVEL ROAD DUST	20.0%
		CARBON PARTICLES	16.0%
		CHRYSTILE	4.0%
		TOTAL	100.0%
211453-26 DB2700	5TH FLOOR: MER	CELLULOSE	10.0%
		FIBER GLASS	45.0%
		GRAVEL ROAD DUST	30.0%
		CARBON PARTICLES	11.0%
		CHRYSTILE	4.0%
		TOTAL	100.0%
211453-27 DB2701	5TH FLOOR: ADJACENT TO 5 - 7	CELLULOSE	15.0%
		FIBER GLASS	41.0%
		GRAVEL ROAD DUST	20.0%
		CARBON PARTICLES	20.0%
		CHRYSTILE	4.0%
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed, There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:38 PM

FAX NO.

P. 17

NYC-WTC_000154877

AMBIENT GROUP, INC.
10 MCLELLAN AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: JOHN LEITNER

DATE COLLECTED: 9/27/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/29/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-28 DB2702	5TH FLOOR: MER	CELLULOSE	15.0%
		FIBER GLASS	50.0%
		GRAVEL ROAD DUST	19.0%
		CARBON PARTICLES	10.0%
		CHRYSTOLE	6.0%
		TOTAL	100.0%
211453-29 DB2703	5TH FLOOR: ADJACENT TO "A" STAIRWAY FOR MER	CELLULOSE	15.0%
		FIBER GLASS	45.0%
		GRAVEL ROAD DUST	20.0%
		CARBON PARTICLES	18.0%
		CHRYSTOLE	2.0%
		TOTAL	100.0%
211453-30 DB2704	5TH FLOOR: MER CHILLERS	CELLULOSE	15.0%
		FIBER GLASS	45.0%
		GRAVEL ROAD DUST	25.0%
		CARBON PARTICLES	15.0%
		CHRYSTOLE	TRACE
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed, There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:38 PM

FAX NO.

P. 18

NYC-WTC_000154878

AMBIENT GROUP, INC.
10 MONROE AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: JOHN LEITNER

DATE COLLECTED: 9/27/01
DATE RECEIVED: 9/28/01
DATE ANALYZED: 9/29/01

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-37 DB2711	7TH FLOOR: NORTHWEST INTERIOR	CELLULOSE	15.0%
		FIBER GLASS	55.0%
		GRAVEL ROAD DUST	15.0%
		CARBON PARTICLES	15.0%
		CHRYSONITILE	TRACE
		TOTAL	100.0%
211453-38 DB2712	7TH FLOOR: JAME QUARARELLA	CELLULOSE	10.0%
		FIBER GLASS	60.0%
		GRAVEL ROAD DUST	18.0%
		CARBON PARTICLES	10.0%
		CHRYSONITILE	2.0%
		TOTAL	100.0%
211453-39 DB2713	7TH FLOOR: NORTHWEST SIDE	CELLULOSE	30.0%
		FIBER GLASS	45.0%
		GRAVEL ROAD DUST	20.0%
		CARBON PARTICLES	5.0%
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed. There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:38 PM

FAX NO.

P. 19

NYC-WTC_000154879

AMBIENT GROUP, INC.
10 MORRIS AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: PETER SCHORK

DATE COLLECTED: 9/28/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/30/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-8-03 DB2659	8TH FLOOR: NE CORNER B	CELLULOSE	10.0%
		FIBER GLASS	40.0%
		CEMENT DUST	40.0%
		CARBON PARTICLES	8.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%
211453-8-04 DB2660	8TH FLOOR: MIDDLE OF WEST WALL B	CELLULOSE	10.0%
		FIBER GLASS	40.0%
		CEMENT DUST	40.0%
		CARBON PARTICLES	8.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed, There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:38 PM

FAX NO.

P. 21

NYC-WTC_000154880

AMBIENT GROUP, INC.
10 MONTAGU AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: PETER SCHORK

DATE COLLECTED: 9/28/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/30/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-9-01 DB2621	9TH FLOOR: NW CORNER B	FIBER GLASS	40.0%
		CEMENT DUST	40.0%
		CARBON PARTICLES	18.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%
211453-9-02 DB2622	9TH FLOOR: MIDDLE OF NORTH WALL B	CELLULOSE	10.0%
		FIBER GLASS	40.0%
		CEMENT DUST	40.0%
		CARBON PARTICLES	8.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed, There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:39 PM

FAX NO.

P. 23

NYC-WTC_000154881

AMBIENT GROUP, INC.
10 MORRIS AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: PETER SCHORK

DATE COLLECTED: 9/28/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/30/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-10-01 DB2666	10TH FLOOR: NW CORNER B	CELLULOSE	10.0%
		FIBER GLASS	40.0%
		GRAVEL ROAD DUST	40.0%
		CARBON PARTICLES	7.0%
		CHRYSTOLE	3.0%
		TOTAL	100.0%
211453-10-02 DB2667	10TH FLOOR: MIDDLE OF NORTH WALL B	CELLULOSE	10.0%
		FIBER GLASS	40.0%
		CEMENT DUST	40.0%
		CARBON PARTICLES	8.0%
		CHRYSTOLE	2.0%
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed, There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:39 PM

FAX NO.

P. 25

NYC-WTC_000154882

AMBIENT GROUP, INC.
10 MORRIS AVENUE
GLEN COVE, NY 11542

DUST CHARACTERIZATION LABORATORY DATA REPORT

PROJECT ID: 211453
CLIENT: CUSHMAN & WAKEFIELD, INC.
LOCATION: 130 LIBERTY STREET
TECHNICIAN: PETER SCHORK

DATE COLLECTED: 9/28/2001
DATE RECEIVED: 9/28/2001
DATE ANALYZED: 9/30/2001

FIELD ID LABORATORY ID	DESCRIPTION	SAMPLE CONSTITUENTS	PERCENT OF SAMPLE **
211453-19-01 DB2603	19TH FLOOR: NW CORNER B	CELLULOSE	10.0%
		FIBER GLASS	40.0%
		CEMENT DUST	40.0%
		CARBON PARTICLES	9.2%
		CHRYSTILE	0.8%
		TOTAL	100.0%
211453-19-02 DB2604	19TH FLOOR: MIDDLE OF NORTH WALL B	CELLULOSE	10.0%
		FIBER GLASS	40.0%
		CEMENT DUST	40.0%
		CARBON PARTICLES	8.0%
		CHRYSTILE	2.0%
		TOTAL	100.0%

Signed for Ambient Group Inc. by,

TAREK FATA

ND = None Detected, NA = Not Analyzed. There are two (2) types of dust sample submitted for analysis: Settled = Samples submitted on tape/bulk, Airborne = Samples submitted in Air-O-Cell Cassettes. All results disclosed in this report relate only to the items tested. No reproduction of all or any portion of this report shall occur without written approval of Ambient Group Inc. Unless otherwise directed by the Client, Ambient Group Inc. will retain the samples listed in this report for five (5) days, after which time they may be disposed of in accordance with applicable regulations.

JUN-10-2002 MON 05:40 PM

FAX NO.

P. 27

NYC-WTC_000154883



AMBIENT GROUP, INC.

10 Morris Avenue, Glen Cove, NY 11542
Phone: (516) 609-0009 - Fax: (516) 609-8271

Laboratory Report
AGL01955

Bulk Asbestos Analysis by Polarized Light Microscopy

NVLAP ID#101618-0; NY ELAP ID#10865

Client:	Cushman & Wakefield a/a/f Deutsche Bank	Job Number:	211909
Address:	130 Liberty Street	Date Received:	02/13/2002
	New York NY 10005	Date Analyzed:	2/16/02
Collected By:	Customer	Job Location:	130 Liberty Street
Collected:	02/09/2002		

Lab ID Field ID	Sample Location	Sample Description	Asbestos Detected	Asbestos Type (%)	Non-Asbestos Constituents
0001955-001 14-A-01	14th Floor: NE Corner	LAYER# 1 Wall System, Gray, Non- homogeneous, Coarse	Yes	Chrysotile 2%	Cellulose Fiber 20% Mineral Wool 40% Non-Fibrous Material 38%
0001955-002 14-A-02	14th Floor: Middle of North Wall	LAYER# 1 Wall System, Gray, Non- homogeneous, Coarse	Yes	Chrysotile 2%	Cellulose Fiber 30% Mineral Wool 40% Non-Fibrous Material 28%
0001955-003 14-A-03	14th Floor: NW Corner	LAYER# 1 Wall System, Non-homogeneous, Coarse	Yes	Chrysotile 3%	Cellulose Fiber 30% Mineral Wool 40% Non-Fibrous Material 27%
0001955-004 12-A-01	12th Floor: NE Corner	LAYER# 1 Wall System, Gray, Non- homogeneous, Coarse	Yes	Chrysotile 0.5%	Cellulose Fiber 40% Mineral Wool 30% Non-Fibrous Material 29.5%
0001955-005 12-A-02	12th Floor: Middle of North Wall	LAYER# 1 Wall System, Non-homogeneous, Coarse	Yes	Chrysotile 0.5%	Cellulose Fiber 40% Mineral Wool 30% Non-Fibrous Material 29.5%
0001955-006 12-A-03	12th Floor: NW Corner	LAYER# 1 Wall System, Non-homogeneous, Coarse	Yes	Chrysotile 0.5%	Cellulose Fiber 30% Mineral Wool 40% Non-Fibrous Material 29.5%
0001955-007 11-A-01	11th Floor: NE Corner	LAYER# 1 Wall System, Non-homogeneous, Coarse	Yes	Chrysotile 0.3%	Cellulose Fiber 20% Mineral Wool 30% Non-Fibrous Material 49.2%
0001955-008 11-A-02	11th Floor: Middle of North Wall	LAYER# 1 Wall System, Gray, Non- homogeneous, Coarse	Yes	Chrysotile 0.5%	Cellulose Fiber 20% Mineral Wool 30% Non-Fibrous Material 49.5%

Ambient Group, Inc.
10 Morris Avenue
Glen Cove, NY 11542
ELAP # 10865

Client: Cushman Wakefield a/a/f Deutsche Bank
Address: 130 Liberty Street
Project ID: 211909

Project ID	Date Collected	Field ID	Floor/Location	Asbestos Wipes (str/cm ²)					
211909	4/22/02	211909-01	Level B/Metal Shelf (No Ceiling)	Chrysotile (3,257)					
211909	4/22/02	211909-10	Level B/Top Of Vending Machine	Chrysotile (608,692)					
211909	4/22/02	211909-10P	Level B/Top Of Light Fixture	Chrysotile & Amosite (57,001)					
211909	4/22/02	211909-02	Level B/Metal Shelf (No Ceiling)	Chrysotile & Amosite (97,716)					
211909	4/22/02	211909-03	Level B/Folder (12 Ft Ceiling - 1/2 Missing)	Chrysotile (42,751)					
211909	4/22/02	211909-09	Level B/Elevator Pit Room #23 (No Ceiling)	Chrysotile (59,037)					
211909	4/22/02	211909-11	Level B/Tabletop (12 Ft Ceiling - 1/2 Missing)	Chrysotile (150,646)					
211909	4/22/02	211909-04	Level B/Box On Shelf (12 Ft Ceiling - 1/4 Missing)	Chrysotile (46,822)					
211909	4/22/02	211909-05	Level B/Top Of Copy Machine	Chrysotile (209,683)					
211909	4/22/02	211909-05P	Level B/Top Of Light Fixture	Chrysotile & Amosite (8,143)					
211909	4/22/02	211909-06	Level B/Tabletop (No Ceiling)	ND					
211909	4/22/02	211909-07	Level B/Side Of Cabinet (No Ceiling)	Chrysotile (57,001)					
211909	4/22/02	211909-08	Level B/Top Of Desk (No Ceiling)	Chrysotile (81,430)					

211909 A,B, and 1st Floor Asb Wipe summary Level B

0106666717 VVJ / 0:01 2007/11/00

AMBIENT GROUP

TTA 00

NYC-WTC_000154885

Ambient Group, Inc.
10 Morris Avenue
Glen Cove, NY 11542
ELAP # 10885

Client: Cushman Wakefield a/a/f Deutsche Bank
Address: 130 Liberty Street
Project ID: 211909

Project ID	Date Collected	Field ID	Floor/Location	Asbestos Wipes (str/cm ²)					
211909	4/22/02	211909-14P	Level A/Ceiling Light Fixture	Chrysotile (1,357)					
211909	4/22/02	211909-20	Level A/Top Of Desk (Ceiling 3/4 Missing)	Chrysotile (105,860)					
211909	4/22/02	211909-13	Level A/Top Of Desk	Chrysotile (38,679)					
211909	4/22/02	211909-13P	Level A/Ceiling Light Fixture	Chrysotile (1,016)					
211909	4/22/02	211909-12	Level A/Top Of Desk	Chrysotile (657,550)					
211909	4/22/02	211909-12P	Level A/Ceiling Light Fixture	Chrysotile (44,787)					
211909	4/22/02	211909-17	Level A/Floor Tile	Chrysotile (21,986)					
211909	4/22/02	211909-17P	Level A/Ceiling Light Fixture	Chrysotile (48,858)					
211909	4/22/02	211909-19	Level A/Floor Tile	Chrysotile (36,644)					
211909	4/22/02	211909-19P	Level A/Ceiling Light Fixture	Chrysotile (40,716)					
211909	4/22/02	211909-18	Level A/Top Of Orange Machine (No Ceiling)	Chrysotile (27,686)					
211909	4/22/02	211909-21	Level A/Top Of Automatic Door Frame	Chrysotile (81,430)					
211909	4/22/02	211909-21P	Level A/Ceiling Light Fixture	Chrysotile (225,969)					
211909	4/22/02	211909-15	Level A/Top Of Desk	Chrysotile (50,487)					
211909	4/22/02	211909-15P	Level A/Ceiling Light Fixture	Chrysotile (20,358)					

211909 A,B, and 1st Floor Asb Wipe summary Level A

06/11/2002 13:07 FAX 212946018

AMBIENT GROUP

NYC-WTC_000154886

Client: Cushman Wakefield a/a/f Deutsche Bank
Address: 130 Liberty Street
Project ID: 211909

Project ID	Date Collected	Field ID	Floor/Location	Asbestos Wipes (str/cm ²)					
211909	4/23/02	211909-23	1st Floor/Top Of Table	Chrysotile (213,889)					
211909	4/23/02	211909-23P	1st Floor/Ceiling Light Fixture	Chrysotile (79,144)					
211909	4/23/02	211909-24	1st Floor/Top Of Wood Shelf (Low Ceiling)	Chrysotile (348,234)					
211909	4/23/02	211909-25	1st Floor/Top Of Wood Desk	Chrysotile (158,288)					
211909	4/23/02	211909-25P	1st Floor/Ceiling Light Fixture	Chrysotile (522,350)					
211909	4/23/02	211909-26	1st Floor/Top Of Heater	Chrysotile (316,576)					
211909	4/23/02	211909-26P	1st Floor/Ceiling Light Fixture	Chrysotile (229,518)					
211909	4/23/02	211909-27	1st Floor/Floor In Corner (20 Ft Tile Ceiling)	Chrysotile (205,774)					
211909	4/23/02	211909-29	1st Floor/Floor In Corner	Chrysotile (102,887)					
211909	4/23/02	211909-30	1st Floor/In Between Two Escalators	Chrysotile (253,261)					
211909	4/23/02	211909-35	1st Floor/Top Of Metal Shelf	Chrysotile (41,154.9)					
211909	4/22/02	211909-33	1st Floor/Top Of Computer Table	Chrysotile (159,845)					
211909	4/22/02	211909-33P	1st Floor/Ceiling Light Fixture	Chrysotile (3,054)					
211909	4/22/02	211909-31	1st Floor/Top Of Desk	Chrysotile (61,073)					
211909	4/22/02	211909-31P	1st Floor/Top Of Ceiling Light Fixture	Chrysotile (122,146)					

211909 A,B, and 1st Floor Asb Wipe summary 1st Floor

Client: Cushman Wakefield a/a/f Deutsche Bank
Address: 130 Liberty Street
Project ID: 211909

Project ID	Date Collected	Field ID	Floor/Location	Asbestos Wipes (str/cm ²)					
211909	4/22/02	211909-32	1st Floor/Top Of Desk	Chrysotile (81,430)					
211909	4/22/02	211909-32P	1st Floor/Ceiling Light Fixture	Chrysotile (49,673)					
211909	4/22/02	211909-34	1st Floor/Top Of Computer Desk	Chrysotile (663,658)					
211909	4/22/02	211909-34P	1st Floor/Ceiling (On Duct Work)	Chrysotile (40,715)					

211909 A,B, and 1st Floor Asb Wipe summary 1st Floor

130 Liberty Street
Bulk Heavy Metals Results
Occupied Areas surveyed on September 28, 2001
Air Plenums and Ducts surveyed January 16 to 19, 2002
Elevators surveyed January 21 and 22, 2002

Floor #	Area	Range of Results (ppm)						Notes
		Cadmium	Chromium	Copper	Lead	Nickel	Zinc	
28	Occupied area	-	-	-	-	-	-	
	Return air plenum	<0.341 - 2.92	27 - 383	51 - 1680	<22.7 - 346	18.7 - 68	402 - 2840	
	Supply air ducts	-	-	-	-	-	-	
27	Occupied area	13.8 - 22	61 - 67	371 - 678	189 - 318	11.7 - 56	1667 - 1757	
	Return air plenum	<0.985 - 18.3	15.1 - 488	16.1 - 392	4.23 - 303	<11.6 - 73	230 - 2140	
	Supply air ducts	-	-	-	-	-	-	
26	Occupied area	-	-	-	-	-	-	
	Return air plenum	<1.16 - 16.3	34 - 154	19.9 - 587	10.4 - 399	<5.78 - 69.4	98.3 - 2170	
	Supply air ducts	-	-	-	-	-	-	
25	Occupied area	15.9 - 68	65 - 203	403 - 2122	339 - 554	60 - 122	1892 - 2568	
	Return air plenum	<0.389 - 12.9	129 - 1390	55 - 2720	29 - 2070	40 - 504	595 - 16700	
	Supply air ducts	-	-	-	-	-	-	
24	Occupied area	-	-	-	-	-	-	
	Return air plenum	3.08 - 9.77	58.1 - 166	164 - 2040	128 - 345	<19.1 - 43	1330 - 3250	
	Supply air ducts	-	-	-	-	-	-	
23	Occupied area	14.9 - 17.8	82 - 89	383 - 439	311 - 342	36 - 71	1976 - 2167	
	Return air plenum	4.92 - 73	84 - 227	97 - 986	107 - 3820	36 - 98	980 - 39000	
	Supply air ducts	-	-	-	-	-	-	
22	Occupied area	-	-	-	-	-	-	
	Return air plenum	<0.579 - 6.01	33 - 241	59.2 - 593	<15 - 338	19.4 - 50.8	626 - 4080	
	Supply air ducts	-	-	-	-	-	-	
21	Occupied area	5.6 - 16.7	65.7 - 157	162 - 1090	111 - 894	16 - 52.7	1250 - 5240	
	Return air plenum	-	-	-	-	-	-	
	Supply air ducts	-	-	-	-	-	-	
20	Occupied area	-	-	-	-	-	-	
	Return air plenum	-	-	-	-	-	-	
	Supply air ducts	-	-	-	-	-	-	
19	Occupied area	5.41 - 5.91	71.0 - 78.8	120 - 125	50 - 55	10 - 11	869 - 941	
	Return air plenum	-	-	-	-	-	-	
	Supply air ducts	-	-	-	-	-	-	
18	Occupied area	-	-	-	-	-	-	
	Return air plenum	-	-	-	-	-	-	
	Supply air ducts	-	-	-	-	-	-	

9106666717 VAF 01:01 2002/11/00

AMBIENT GROUP

2700

NYC-WTC_000154889

130 Liberty Street
Bulk Heavy Metals Results
Occupied Areas surveyed on September 28, 2001
Air Plenums and Ducts surveyed January 16 to 19, 2002
Elevators surveyed January 21 and 22, 2002

Floor #	Area	Range of Results (ppm)						Notes
		Cadmium	Chromium	Copper	Lead	Nickel	Zinc	
17	Occupied area	5.94 - 6.13	85.15 - 93.22	135.15 - 166.74	63.37 - 101.09	15 - 17	1114 - 1173	
	Return air plenum	-	-	-	-	-	-	
	Supply air ducts	-	-	-	-	-	-	
16	Occupied area	-	-	-	-	-	-	
	Return air plenum	<2.93 - 19.2	58.8 - 199	336 - 1530	87.1 - 702	24 - 61	519 - 3200	
	Supply air ducts	-	-	-	-	-	-	
15	Occupied area	4.71 - 6.56	62 - 64	102 - 124	34 - 48	7.06 - 9.26	773 - 976	
	Return air plenum	-	-	-	-	-	-	
	Supply air ducts	-	-	-	-	-	-	
14	Occupied area	-	-	-	-	-	-	
	Return air plenum	-	-	-	-	-	-	
	Supply air ducts	-	-	-	-	-	-	
12	Occupied area	6.04 - 6.61	84 - 90	136 - 145	48 - 61	10.5 - 11.3	1043 - 1047	
	Return air plenum	6.67 - 8.63	77 - 109	146 - 1220	193 - 306	27 - 37	1190 - 43900	
	Supply air ducts	-	-	-	-	-	-	
11	Occupied area	5.92 - 6.28	109 - 142	126 - 148	39 - 66	16.6 - 22	900 - 953	
	Return air plenum	-	-	-	-	-	-	
	Supply air ducts	-	-	-	-	-	-	
10	Occupied area	5.08 - 5.74	95 - 149	103 - 168	37 - 72	12.6 - 24	789 - 1008	
	Return air plenum	-	-	-	-	-	-	
	Supply air ducts	-	-	-	-	-	-	
9	Occupied area	5.6 - 9.08	124 - 144	165 - 218	32.9 - 103	16.4 - 23	956 - 1598	
	Return air plenum	-	-	-	-	-	-	
	Supply air ducts	-	-	-	-	-	-	
8	Occupied area	12.5 - 44	53 - 56	197 - 200	170 - 172	9.21 - 14.0	1149 - 1245	
	Return air plenum	6.44 - 18.3	78 - 158	225 - 756	173 - 455	29 - 57	1350 - 2620	
	Supply air ducts	-	-	-	-	-	-	
7	Occupied area	7.93 - 14.8	61 - 87	132 - 183	9.01 - 137	10.8 - 11.0	984 - 1184	
	Return air plenum	5.27 - 10.3	74 - 153	189 - 706	160 - 340	23 - 54	1150 - 3580	
	Supply air ducts	-	-	-	-	-	-	
5	Occupied area	4.69 - 5.81	55 - 71	77 - 171	38 - 233	8.71 - 11.3	1162 - 3113	
	Return air plenum	5.43 - 49	64 - 127	150 - 399	101 - 279	19.5 - 35	1640 - 9640	
	Supply air fans	2.77 - 41	54 - 182	113 - 686	165 - 2750	16.1 - 48	2270 - 16600	

AMBIENT GROUP

06/11/2002 13:10 FAX 2129444618

NYC

NYC-WTC_000154890

00TQ546272 VVY DT:CT Z00Z/TT/00

AMBIENT GROUP