

Gilsenan, Michael

From: Theodorellys, Penny
Sent: Tuesday, April 01, 2003 8:14 AM
To: tahern@etsets.net; bmiddleton@etsets.net
Cc: Radhakrishnan, Krish; Gilsenan, Michael
Subject: 114Liberty(JLC).xls

Look at the Asbestos at the end of the table. Failing results highlighted. Blanks haven't received results.

Make sure you increase crew size to accommodate re-cleaning and completion of the restaurant. We need to come to a closure on this project.

I'll keep in touch throughout the day.



114Liberty(JLC).xls

Floor/Unit	Lead pre-Floor	Lead pre-Wall	Lead pre-Counter	Dioxin pre-Floor	Dioxin pre-wall	Dioxin pre-Counter	PAHs pre-floor
1st Floor							
1st Floor							
1st Floor							
1st Floor							
1st Floor							
1st Floor Pizza							
1st Floor Newstand							
2nd Floor Restaurant							
2nd Floor Weight Watchers							
3rd Floor Ente Optometrist							
3rd Floor Universal Podiatry							
3rd Floor/302	43	<20	<20				
4th Floor	56	<20	39				
5th Floor	125	<20	59				
6th Floor	<20	<20	<20				
7th Floor	35.5	<20	<20				
8th Floor	<20	<20	<20				
9th Floor	26.5	<20	60.5				
10th Floor	87.5	<20	57.5				
11th Floor (PH)	<20	32	128				
12th Floor (PH)	483	<20	<20				

PAHs pre-wall	PAHs pre-counter	Fibrous Glass	Silica	Asbestos pre-3/5/03	Asbestos 3/6/03	Asbestos 3/7/03	Asbestos 3/8/03	Asbestos 3/9/03
					<0.0009	<0.0009	<0.0009	<0.0009
					<0.0009	<0.0009	<0.0009	<0.0009
					<0.0009	OL	<0.0009	<0.0009
					0.0009	OL	OL	<0.0009
					<0.0009	OL	OL	<0.0009

<0.0009

<0.0009

<0.0009

<0.0009

<0.0009

Asbestos	Asbestos	Asbestos	Asbestos	Asbestos	Asbestos	Asbestos	Asbestos	Asbestos
3/10/03	3/11/03	3/12/03	3/13/03	3/14/03	3/15/03	3/16/03	3/17/03	3/18/03
<0.0009	<0.0009	<0.0009	<0.0009	0.0018	<0.0009	<0.0009	<0.0009	<0.0009
0.0009	0.0009	<0.0009	0.0009	0.0018	<0.0009	<0.0009	<0.0009	0.0009
0.0009	0.0009	0.0018	0.0009	<0.0009	<0.0009	<0.0009	<0.0009	<0.0009
<0.0009	<0.0009	0.0009	0.0009	<0.0009	<0.0009	0.0018	<0.0009	<0.0009
<0.0009	<0.0009	<0.0009	0.0009	OL	<0.0009	<0.0009	<0.0009	<0.0009

Asbestos 3/19/03	Asbestos 3/20/03	Asbestos 3/21/03	Asbestos 3/22/03	Asbestos 3/23/03	Asbestos 3/24/03	Asbestos 3/25/03	Asbestos 3/26/03	Asbestos 3/27/03
<0.0009	<0.0009	<0.0009	<0.0009	<0.0009		<0.0009	0.0018	<0.0009
<0.0009	<0.0009	<0.0009	<0.0009	0.0009		<0.0009	<0.0009	0.0009
<0.0009	<0.0009	<0.0009	0.0009	0.0009		<0.0009	OL	<0.0009
<0.0009	<0.0009	<0.0009	<0.0009	<0.0009		<0.0009	<0.0009	0.0009
<0.0009	<0.0009	<0.0009	<0.0009	<0.0009		<0.0009	<0.0009	<0.0009

Lead Post	Lead Post	Lead Post	Asbestos	Asbestos	Asbestos	Asbestos	Asbestos
3/29/03	3/29/03	3/29/03	Clearance	Clearance	Clearance	Clearance	Clearance

			<0.0004	<0.0004			
			<0.0004	<0.0004	<0.0004		
			<0.0004	<0.0004	<0.0004		
<9µg/ft ²	<9µg/ft ²	<9µg/ft ²	<0.0004	<0.0004	<0.0004	<0.0004	<0.0004
<9µg/ft ²	<9µg/ft ²	<9µg/ft ²					
<9µg/ft ²	<9µg/ft ²	<9µg/ft ²					
<9µg/ft ²	<9µg/ft ²	<9µg/ft ²					
<9µg/ft ²	<9µg/ft ²	<9µg/ft ²	0.0027				
<9µg/ft ²	<9µg/ft ²	<9µg/ft ²	0.0025	0.0018	OL	0.0009	0.0009
12.5µg/ft ²	<9µg/ft ²	<9µg/ft ²	0.0018	0.0018	0.0013	0.0013	0.0004
<9µg/ft ²	<9µg/ft ²	<9µg/ft ²	OL	OL	OL	OL	OL
<9µg/ft ²	<9µg/ft ²	<9µg/ft ²	<0.0004	<0.0004	<0.0004	<0.0004	<0.0004
12µg/ft ²	<9µg/ft ²	<9µg/ft ²	<0.0004	<0.0004	<0.0004	<0.0004	<0.0004