

cc: DiMartino
 Farag
 D.Smith
 Patel
 Suspense
 CP:lp

Copy to:
 Mr. Barney LaGrecca, P.E.
 Chief Engineer
 Division of Street Design
 Bureau of Highway Operations
 N.Y.C. Dept. of Transportation
 40 Worth Street
 New York, N.Y. 10013

11016
 4-15-85

April 15, 1985

Mr. Charles Rathjen, P.E.,
 Government Liaison
 The Port Authority of NY & NJ
 One World Trade Center
 New York, NY 10048

RE: Contract L.T.-268, Lincoln Tunnel-New York Approach, Repair to Bridges over the New York Expressway and Dyer Avenue, Borough of Manhattan.

Dear Mr. Rathjen:

This is in reply to your submittal of drawings with a letter dated March 29, 1985 regarding the above referenced contract.

The drawings as submitted do not indicate new drainage work to be included in the contract. It has been our experience that inadequate drainage is a major cause of deterioration of elevated structures in N.Y.C. Please find attached recent guidelines for N.Y.C.D.O.T. bridge drainage structure.

Very truly yours,

MAGDI FARAG, P.E., CHIEF,
 Div. Sewer Regulation & Control
 Bureau of Sewers

DISPATCHED

APR 17 1985

WATER POLLUTION CONTROL
 MAIL ROOM

10: SMITH
2/85
THE PORTAL AUTHORITY OF NY & NJOne World Trade Center
New York, N.Y. 10048(212) 466-7000
(201) 622-6600RECEIVED
BUREAU OF SEWERS

APR 1 - 1985

DIVISION OF
SEWER REGULATION
AND CONTROL

March 29, 1985

Mr. Barney LaGreca, P.E.
Chief Engineer - Street Design
The City of New York
Department of Transportation
Bureau of Highway Operations
40 Worth Street, Room 1104
New York, NY 10013

SUBJECT: LINCOLN TUNNEL - NEW YORK APPROACH - REPAIR TO
BRIDGES OVER THE NEW YORK EXPRESSWAY AND DYER AVENUE
CONTRACT: LT-268

Dear Mr. LaGreca:

Attached are two sets of drawings and specifications for the subject contract for your review. The bridges are sections of W. 34th, W. 35th, W. 37th, W. 38th and W. 39th Streets between 9th and 10th Avenues, Manhattan. It is requested that any comments from your office be received by this office by April 26, 1985 so we may meet our construction schedule.

Additionally, by copy of this letter, it is requested the agencies and utilities listed below also provide comments within the specified time frame.

Should there be any technical questions, you may contact Ralph Melendez directly at (212) 466-7135.

Thank you for your continued cooperation.

Very truly yours,

Charles Rathjen
Charles Rathjen, P.E.
Government Liaison

11016
MAY 4 1985

Att.

CC: See attachment

Writer's direct dial telephone: (212) 466-7773

CC Attachments: 2 Sets of drawings & specifications

N.Y.C. Bureau of Water Supply
Attention: Mr. Martin Englehardt, P.E.
Chief, Planning & Programs

✓ N.Y.C. Bureau of Sewers
Attention: Mr. Magdi Farag, P.E.
Chief, Division of Sewer
Regulation & Control

N.Y.C. Bureau of Electrical Control
Attention: Mr. Joseph Mackey, P.E.
Assistant Director
Division of Engineering

Empire City Subway Company
Attention: Mr. Earl Willoughby, P.E.
Manager, Engineering
Design/Construction

Consolidated Edison
Attention: Mr. John Brower
Liaison Representative