

I talked to Mumfah 613-5187 on Oct. 14, 1987. He told me that in Section D on sheet no. 55, drawing no. 5-22, the slab of the tunnel section in the fifth floor has been designed as a beam & that deflection is .006" which is negligible.

R.A.

Also we ~~are~~ are not checking each and every comp. of Structural design.