

CITY OF NEW YORK  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF SEWER  
INTER - DEPARTMENT  
MEMORANDUM April 9 1984

HAND DELIVERED  
Date APR 11 1984

TO: FRANK SAIA, P.E., ACTING CHIEF, DIVISION OF SEWER MAINTENANCE  
FROM: MAGDI FARAG, P.E., CHIEF, ENGINEERING REVIEW SECTION  
SUBJECT: PARK AVENUE TUNNEL EMERGENCY EXITS IMPROVEMENT AT 59TH STREET,  
BOROUGH OF MANHATTAN

---

We have received a proposal from Leroy Callender, P.C., on behalf of Metro North which calls for the rehab. and modernization of the emergency R.R. Tunnel Exits in Park Avenue at 59th Street.

The proposal calls for framing the structure loads down to footings at elevations close to the top of the two existing Park Avenue sewers (7'-3" circular-eastside, 4'-0" X 2'-8"-Westside).

It will be necessary to examine the interior of each sewer before and after construction operations. We are interested specifically in those locations under the existing column footings. These have been stationed off on the attached drawings. Please take photographs at these locations to ascertain if the existing condition has affected the sewer.

This office has been unable to obtain "As-Built" information for these two sewers.

ATTACHMENT.

**DISPATCHED**

APR 11 1984

MAGDI FARAG, P.E., CHIEF  
Engineering Review Section

WATER POLLUTION CONTROL  
MAIL ROOM

cc: DiMartino  
Novotny  
Farag  
Nagy  
Suspense  
MN:lp

8393  
4.9.84