

Copies to: Joseph Medler & Luk Sun Wong
Dept. of Police & Terminals
Battery Maritime Building
New York, N.Y. 10004

Mr. Heimbush
Clark & Rapallo Inc.
215 Lexington Avenue
New York, N.Y. 10006

March 2, 1982

John T. Dwyer
Consentini Associates
2 Pennsylvania Plaza
New York, N.Y. 10121

Re: Interpid Museum Project,
Pier 86 at W.46th Street

BOROUGH OF MANHATTAN

Dear Mr. Dwyer:

This is in reply to your letter of February 18, 1982 wherein SD 182 applications and related site plans for the above project were submitted to this office for processing.

Our examination of your plans indicates that a building structure is to be erected within the filled-in portion of Pier 86 directly over an existing double barrel 6'-6" x 8'-6" sewer outfall. Such a structure could have an adverse affect on our maintenance or reconstruction capabilities of the sewer. Since your drawings do not provide any details as to the type of structure or the method of installation, it is impossible to access the extent of the impact on our sewer or to make any determination as to the acceptability of this proposal.

It is requested that you submit detailed drawings indicating the following:

1. Type of building structure.
2. Location of footings (both horizontally and vertically with respect to the sewer) or other foundation structures over the sewer.
3. Net vertical clearance (if any) from the building to ground surface over the sewer.

Please note that no further processing of your house connection application can be performed until the aforementioned drawings have been submitted to and reviewed by this office.

cc: DiMartino
Novotny
Farag
Uriko/Sirico
Lau
Tartaro
Suspense

Very truly yours,

MAGDI FARAG, P.E., ACTING CHIEF,
Div. Sewer Regulation & Control
Bureau of Sewers

NL:im

CoSENTINI Associates

CONSULTING ENGINEERS

Two Pennsylvania Plaza, New York, N.Y. 10121

Telephone (212) 564-7200 Telex-WUI-666447

M. A. Mass, P. E.
J. Weisbin, P. E.
D. Michaeli, P. E.
D. Mozur, P. E.
A. Tinfo, P. E.

To: ~~State~~
MT 2/24/82
Unkr
FT
512100

February 18, 1982

Department of Water Resources
Bureau of Sewers
40 Worth Street
New York, N.Y. 10013

Att: Mr. Nolan Lau
Drainage Section

Re: Intrepid Museum
Our Job No 2673

Gentlemen:

Per yesterday's discussion we are resubmitting herein, our Dec. 21
submittal to the Department for review and approval of the sanitary
sewer house connection.

Concerning the question of salt water use for flushing please be
advised that all waste water flushing uses fresh water.

Thank you for your assistance in this matter.

Very truly yours,

COSENTINI ASSOCIATES

John T. Dwyer
John T. Dwyer

STD/sm
Encl.

cc: H. Kistler

303 East Wacker Drive
Chicago, Ill. 60601

Tillon
Morse
Diesel
730-
4167

Handwritten notes and stamps
44 Brattle Street
Cambridge, Mass. 02138



DEPARTMENT OF PORTS AND TERMINALS
Battery Maritime Building, New York, N.Y. 10004
Telephone: 212-248- 8592
Linda W. Neale, Commissioner

LNU
2/17/82

February 9, 1982

Mr. Ado Uriko
Chief Sewers Information
Bureau of Sewers
Dept. of Environmental Protection
40 Worth Street
New York, NY 10013

RE: Intrepid Museum Project
Pier 86, North River, Manhattan
DPT Work Permit #810136

Dear Mr. Uriko:

The Department of Ports and Terminals and the Intrepid Museum Foundation, Inc., a non-profit educational organization, have been working closely over the past two years towards the establishment of an air, sea and space museum on board the aircraft carrier USS Intrepid. The Intrepid Museum will be permanently berthed on the southside of Pier 86 located at the foot of West 46th Street.

The Foundation has completed its financing and has entered into a long-term leasing arrangement with this Department for the operation of a museum at Pier 86. In order to generate revenues to cover debt service on the financing, the Museum must open to the public on July 4th of 1982. To meet this scheduled opening date, they have filed for Work Permits with the Department of Ports and Terminals relating to all the construction work for the ship and pier. We have been advised that the Foundation's engineers, Cosentini Associates have also filed with the Department of Environmental Protection, specifically with your office, the Bureau of Sewers, requesting approval of the sanitary sewer connection to the City sewer mains located along 12th Avenue and West 46th Street. Your expeditious review of their plans concerning this matter would be greatly appreciated.

Since this project is a major waterfront development priority for the City the Department and the Foundation would be prepared to schedule a briefing for you in order to facilitate the review process. If you have any comments or questions related to this project, please contact the Project Manager, Luk Sun Wong at 248-8592 or me at 248-8048.

Very truly yours,

Joseph H. Medler
Joseph Medler
Chief Engineer

LSW/pak
cc: Robert Brugger, A/C, DEP
A/C Benguiat
L.S. Wong

AVE
D. Tillon

MAR 2 2002