

Vollmer Associates

11 West 19th Street New York NY 10011
212 691 3800

March 9, 1987

Mr. Douglas Smith
Bureau of Sewers
40 Worth Street
New York, NY 10013

Re: 7 World Trade Center
Paver's Plan
Borough of Manhattan

Dear Mr. Smith:


We are submitting herewith three (3) sets of revised pavers plans in response to the comments made in a meeting held on February 27, 1987 between you and Jerry Blaustein of the Highway Department.

The plans are revised as follows:

1. The crosswalk running east-west over Washington Street on the north side of Vesey Street has been narrowed. This will allow the existing catch basin at the northeast corner of this intersection to remain in place.
2. The proposed 10" "house connection" accommodating storm drainage from the pedestrian bridge has been added to the plans.
3. Note 'F' has been added to Drawing 'BP-2' as per wording received from Jerry Blaustein.

At this time we request your review and approval of these drawings. If you have any questions, please call.

Very truly yours,


Stuart E. Lerner

SEL:sfs
86057-00
Enclosure

cc: Jerry Blaustein (DOT Paver's Section)
Robert Washlick (Tishman)
Harold Jupiter (Silverstein Development)
Soad Doss (Bureau of Sewers)

EP 3-00013
DATE 3-12-87

An Equal Opportunity Employer